

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Sunday				Date : 03.03.24			
Probable Maximum Demand : 11800 MW					Probable Maximum Generation : 12962 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.70 ft				Today = 83.62 ft			
					Rule Curve = 92.68 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.03.24 (Yesterday)		03.03.24 (Today)		02.03.24 (Yesterday)		03.03.24 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	180	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	411	409	412	412			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	136	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	25			
15	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	38	40	40			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	18	14	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	115	48	133			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	85	195	95			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	10	100	18			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	0	17			
28	Meghnaghat 104 MW PP (OFSL)	HFO (IPP)	6x18.5	104	104	0	17	17	17			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	35	35			
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	33	0	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	0	8			
33	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	9	17	17			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	62	64	80			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	24	24			
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			540	370	0	0	0			Test run
	Meghnaghat 589 MW CCPP(Summit)	Gas										Test run
Dhaka Zone Total					5655	5062	1760	2189	2058	2120	948	740
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	35	35	190		Inadequate Water Level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
41	Teknaf 20MW PP (Solutech)	Solar (IPP)	1x20	20	20	0	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
44	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	221	220	220			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	104	65	100			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	25	25	25			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	34	51			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	68	40	64			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	7	5	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	15	15			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	13	25	25	25			
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	9	126	35	127			
58	Chattogram 2162MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	374	440	390	390			
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	155	318	500	500			
	Cox's Bazar Wind PP	(Wind) (IPP)				11	7	40	40			Test run
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				67	0	20	0			Test run
Chattogram Zone Total					4404	4344	983	1546	1557	1725	370	330
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	44	44	45	45			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	145	150	150	150			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	305	300	300	55		Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	250	335	280	280	65		Gas Shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+1116	195	195	0	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	24	0	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	6	6			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	40	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	4	33	35	35			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9			
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	16	11	17			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	1	80	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	0	69	36	78			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	52	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	39	18	36			
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	30	47	40	45			
**	Import (Tripura)	India		160	160	102	128	128	141			
Cumilla Zone Total					2959	2951	946	1441	1373	1457	667	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	39	35	70	163		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	69	9	9			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	59	68			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0			
87	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total					622	614	204	123	155	153	163	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.03.24 (Yesterday)		03.03.24 (Today)		02.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	27	42	42	42		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	28	30	30		62	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	50	50				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	20	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	0	0	0	0			Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	206	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	285	310	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	349	339	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	344	340	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	98	0	0	0			Test run	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	44	44				
Sylhet Zone Total						2472	2427	1539	1450	1531	1531	0	420
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	94				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	341	643	400	400				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	916	630	927	927				
Khulna Zone Total						3241	3237	1347	1283	1462	1541	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	135	140	140		59	ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	750	810	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	54				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	140	140				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
Barishal Zone Total						2265	2265	1164	1321	1740	1793	0	59
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	12	0	21				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	43	50	90				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	50				
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	146	170	180	74		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	280	287	414	414	127		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	0	35				
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1150	1299	1400	1400				
Raishahi Zone Total						3653	3631	1590	1824	2196	2391	702	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	35	6				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	50	35	75				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	174	0	130	0				
Rangpur Zone Total						1030	950	417	220	408	251	189	85
Sub-total: Plants in operation						26301	25481	9950.0	11397	12480	12962	3449	1897
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	9950	11397	12480	12962	3449	1897

(C) Actual data of 02.03.24 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	11470	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11069	MW, at =	19:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	11397	MW, at =	19:00 hrs			MW	MW			MW	MW
04.	Minimum Generation (Generation end)	:	7303	MW, at =	5:00 hrs		Dhaka	4160	4145	15	Mymensingh	1002	947
05.	Day-peak Generation (Generation end)	:	9950	MW, at =	12:00 hrs		Chattogram	1061	1061	0	Sylhet	386	386
06.	Evening-peak Generation (Generation end)	:	11397	MW, at =	19:00 hrs		Khulna	1281	1281	0	Barishal	309	309
07.	Evening Peak Load-shed (Sub-station end)	:	70	MW, at =	19:00 hrs		Rajshahi	1186	1186	0	Rangpur	762	762
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7913	MW, at =	5:00 hrs		Cumilla	922	922	0			
09.	Generation shortfall at evening peak due to :	:									Total	11069	10999
	a) Gas/LF limitation	:	3070	MW			13.	Fuel cost :	(a) Gas = 317819292 Taka	(c) Coal = 510954872 Taka			
	d) Coal supply Limitation	:	189	MW				(b) Oil = 211750302 Taka	Total = 1040524465 Taka				
	b) Low water level in Kaptai lake	:	190	MW									
	c) Plants under shut down/ maintenance	:	1897	MW			14.	Maximum Temperature in Dhaka was :	30.5°C				
10.	Total Energy (Generation + India Import)	:	229.51	MKWh			15.	Export through East-West interconnections :					
	By Gas = 116.561 MKWH			By Oil = 11.806 MKWh				At evening peak-hour	:	9950	MW, at	19:00 hrs	
	By Coal = 74.916 MKWH			By Hydro = 0.826 MKWh				Maximum	:	680	MW, at	8:00 hrs	
	By Solar = 3.295 MKWH							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	857.67	MMCFD									
(D) Forecast of 03.03.24 (Today) Sunday :													
01.	Maximum Demand	:	11800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12962	MW	(Generation end)	05.	Total Generation	:	237.62	MKWh			
03.	Reserve / Shortage	:	1162	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.5°C				

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation