

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Monday				Date : 04.03.24							
Probable Maximum Demand : 12000 MW					Probable Maximum Generation : 13609 MW											
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.62 ft				Today = 83.52 ft				Rule Curve = 92.50 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.24 (Yesterday)		04.03.24 (Today)		03.03.24 (Yesterday)		04.03.24 (Today)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)					
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date					
(A) Plants in operation:																
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0					0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	150	130	150							
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI				
4	Ghorshal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage				
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0							
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450							
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling				
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	413	421	412	412							
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	332	334	335	335							
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	49	15	50							
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8							
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0							
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	21	40	40	40							
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	33	33	33	33							
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	18	18	25	25							
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17							
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	100							
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	140	48	133							
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17							
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	60	95	130							
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	94	17	17	35							
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17							
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17							
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17							
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	35	17							
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0							
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17							
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	8	8							
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	17	17							
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	20	0	68	85							
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	12	0	24	24							
36	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
	Meghnaghat Unique Power	Gas			0	0	0	0	0			Test run				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			Test run				
Dhaka Zone Total				5655	5062	1740	1944	1837	2154	948	740					
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190		Inadequate Water Level				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.				
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0							
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17							
41	Teknaf 20MW PP (Solutech)	Solar (IPP)	1x20	20	20	19	0	20	0							
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20							
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	15	17	17	17							
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.				
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	215	220	220							
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	102	65	100							
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25							
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	34	51							
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	9	59	40	64							
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10							
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	14	5	10							
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	4	0	0							
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	15	0	0	17							
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	12	17	15	15							
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25							
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	25	0	25	25							
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17							
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	126	35	127							
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	404	485	400	450							
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	156	155	156	450							
	Cox's Bazar Wind PP	(Wind) (IPP)				18	16	40	40			Test run				
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				62	0	20	0			Test run				
Chattogram Zone Total				4404	4344	1203	1414	1228	1740	370	330					
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	43	44	44							
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	142	41	200	200							
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	270	300	300	90		Gas Shortage				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage				
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	340	395	330	350							
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+116	195	195	54	8	8	8	187		Gas Shortage				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51							
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	6	6	6							
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	40	40							
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	36	34	35	35							
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0							
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9							
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33							
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	25	8	8							
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	16	11	17							
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	89	17	114	114							
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.3	113	113	8	26	28	78							
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17							
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	33	0	36							
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	44	51	44	51							
**	Import (Tripura)	India		160	160	110	138	128	141							
Cumilla Zone Total				2959	2951	1317	1261	1406	1538	637	163					
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	72	35	70	130		Gas Shortage				
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0							
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9							
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	68	59	68							
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0							
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0							
87	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6							
Mymensingh Zone Total				622	614	145	155	155	153	130	0					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.24 (Yesterday)		04.03.24 (Today)		03.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	38	38	42	42		Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30	60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	0	0	50			
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	63	65	65			
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0		Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	130	150	150			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	0	0	0	0	0			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	24	17	17			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	295	310	310			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	366	400	400			
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	340	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	48	0	0	44			
Sylhet Zone Total					2472	2427	1503	1459	1587	1681	0	422
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	94			
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0			
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			
114	Nacopara 40 MW PP (Khangshan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	855	988	750	750			
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	909	626	648	936			
Khulna Zone Total					3241	3237	1827	1614	1533	1900	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	48			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	136	140	140	58	ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	1060	1200	1200			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	54			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220			
Barishal Zone Total					2265	2265	1084	1562	1740	1809	0	58
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	25	25			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	21			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	50	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	40	50			
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42			
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	38			
132	Siragajonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Siragajonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Siragajonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	160	140	170	180	80	Gas Shortage	
135	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	332	414	414	82	Gas Shortage	
136	Ulipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35			
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Siragajonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1116	1413	1400	1400			
Raishahi Zone Total					3653	3631	1699	2194	2196	2383	663	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	6	35	6			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	40	55	35	75			
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	15	0	30	0			
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	161	0	130	0			
Rangpur Zone Total					1030	950	425	231	408	251	189	85
Sub-total: Plants in operation					26301	25481	10943.0	11834	12090	13609	3347	1898

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0	
Gross Total					26504	25481	10943	11834	12090	13609	3347	1898

(C) Actual data of 03.03.24 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	11930	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11419	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	11834	MW, at =	19:00 hrs	Dhaka	4366	4366	0	Mymensingh	1015	923
04.	Minimum Generation (Generation end)	:	7913	MW, at =	5:00 hrs	Chattogram	1098	1098	0	Sylhet	392	392
05.	Day-peak Generation (Generation end)	:	10943	MW, at =	12:00 hrs	Khulna	1324	1324	0	Barishal	315	315
06.	Evening-peak Generation (Generation end)	:	11834	MW, at =	19:00 hrs	Rajshahi	1165	1165	0	Rangpur	775	775
07.	Evening Peak Load-shed (Sub-station end)	:	92	MW, at =	19:00 hrs	Cumilla	969	969	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8132	MW, at =	5:00 hrs					Total	11419	11327
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 344469150 Taka	(c) Coal = 626872786 Taka			
	a) Gas/LF limitation	:	2968	MW				(b) Oil = 257445838 Taka	Total = 1226787774 Taka			
	d) Coal supply Limitation	:	189	MW		14.	Maximum Temperature in Dhaka was : 31.4°C					
	b) Low water level in Kaptai lake	:	190	MW		15.	Export through East-West interconnections :					
	c) Plants under shut down/ maintenance	:	1898	MW			At evening peak-hour	:	10943	MW, at	19:00 hrs	
10.	Total Energy (Generation + India Import)	:	245.55	MKWh			Maximum	:	720	MW, at	7:00 hrs	
	By Gas = 113.023 MKWH			By Oil = 14.274 MKWh			Energy	:	0	MKWh		
	By Coal = 91.707 MKWH			By Hydro = 0.816 MKWh								
	By Solar = 2.837 MKWH											
11.	Total Gas Supplied	:	848.58	MMCFD								

(D) Forecast of 04.03.24 (Today) Monday :												
01.	Maximum Demand	:	12000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13609	MW	(Generation end)	05.	Total Generation	:	248.99	MKWh		
03.	Reserve / Shortage	:	1609	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.4°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation