

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Wednesday				Date : 06.03.24			
Probable Maximum Demand : 12300 MW					Probable Maximum Generation : 13503 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.40 ft				Today = 83.31 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.24 (Yesterday)		06.03.24 (Today)		05.03.24 (Yesterday)		06.03.24 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	170	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	391	422	412	412			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	300	300			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	156	154	155	155	181		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	15	55	55			
15	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	37	39	39			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	24	24	28	28			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	88	17	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	133	64	133			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	121	95	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	40	17	17	35			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	35	17			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	35	0	35			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	21	8	16			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	8	17	17			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	68	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	24	24			
36	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			Test run
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			Test run
Dhaka Zone Total				5655	5062	1826	2228	2064	2301	794	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190		Inadequate Water Level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	4	17	8	17			
41	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	0	20	0	20			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	215	220	220			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	68	121	65	121			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	4	51	34	51			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	64	40	64			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	23	5	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	15	15			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	25	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	125	35	127			
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	450	451	470	470			
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	725	721	730	730			
	Cox's Bazar Wind PP	(Wind) (IPP)				9	9	40	40			Test run
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				66	0	20	0			Test run
Chattogram Zone Total				4404	4344	1777	2004	1872	2061	370	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	42	44	44			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	39	222	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	270	310	310	90		Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	285	285	260	260			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+1116	195	195	65	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	41	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	32	40	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	36	34	35	35			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9			
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	20	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	2	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	15	17			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	52	52	100	100			
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	14	47	28	78			
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	0	36			
80	Ashuganj 55 MW PP (Precision)	Gas (NENP)	1514	55	55	47	15	32	32			
**	Import (Tripura)	India		160	160	130	134	128	141			
Cumilla Zone Total				2959	2951	1099	1305	1349	1450	637	163	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	70	66	70	132		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	67	59	68			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	1.6	0	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
87	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				622	614	154	152	186	153	132	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.24 (Yesterday)		06.03.24 (Today)		05.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	39	42	42		31	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	20	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	0	0	0	0			Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	135	150	150				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	290	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	365	365	365	365				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	325	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	96	100	100			Test run	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1454	1486	1632	1642	0	421
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	6	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	94				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	626	627	622	622				
116	Khulna 330 MW CCPP	Gas/HSD (BPDDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	921	638	938	650				
Khulna Zone Total						3241	3237	1638	1271	1695	1486	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	100	131	140	140		63	ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	690	700	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1154	1197	1772	1790	0	63
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	8	0	21				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	40	50				
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	16	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	167	170	180	53		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	384	316	350	350	98		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	30	0	35				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1016	1228	1400	1400				
Raishahi Zone Total						3653	3631	1562	1961	2135	2322	652	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	54	40	35				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	56	93	35	93				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	42	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	208	0	130	0				
Rangpur Zone Total						1030	950	483	317	413	298	189	85
Sub-total: Plants in operation						26301	25481	11147.0	11921	13118	13503	3184	1902
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	11147	11921	13118	13503	3184	1902

(C) Actual data of 05.03.24 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	12040	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11619	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	11921	MW,	at =	19:00 hrs	Dhaka	4375	4360	15	Mymensingh	1023	924
04.	Minimum Generation (Generation end)	:	8285	MW,	at =	5:00 hrs	Chattogram	1114	1114	0	Sylhet	382	382
05.	Day-peak Generation (Generation end)	:	11147	MW,	at =	12:00 hrs	Khulna	1374	1374	0	Barishal	310	310
06.	Evening-peak Generation (Generation end)	:	11921	MW,	at =	19:00 hrs	Rajshahi	1235	1235	0	Rangpur	812	812
07.	Evening Peak Load-shed (Sub-station end)	:	114	MW,	at =	19:00 hrs	Cumilla	995	995	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8334	MW,	at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:									Total	11619	11505
a)	Gas/LF limitation	:	2805	MW			13.	Fuel cost :	(a) Gas = 356627380 Taka	(c) Coal = 616782248 Taka			
d)	Coal supply Limitation	:	189	MW					(b) Oil = 240129681 Taka	Total = 1213539309 Taka			
b)	Low water level in Kaptai lake	:	190	MW									
c)	Plants under shut down/ maintenance	:	1902	MW			14.	Maximum Temperature in Dhaka was :	30.5°C				
10.	Total Energy (Generation + India Import)	:	248.33	MKWh			15.	Export through East-West interconnections :					
	By Gas = 117.398 MKWH							At evening peak-hour	:	11147	MW,	at	19:00 hrs
	By Coal = 91.778 MKWH							Maximum	:	720	MW,	at	7:00 hrs
	By Solar = 3.696 MKWH							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	872.09	MMCFD									
(D) Forecast of 06.03.24 (Today) Wednesday :													
01.	Maximum Demand	:	12300	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13503	MW	(Generation end)		05.	Total Generation	:	256.22	MKWh		
03.	Reserve / Shortage	:	1203	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.5°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation