

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9584667, 9551085

Month March, 2024				Day : Friday				Date : 08.03.24						
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 13258 MW				Rule Curve = 91.88 ft						
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 83.17 ft		Today = 82.89 ft		08.03.24 (Yesterday)		08.03.24 (Today)				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	07.03.24 (Yesterday)		08.03.24 (Today)		07.03.24 Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		08.03.24 (Yesterday) Machines shut down (MW)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
(A) Plants in operation:														
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	150	150	170	170					
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
4	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGP		
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	0	0	0	0	108		Gas Shortage		
6	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
8	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
9	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
11	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	364	398	412	412					
12	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
13	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	270	335	335	335					
14	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	134	157	155	155	178		Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	15	30					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
18	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	32	32	39	39					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	18	28	28					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	100					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	133	64	133					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	97	95	130					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	35					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	0	17	35					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	18	8	18					
34	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	0	0	17	17					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	32	48	85	85					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	24	24					
37	Katpottii 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
38	Meghnaghat Unique Power	Gas			0	0	0	0	0			Test run		
39	Meghnaghat 589 MW CCGP(Summit)	Gas			0	0	0	0	0			Test run		
Dhaka Zone Total				5655	5062	1689	2144	2049	2339	791	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190		Inadequate Water Level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	20					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	26	17	17					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	217	211	220	220					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	68	140	65	121					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	25	25					
49	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	34	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	40	64					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
52	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	13	10	25					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	15	15					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
57	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	12	25	25	25					
58	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	125	126	35	127					
60	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	270	285	470	470					
61	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	363	567	730	730					
62	Cox's Bazar Wind PP	(Wind) (IPP)				41	34	40	40			Test run		
63	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				66	0	25	0			Test run		
Chattogram Zone Total				4404	4344	1399	1648	1882	2076	370	330			
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	47	44	44					
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	221	227	225	225					
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	270	290	310	310	70		Gas Shortage		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360		Gas Shortage		
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	250	70	300	300					
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	120	8	8	75		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	41	48	0	50					
69	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	35	35					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9					
73	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	16	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	17					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*19.78	114	114	70	114	100	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	37	28	78					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	40	0	36					
80	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	47	49	50	50					
81	** Impoport (Tripura)	India		160	160	120	120	128	141					
Cumilla Zone Total				2959	2951	1247	1318	1367	1532	505	163			
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	28	42	65	70	160		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.03.24 (Yesterday)		08.03.24 (Today)		07.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :							
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	42	42		28	Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	53	53								
91	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163								
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0								
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	62	65	65								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17								
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	290	300								
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	365	365	365								
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	280	253	200	200								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	90	0	0	0			Test run					
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	48	48	48								
Sylhet Zone Total						2472	2427	1340	1328	1283	1293	0	418				
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage					
107	Ferdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50								
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	5	0	70								
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	94								
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0								
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0								
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0								
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0								
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	1260	630	630	630								
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0								
**	Bheramara (HVEDC)	India		1000	1000	911	633	937	649								
Khulna Zone Total						3241	3237	2255	1268	1702	1493	410	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	48								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	124	140	140		70	ST under maint.					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	930	1200	1200								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35								
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0								
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220								
Barishal Zone Total						2265	2265	924	1296	1632	1650	0	70				
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	25	25								
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	21								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90								
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	40	50								
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38								
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	173	200	200	47		Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	317	392	414	414								
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	8	8								
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0								
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55								
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	30	0	35								
140	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0								
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1116	1396	1400	1400								
Rajshahi Zone Total						3653	3631	1611	2250	2229	2406	548	100				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage					
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18x 2*3	113	113	35	6	40	35								
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
147	Majpara, Tatalia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0								
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	111	35	111								
149	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0								
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	180	0	130	0								
Rangpur Zone Total						1030	950	425	287	413	316	189	85				
Sub-total: Plants in operation						26301	25481	11037.0	11663	12742	13258	2973	1906				
(B) Plants under long term maintenance/ contract expired																	
151	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
152	Bosila 108MW PP(CIC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0				
Gross Total						26504	25481	11037	11663	12742	13258	2973	1906				
(C) Actual data of 07.03.24 (Yesterday) Thursday :																	
01.	Max. Demand at eve. peak (Generation end)	:	11750 MW, at =	19:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	11423 MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	11663 MW, at =	19:00 hrs		Dhaka	4274	4274	0	Mymensingh	1006	923	83				
04.	Minimum Generation (Generation end)	:	8254 MW, at =	5:00 hrs													
05.	Day-peak Generation (Generation end)	:	11037 MW, at =	11:00 hrs		Chattogram	1164	1164	0	Sylhet	386	386	0				
06.	Evening-peak Generation (Generation end)	:	11663 MW, at =	19:00 hrs		Khulna	1292	1292	0	Barishal	299	299	0				
07.	Evening Peak Load-shed (Sub-station end)	:	83 MW, at =	19:00 hrs		Rajshahi	1221	1221	0	Rangpur	824	824	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8246 MW, at =	5:00 hrs		Cumilla	957	957	0								
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :		(a) Gas = 354406118 Taka	(c) Coal = 610873068 Taka								
	a) Gas/LF limitation	:	2594 MW					(b) Oil = 291962004 Taka	Total = 1257241190 Taka								
	d) Coal supply Limitation	:	189 MW			14. Maximum Temperature in Dhaka was :		30.6°C									
	b) Low water level in Kaptai lake	:	190 MW			15. Export through East-West interconnections :											
	c) Plants under shut down/ maintenance	:	1906 MW			At evening peak-hour		:	11037 MW, at	19:00 hrs							
10.	Total Energy (Generation + India Import)	:	248.07 MKWh			Maximum		:	700 MW, at	8:00 hrs							
	By Gas = 114.658 MKWh					Energy		:	0 MKWh								
	By Coal = 90.100 MKWh																
	By Solar= 3.337 MKWh																
11.	Total Gas Supplied	:	872.63 MMCFD														
(D) Forecast of 08.03.24 (Today) Friday :																	
01.	Maximum Demand	:	11000 MW (Generation end)			04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	13258 MW (Generation end)			05.	Total Generation	:	233.97 MKWh								
03.	Reserve / Shortage	:	2258 MW (Generation end)			06.	Probable Max. Temperature in Dhaka :	:	30.6°C								