

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9584667, 9551095

Month March, 2024					Day : Saturday					Date : 09.03.24				
Probable Maximum Demand :					11600 MW					Probable Maximum Generation : 12694 MW				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.89 ft					Today = 82.76 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	08.03.24 (Yesterday)		09.03.24 (Today)		08.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW					
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	140	200	200	200					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HSP/		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	0	0	0	0	108	Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0		Contract Expired			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	420	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	375	420	412	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage			
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	260	335	335	335					
13	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	155	155	155	180	Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	8	8					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	31	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	21	28	28					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	100					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	133	48	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	35					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	17					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	17	35					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	8	8					
33	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	0	8	17	17					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	70	96	96					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	24	24					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			0	0	0	0	0			Test run		
	Meghnaghat 589 MW CCGP(Summit)	Gas			0	0	0	0	0			Test run		
Dhaka Zone Total					5655	5062	1421	2141	2076	2386	793	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
40	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	207	206	220	220					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	80	65	135					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	10	25	25					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	51					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	24	40	64					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			20	35	10	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	15	15	15					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	17	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	25	25					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	108	53	127					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	293	278	300	300					
59	Matbarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	575	456	364	364					
	Cox's Bazar Wind PP	(Wind) (IPP)				30	34	40	40			Test run		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				71	0	25	0			Test run		
Chattogram Zone Total					4404	4344	1261	1394	1371	1539	380	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	47	47	47					
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	146	101	225	225					
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	305	275	310	310	85	Gas Shortage			
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Gas Shortage			
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	330	335	300	300					
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	83	0	0	112	Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	5	6	6					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	20	0	50					
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	33	40	34	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	9	9	9					
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	17	17	17					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	18	17	17					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*19.78	114	114	70	70	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	55	57	28	78					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	0	36					
80	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	5	52	32	50					
**	Impoport (Tripura)	India		160	160	118	118	128	141					
Cumilla Zone Total					2959	2951	1208	1359	1343	1510	557	163		
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	34	42	35	48	160	Gas Shortage			
82	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9					
84	Myensingpur 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	59	65	59	68					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0					
87	Tangali 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	6	0	6					
Myensinging Zone Total					622									

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.03.24 (Yesterday)		09.03.24 (Today)		08.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42	28	Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	29	30	30	61	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0			
91	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
92	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	63	65	65			
94	Shahjibazar 330 MW CCPP	Gas (RPP)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 68 MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0		Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	122	132	132			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	17	17	17			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	305	290	300			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	320	369	365	365			
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	170	190	200	200			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0			
Sylhet Zone Total					2472	2427	1210	1310	1314	1324	0	419
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Ferdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0	50		
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	18x6.98	109	109	0	10	0	70			
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	94			
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	92	0	100	0			
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	441	530	500	500			
116	Khulna 330 MW CCPP	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVC)	India		1000	1000	919	635	945	656			
Khulna Zone Total					3241	3237	1452	1175	1580	1370	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	80	135	135	114	ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	810	700	1200	1200			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1164	1006	1689	1707	0	114
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	21			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	50			
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	16	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	161	189	200	200	31	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	409	380	414	414			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	35	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	0	35			
140	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	5	0	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	917	1097	1400	1400			
Rajshahi Zone Total					3653	3631	1497	1671	2264	2406	532	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18x 2*3	113	113	42	33	40	40			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	113	35	111			
149	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0			
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	182	0	130	0			
Rangpur Zone Total					1030	950	434	316	413	321	189	85
Sub-total: Plants in operation					26301	25481	9803.0	10494	12205	12694	3021	1951
(B) Plants under long term maintenance/ contract expired												
151	Jamalganj 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosilia 108MW PP(CIC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					203	0	0	0	0	0	0	0
Gross Total					26504	25481	9803	10494	12205	12694	3021	1951

(C) Actual data of 08.03.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	10535	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10201	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10494	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	8246	MW, at =	5:00 hrs	Dhaka	3490	3490	0	Mymensingh	968	929	39
05.	Day-peak Generation (Generation end)	:	9803	MW, at =	12:00 hrs	Chattogram	1031	1031	0	Sylhet	363	363	0
06.	Evening-peak Generation (Generation end)	:	10494	MW, at =	19:00 hrs	Khulna	1224	1224	0	Barishal	285	285	0
07.	Evening Peak Load-shed (Sub-station end)	:	39	MW, at =	19:00 hrs	Rajshahi	1147	1147	0	Rangpur	785	785	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7865	MW, at =	5:00 hrs	Cumilla	907	907	0				
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	2632	MW		13.	Fuel cost :	(a) Gas = 348662842	Taka	(c) Coal = 521539778	Taka		
	d) Coal supply Limitation	:	189	MW	(b) Oil = 138935212			Taka	Total = 1009137831	Taka			
	b) Low water level in Kaptai lake	:	200	MW									
	c) Plants under shut down/ maintenance	:	1951	MW		14.	Maximum Temperature in Dhaka was : 31°C						
10.	Total Energy (Generation + India Import)	:	226.75	MKWh		15.	Export through East-West interconnections :						
	By Gas = 114.258 MKWh		By Oil = 7.538 MKWh			At evening peak-hour	:	9803	MW, at	19:00 hrs			
	By Coal = 77.820 MKWh		By Hydro = 0.772 MKWh			Maximum	:	640	MW, at	9:00 hrs			
	By Solar= 3.567 MKWh					Energy	:	0	MKWh				
11.	Total Gas Supplied	:	876.88	MMCFD									
(D) Forecast of 09.03.24 (Today) Saturday :													
01.	Maximum Demand	:	11600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12694	MW	(Generation end)	05.	Total Generation	:	250.65	MKWh			
03.	Reserve / Shortage	:	1094	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31°C				

* Co-firing Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation