

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Monday					Date : 11.03.24				
Probable Maximum Demand : 12300 MW					Probable Maximum Generation : 13179 MW					Rule Curve = 91.40 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.64 ft					Today = 82.52 ft.				
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.24 (Yesterday)		11.03.24 (Today)		10.03.24 (Yesterday)		11.03.24 (Today)		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
						Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date	
(A) Plants in operation:														
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	150	150	150					
3	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGP1		
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	340	380	450	450					
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	402	412	412					
12	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335					
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	30					
16	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
17	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	32	38	38					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	33	33	33	33					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	12	12	28	28					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	100					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	149	48	149					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	90	195	95					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	35					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17					
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	35					
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	12	9	8	8					
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	19	0	17	17					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	60	96	96					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	24	24					
37	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
38	Meghnaghat Unique Power	Gas				0	0	0	0			Test run		
39	Meghnaghat 585 MW CCPP(Summit)	Gas				180	60	180	180			Test run		
Dhaka Zone Total				5655	5062	1825	2010	2165	2343	948	740			
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level		
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
44	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20					
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	206	220	220					
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	66	100	65	120					
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	25	25					
52	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	51	51	51					
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	32	40	64					
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	14	10	15					
56	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17					
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	15	15					
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	22	12	25	25					
60	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	36	36	36	36					
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	44	144	53	144					
63	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	284	284	280	280					
64	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	507	576	500	500					
65	Cox's Bazar Wind PP	(Wind) (IPP)				46	47	40	40			Test run		
66	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				76	0	25	0			Test run		
Chattogram Zone Total				4404	4344	1517	1658	1498	1663	380	330			
67	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	46	46	46					
68	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	220	223	225	225					
69	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	330	250	310	310	110		Gas Shortage		
70	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage		
71	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	320	300	300	300					
72	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+1116	195	195	0	0	0	0	195		Gas Shortage		
73	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	10	51	51					
74	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6					
75	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	48	0	50					
76	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	40	40	40					
77	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	63	34	34					
78	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
79	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9					
80	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25					
81	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
82	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	16	17	17					
83	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	0	114	114	114					
84	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	0	46	38	78					
85	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	17	17					
86	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	115	0	115	36					
87	Ashuganj 55 MW PP (Precision)	Gas (NENP)	1514	55	55	5	53	32	53					
88	** Import (Tripura)	India		160	160	118	126	128	141					
Cumilla Zone Total				2959	2951	1307	1383	1515	1560	665	0			
89	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	33	35	48	169		Gas Shortage		
90	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
91	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9					
92	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	67	59	68					
93	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
94	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0</							

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.24 (Yesterday)		11.03.24 (Today)		10.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	42	42		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	30	30		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	65	65				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	0	0	0	0			Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	62	190	190				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	17	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	310	290	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	370	365	365				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	260	200	200	200				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	0	42	42				
Sylhet Zone Total						2472	2427	1317	1291	1485	1495	0	448
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	6	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	94				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	92	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	459	503	500	500				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	926	925	945	800				
Khulna Zone Total						3241	3237	1477	1434	1580	1514	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	135	135		64	ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1160	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1214	1549	1579	1707	0	64
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	21				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	50	90				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	40	50				
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	16	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	186	170	185	185				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	35				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	6	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1294	1398	1400	1400				
Raishahi Zone Total						3653	3631	1905	2240	2284	2400	501	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	42	6	32	55				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	111				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	189	0	130	0				
Rangpur Zone Total						1030	950	473	281	435	366	159	85
Sub-total: Plants in operation						26301	25481	11183.0	11961	12696	13179	3232	1767
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	11183	11961	12696	13179	3232	1767

(C) Actual data of 10.03.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	12045	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11575	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11961	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	8334	MW, at =	5:00 hrs	Dhaka	4312	4312	0	Mymensingh	1031	951	80
05.	Day-peak Generation (Generation end)	:	11183	MW, at =	12:00 hrs	Chattogram	1100	1100	0	Sylhet	395	395	0
06.	Evening-peak Generation (Generation end)	:	11961	MW, at =	19:00 hrs	Khulna	1357	1357	0	Barishal	300	300	0
07.	Evening Peak Load-shed (Sub-station end)	:	80	MW, at =	19:00 hrs	Rajshahi	1255	1255	0	Rangpur	839	839	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8420	MW, at =	5:00 hrs	Cumilla	986	986	0				
09.	Generation shortfall at evening peak due to :	:								Total	11575	11495	80
	a) Gas/LF limitation	:	2873	MW		13.	Fuel cost :	(a) Gas = 345411974 Taka	(c) Coal = 592292107 Taka				
	d) Coal supply Limitation	:	159	MW				(b) Oil = 329585338 Taka	Total = 1267289418 Taka				
	b) Low water level in Kaptai lake	:	200	MW									
	c) Plants under shut down/ maintenance	:	1767	MW		14.	Maximum Temperature in Dhaka was : 30.3°C						
10.	Total Energy (Generation + India Import)	:	250.17	MKWh		15.	Export through East-West interconnections :						
	By Gas = 114.006 MKWH			By Oil = 18.381 MKWh			At evening peak-hour	:	11183	MW, at	19:00 hrs		
	By Coal = 88.551 MKWH			By Hydro = 0.733 MKWh			Maximum	:	910	MW, at	7:00 hrs		
	By Solar = 3.721 MKWH						Energy	:	0	MKWh			
11.	Total Gas Supplied	:	874.23	MMCFD									

(D) Forecast of 11.03.24 (Today) Monday :													
01.	Maximum Demand	:	12300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13179	MW	(Generation end)	05.	Total Generation	:	257.26	MKWh			
03.	Reserve / Shortage	:	879	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C				

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation