

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Tuesday				Date : 12.03.24			
Probable Maximum Demand : 12700 MW					Probable Maximum Generation : 13198 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 82.52 ft				Today = 82.40 ft			
					Rule Curve = 91.24 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.03.24 (Yesterday)		12.03.24 (Today)		11.03.24 (Yesterday)		12.03.24 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	150	150	150	90		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	430	390	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	375	385	412	412			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	331	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	17	31	38	38			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	12	12	12	12			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	149	48	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	120	95	100	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	8	17	17	149			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	18	17	18			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	17	17			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	17	8	8			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	14	10	10			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	96	96	96	96			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	24	24	24	24			
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas				0	0	0	0			Test run
	Meghnaghat 589 MW CCPP(Summit)	Gas				195	350	450	400			Test run
Dhaka Zone Total				5655	5062	1985	2357	2317	2677	1038	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
41	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	208	207	200	210			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	51	153	65	100			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	32	30	32			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	18	10	15			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	15	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	36	36	36	36			
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	70	53	144			
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	290	278	280	280			
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	484	484	500	500			
	Cox's Bazar Wind PP	(Wind) (IPP)				8	3	40	40			Test run
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				73	0	25	0			Test run
Chattogram Zone Total				4404	4344	1406	1501	1442	1577	380	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	46	46	46			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	224	224	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	305	310	310			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	340	330	300	330			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+116	195	195	0	0	0	0	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	28	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	8	6	8			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	31	0	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	0	9	10			
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	19	17	19			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	114	114	98	98			
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	38	48	38	50			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	115	36			
80	Ashugani 55 MW PP (Precision)	Gas (NENP)	1514	55	55	5	7	7	7			
**	Import (Tirupura)	India		160	160	118	138	128	141			
Cumilla Zone Total				2959	2951	1343	1424	1434	1465	555	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	33	35	40	169		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	19	9	19			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	88	59	88			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
87	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				622	614	142	146	155	153	169	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.03.24 (Yesterday)		12.03.24 (Today)		11.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	39	42	42	31	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	20	20	70	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	15	15	15			
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	59	65	65			
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0		Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	206	200	210			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	20	20	20			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	150	310	290	310			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	375	315	320	330			
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	205	205	200	210			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0			
Sylhet Zone Total					2472	2427	1294	1379	1362	1412	0	431
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	0	50			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	0	70			
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17			
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100	0			
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	15	0	15			
114	Nacopara 40 MW PP (Khangshan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	427	434	500	500			
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	925	926	945	926			
Khulna Zone Total					3241	3237	1447	1475	1562	1578	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	110			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	7	7			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	124	130	130	130	64	ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	910	980	1200	1200			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	35			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220			
Barishal Zone Total					2265	2265	1218	1370	1574	1702	0	64
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	25	34			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	50	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	8	45	40	50			
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	16	42	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	16	30			
132	Siragajonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Siragajonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Siragajonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	151	168	150	170	52	Gas Shortage	
135	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414			
136	Ulipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	35	35			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	1	35	35	35			
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Siragajonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1270	1438	1400	1400			
Raishahi Zone Total					3653	3631	1857	2311	2246	2353	553	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	6	0	6			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	10	75	35	75			
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0			
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	178	0	130	0			
Rangpur Zone Total					1030	950	463	281	403	281	159	85
Sub-total: Plants in operation					26301	25481	11155.0	12244	12495	13198	3264	1750

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					203	0	0	0	0	0	0	0
Gross Total					26504	25481	11155	12244	12495	13198	3264	1750

(C) Actual data of 11.03.24 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	12400	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11862	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	12244	MW, at =	19:00 hrs	Dhaka	4376	4376	0	Mymensingh	1086	937
04.	Minimum Generation (Generation end)	:	8420	MW, at =	5:00 hrs	Chattogram	1127	1127	0	Sylhet	420	420
05.	Day-peak Generation (Generation end)	:	11155	MW, at =	12:00 hrs	Khulna	1394	1394	0	Barishal	324	324
06.	Evening-peak Generation (Generation end)	:	12244	MW, at =	19:00 hrs	Rajshahi	1272	1272	0	Rangpur	858	858
07.	Evening Peak Load-shed (Sub-station end)	:	149	MW, at =	19:00 hrs	Cumilla	1005	1005	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8544	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	11862	11713
a)	Gas/LF limitation	:	2905	MW		13.	Fuel cost :	(a) Gas = 358067003 Taka	(c) Coal = 579054912 Taka			
d)	Coal supply Limitation	:	159	MW			(b) Oil = 362485534 Taka	Total = 1299607449 Taka				
b)	Low water level in Kaptai lake	:	200	MW								
c)	Plants under shut down/ maintenance	:	1750	MW								
10.	Total Energy (Generation + India Import)	:	258.28	MKWh		14.	Maximum Temperature in Dhaka was :	31.9°C				
	By Gas = 122.658 MKWH			By Oil = 19.935 MKWh		15.	Export through East-West interconnections :					
	By Coal = 86.508 MKWH			By Hydro = 0.726 MKWh			At evening peak-hour	:	11155	MW, at	19:00 hrs	
	By Solar= 3.439 MKWH						Maximum	:	900	MW, at	6:00 hrs	
							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	896.36	MMCFD								

(D) Forecast of 12.03.24 (Today) Tuesday :												
01.	Maximum Demand	:	12700	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13198	MW	(Generation end)	05.	Total Generation	:	267.90	MKWh		
03.	Reserve / Shortage	:	498	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)

Deputy Secretary, Generation