POWER GRID COMPANY OF BANGLADESH LTD NATIONAL LOAD DESPATCH CENTER DAILY REPORT Till now the maximum generation is : The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : Maximum Generation : Total Gen. (MKWH) : 21:00 Generation & Demand 11439.0 MW 13327.0 MW 13450.0 MW 1327.20 18-Mar-24 277.764 System Load Factor : 86.84% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Load Shed Total ver. Export from East grid to West grid - Maximum Import from West grid to East grid - Maximum Water Level of Kapital Lake at 6:00 A M on 81.37 Energy Energy 90.12 Oil Consumed (PDB) Gas Consumed HSD FO Cost of the Consumed Fuel (PDB+Pvt): Gas : Coal : Oil : Tk552,808,855 Total : Tk1,566,427,609 Load Shedding & Other Information Today Estimated Shedding (S/S end) MW Area Estimated Demand (S/S end) Dhaka Chittagong Area Khulna Area Rajshahi Area Cumilla Area Mymensingh Area Sylhet Area Barisal Area 0:00 0:00 0:00 0:00 0:00 0:00 0:00 4567 1255 1758 1528 1257 935 524 437 0% 0% 0% 0% 0% 0% 0% Rangpur Area Total Information of the Generating Units under shut down Forced Shut- Down 1) Barapukuria ST: Unit-1,2 2) Ghorasal-3,5,7 3) Shajibazar 330 MW 4) Baghabari-71,100 MW 5) Raozan unit-2 Planned Shut- Down 6) Siddhirganj 210 MW 7) Ashuganj North Additional Information of Machines, lines, Interruption / Forced Load shed etc. Daudkandi-Sonargaon 132 kV CR4-1 is restored. Daudkandi-Sonargaon 132 kV CR4-1 is restored. Daudkandi-Sonargaon 132 kV CR4-2 is restored. Frenchugarj 230132058W SS 132 kV Rahapup CR42 Scheduled SID Due to Bay equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Bay equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Bay Equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Bay Equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Bay Equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Bay Equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Bay Equipment Erection work. Chahatis 12333W SS 13 cL 1 Forced SD Due to Brad Inct. Mahatishangah 13233W SS 14 ft MTR 2 LT Forced SD Due to Red hot. Shaipibazar 12033W SS 85 PCL 86 MW Scheduled SID Due to Red hot. Shaipibazar 13233W SS 87 CL 86 MW Scheduled SID Due to Red hot. Shaipibazar 13233W SS 87 CL 87 the restored. Kulaura 13233W SS 18 Ft 2.1 th restored. Kulaura 13233W SS 18 Ft 2.1 th restored. Kulaura 13233W SS 18 Ft 2.1 th restored. Barapukura 230132SW SS 23013Z KV 1-17, 703T LT Scheduled SD Due to Red hot Maintenance. Barapukura 230132SW SS 132 XV Baphabari Line Forced SD Due to PT maintenance. Dury pask Generation: 1140 MW labrurd 13233W SS 13 KV 134 MW Saphabari Line Forced SD Due to PT maintenance. Panchagarh 13233W SS 13 KV 14 Tripped from Panchagarh 13233W SS 13 KV 14 Saphabari Line Forced SD Due to underground cable fault Panchagarh 13233W SS 13 KV 14 Tripped from Panchagarh 13233W SS 13 KV 14 Saphabari Line Forced SD Due to underground cable fault Panchagarh 13233W SS 13 SA 13 KV 14 Tripped from Panchagarh 13233W SS 13 KV 14 Saphabari Line Forced SD Due to underground cable fault Panchagarh 13233W SS 13 SA 13 KV 14 Tripped from Panchagarh 13233W SS 14 Trippe Additional Information of Machines, lines, Interruption / Forced Load shed etc. Outage 9:11 9:12 9:56 9:56 11:34 11:35 12:00 12:00 12:05 12:10 12:10 16:39 17:48 12:20 30.0MW load interrup anchagarh 132/33kV end 17:52 12:26 13:37 12:11 13:19 13:19 13:19 13:19 13:37 13:37 14:10 14:01 14:46 15:46 16:46 17:21 19:27 19:27 19:34 21:00 22:33 23:19 18:03 18:01 20:10 20:10 52.0MW load interrup. 52.0MW load interrup. 0:53 4:00 7:42 07:03 07:26 Rajshahi 132/33kV S/S Transformer T-1(405T) LT Scheduled 07:28 07:32 Feni 132/33kV S/S T-2(415T) LT Scheduled S/D Due to 33 kv Bus Coupler DS open from PDB (33 kv side) 18.0MW Chandpur 132/33kV S/S 422T LT Scheduled S/D Due to 33 kv Bus coupler T5 maintenance, work 13.0MW load interrup. 06:20 Bogura(New)-Naogaon 132 kV Ckt-1 Scheduled S/D from Naogaon 132/33kV end Due to S/D performed by oder of ALDC Bogura. and from Bogura 230/132kV end Due to project work 06-22 Bogura(New)-Naogaon 132 kV Ckt-2 Scheduled S/D from Naogaon 132/33kV end Due to S/D performed by oder of ALDC Bogura. and from Bogura 230/132kV end Due to project work 06:23 06:25 Bhandaria 132/33kV S/S Transformer-2 LT Project Work S/D Due to 33 KV BUS DS Replacement. 12.0MW Sirajganj-Ullahpara 132KV Ckt-2 Project Work S/D from Sirajganj 132/33kV end Due to ৩০০কেট ভ্ৰমণ স্থাকিট সম্পাদন গাটাকা AP50/0 to AP51/0,pilots wire & temporary cradle guard অপ্যাচন 06:46