

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month April, 2024				Day : Friday				Date : 26.04.24			
Probable Maximum Demand : 16000 MW				Probable Maximum Generation : 16878 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.34 ft				Today = 75.10 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.04.24 (Yesterday)		26.04.24 (Today)		25.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	180	0	0		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	60	60	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	403	401	400	400		
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	196	197	200	200		
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	313	318	335	335		
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	304	309	305	305		
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	42	40	40		
14	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	90	50	92		
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x6.73	80	80	33	33	44	44		
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	31	33	33		
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	16	16	16		
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	17	105		
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	143	32	150		
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	0	54		
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	270	300	300		
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	109	131	130	149		
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55		
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55		
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	70	53	72		
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	126	17	162		
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0		
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0		
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25		
32	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	405	502	500	500		
	Meghnaghat 589 MW CCPP(Summit)	Gas				320	350	590	500		Test run
<b>Dhaka Zone Total</b>				<b>5526</b>	<b>5332</b>	<b>3461</b>	<b>4121</b>	<b>3820</b>	<b>4315</b>	<b>108</b>	<b>845</b>
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	30	30	30	200	Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	107	115	115		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0		
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	4	25	8	25		
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0		
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20		
39	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	17	34	17	34		
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
41	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	212	212	211	211		
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	16	16	16	16		
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12		
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	44	51	51	51		
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	56	40	64		
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	13	15	30		
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	26	12	25		
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	13	36		
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34		
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12		
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	0	0		
52	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	163	54	163		
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	117	272	275	275		
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	663	579	500	500		
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	25	7	40	40		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				76	0	33	0		
<b>Chattogram Zone Total</b>				<b>4464</b>	<b>4404</b>	<b>1559</b>	<b>1726</b>	<b>1524</b>	<b>1715</b>	<b>200</b>	<b>330</b>
57	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	34	40	40		
58	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	209	206	220	220		
59	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	270	280	280		
60	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	280	300	300		
61	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	285	280	300	300		
62	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	6	6	6		
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	41	33	41		
66	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	155	100	150		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0		
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	16	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	33	52	34	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	18	20	20		
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	61	102	52	114		
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	35	64	55	65		
74	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35		
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	98	36	95		
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	38	44	50	50		
**	Impoport (Tripura)	India		160	160	134	112	146	144		
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1639</b>	<b>1864</b>	<b>1773</b>	<b>1996</b>	<b>195</b>	<b>163</b>
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	74	70	100	128	Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	96	50	107		
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	105	56	108		
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0		
82	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	18	18	12	18		
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>209</b>	<b>293</b>	<b>240</b>	<b>333</b>	<b>128</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.04.24 (Yesterday)		26.04.24 (Today)		25.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
83	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	43	43	43		27	Under maint.
84	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	30	30		62	GT-4 Under maint.
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50			
86	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112			
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	52	52	60	60			
89	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
90	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	200	210	210			
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	17	18	18			
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	25	25			
93	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	300	300			
94	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	366	400	400			
95	Bibiyana South 363 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	340	380	380			
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	90	95	95	95			Test run
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	39	44	44			
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1666</b>	<b>1684</b>	<b>1772</b>	<b>0</b>	<b>419</b>	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
99	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	345	345	400	410			
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	42			
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	0	50			
102	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	90	90			
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
105	Monoria Orion 100 MW Solar PP	Solar (IPP)	100	100	100	96	0	100	0			
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	342	378	375	375			
107	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	927	921	939	650			
<b>Khulna Zone Total</b>					<b>3703</b>	<b>3699</b>	<b>1710</b>	<b>1788</b>	<b>1904</b>	<b>1617</b>	<b>0</b>	<b>0</b>
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	48	110			
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	1	10	10	10			
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	123	130	130	130		64	ST under maint.
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	730	1100	1244	1244			
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	17			
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	150	307			
114	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2235</b>	<b>1224</b>	<b>1725</b>	<b>1819</b>	<b>2038</b>	<b>0</b>	<b>64</b>
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	30	35	38	37			
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	25			
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	3	95	50	95			
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	30	40	50			
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	34	34	34			
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	30	33			
122	Siraigonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	180	158	160	200			
123	Siraigonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	160	200	220		Gas Shortage
124	Siraigonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
125	Siraigonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	395	329	414	414			
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	8	25			
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	55			
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	113	113	77			
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	14	35	35	35			
131	Siraigonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1426	1236	1400	1400			
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>2200</b>	<b>2203</b>	<b>2534</b>	<b>2691</b>	<b>511</b>	<b>100</b>
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230			
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	56	34	56			
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
137	Majpara, Tatisa 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	94	115	115			
139	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0			
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	189	0	130	0			
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>529</b>	<b>380</b>	<b>547</b>	<b>401</b>	<b>0</b>	<b>85</b>
<b>Sub-total: Plants in operation</b>					<b>26354</b>	<b>25903</b>	<b>14197.0</b>	<b>15784</b>	<b>15933</b>	<b>16878</b>	<b>1142</b>	<b>2006</b>
<b>(B) Plants under long term maintenance/ contract expired</b>												
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired
142	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Gross Total</b>					<b>27054</b>	<b>25903</b>	<b>14197</b>	<b>15784</b>	<b>15933</b>	<b>16878</b>	<b>1142</b>	<b>2006</b>
<b>(C) Actual data of 25.04.24 (Yesterday) Thursday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 16750 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 15973 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	: 15784 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	: 13053 MW, at = 7:00 hrs										
05.	Day-peak Generation (Generation end)	: 14197 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 15784 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 923 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12736 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
	a) Gas/LF limitation	: 942 MW										
	d) Coal supply Limitation	: 0 MW										
	b) Low water level in Kaptai lake	: 200 MW										
	c) Plants under shut down/ maintenance	: 2006 MW										
10.	Total Energy (Generation + India Import)	: 346.46 MMkWh										
	By Gas = 177.747 MMkWh	By Oil = 44.735 MMkWh										
	By Coal = 95.946 MMkWh	By Hydro = 0.871 MMkWh										
	By Solar = 3.633 MMkWh											
11.	Total Gas Supplied	: 1349.55 MMCFD										
<b>(D) Forecast of 26.04.24 (Today) Friday :</b>												
01.	Maximum Demand	: 16000 MW (Generation end)										
02.	Maximum Generation	: 16878 MW (Generation end)										
03.	Reserve / Shortage	: 878 MW (Generation end)										
12.	<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	5823	5663	160	Mymensingh	1387	1187	200				
	Chattogram	1476	1306	170	Sylhet	590	590	0				
	Khulna	1950	1950	0	Barishal	504	504	0				
	Rajshahi	1613	1493	120	Rangpur	1104	911	193				
	Cumilla	1528	1448	80								
					Total	15973	15050	923				
					(a) Gas = 512882668 Taka	(c) Coal = 640810083 Taka						
					(b) Oil = 823725023 Taka	Total = 1977417774 Taka						
14.	Maximum Temperature in Dhaka = 39.1°C											
15.	Export through East-West interconnections :											
	At evening peak-hour	: 14197 MW, at 19:30 hrs										
	Maximum	: 710 MW, at 21:00 hrs										
	Energy	: 0 MMkWh										
<b>(E) Remarks: Highest Generation 16233 MW on 22-04-2024 at 21:00</b>												
(Md. Helalur Rahman) Deputy Secretary, Generation												