

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | | Energy Generated | Remarks |
|------------------------------|--------------------------------|------------------------|-------------------------|------------------|-------------|------------------|---------------------------|
| | | | | Capacity | Hour | | |
| | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal ST: Unit-1,2 | PDB | 2'55 | 85 | 35 | 726000 | #1 Under maint. |
| | Ghorasal GT: Unit-3 | PDB | 1'210 | 170 | 291 | 6872900 | On test |
| | Ghorasal GT: Unit-4 | PDB | 1'210 | 180 | 0 | 0 | On test |
| | Ghorasal ST: Unit-5 | PDB | 1'210 | 190 | 0 | 0 | Under maint. |
| 2 | Ghorasal ST: Unit-7 | QRPP | 1'243+1'122 | 365 | 240 | 5810399 | |
| | Ghorasal 78MW (MAX) | QRPP | 2'40 | 78 | 0 | 0 | Gas shortage |
| 4 | Ghorashal (Regent) | IPP | 3'413.35 | 108 | 0 | 0 | Gas shortage |
| 5 | Haripur GT: Unit-1, 2 | SBU, PDB | 2'32 | 40 | 0 | 0 | Gas shortage |
| 6 | Haripur 412 MW CCPP | EGCB | 1'273+1'139 | 412 | 377 | 8818570 | FGMO |
| 7 | Haripur NEPC 110MW | IPP | 8'15 | 110 | 50 | 73700 | Low demand |
| 8 | Haripur Power CCPP 360MW | IPP | 1'235+1'125 | 360 | 360 | 7851000 | |
| 9 | Meghnaghat CCPP 450MW | IPP | 2'150+1'150 | 450 | 400 | 8930500 | Frequency control |
| 10 | Meghnaghat (IEL) | QRPP | 12'8.9 | 100 | 60 | 189120 | Low demand |
| 11 | Meghnaghat CCPP(Summit) | IPP | 2'110+1'110 | 305 | 0 | 0 | Reserve |
| 12 | Madanganj 102MW | QRPP | 6'17 | 100 | 80 | 424176 | Low demand |
| 13 | Madanganj-55 MW | (IPP) | 3'17.08+1'11.3 | 55 | 30 | 793199 | Low demand |
| 14 | Keranganj (Powerpac) 100MW | QRPP | 8'13.45 | 100 | 20 | 85938 | Low demand |
| 15 | Narshingdi (Doreen) | SIPP, REB | 8'2.90 | 22 | 19 | 327060 | Engine problem |
| 16 | Siddhirgonj ST 210MW | PDB | 1'210 | 115 | 0 | 0 | Gas shortage |
| 17 | Siddhirgonj GT Unit-1 & 2 | EGCB | 2'105 | 210 | 0 | 0 | Gas shortage |
| 18 | Siddhirgonj (Desh) | QRPP | 96'1.2 | 100 | 0 | 0 | Reserve |
| 19 | Siddhirgonj (Dutch Bangla) | QRPP | 12'8.9 | 100 | 50 | 271680 | Low demand |
| 20 | Siddhirgonj CCPP-335 MW | EGCB | 1'217 | 217 | 200 | 4185583 | Gas shortage |
| 21 | Pagla (DPA) | QRPP | 100'0.5 | 0 | 0 | 0 | Contract Expired |
| 22 | Gagnagar (Orion) | IPP | 12'8.924 | 102 | 58 | 594432 | Low demand |
| 23 | Katpotti 51 MW | IPP | 7'7.9 | 51 | 12 | 678000 | Low demand |
| 24 | Banco Energy 54MW | IPP | 3'18 | 54 | 54 | 1105560 | |
| 25 | Kodda 149MW | BPDB-RPCL | 9'17.06 | 149 | 83 | 380640 | High Voltage. |
| 26 | Northern 55 MW | IPP | 3'19.3 | 55 | 55 | 971426 | |
| 27 | Southern 55MW | IPP | 3'19.3 | 55 | 35 | 263000 | Engine problem |
| 28 | Bosila 108MW | IPP | 12'8.75+1'13.5 | 108 | 30 | 574080 | Engine problem |
| 29 | Summit Power (Madhabdi+Ashuli) | SIPP REB | 3'8.67+4'8.73 | 30 | 50 | 1195620 | Engine problem |
| 30 | Summit Masera | SIPP REB | 4'8.73 | 33 | 33 | 813100 | |
| 31 | Summit Rugganj | SIPP REB | 4'8.73 | 33 | 33 | 767500 | |
| 32 | Gazipur (RPCL) | IPP | 6'8.9 | 52 | 42 | 786876 | Engine problem |
| 33 | Tongi GT | PDB | 1' 105 | 105 | 0 | 0 | Gas shortage |
| 34 | Summit Gazipur-2 | IPP | 18'17.076 | 300 | 235 | 966000 | Low demand |
| 35 | APR Energy, Keranigonj | IPP | 256'1.4 | 300 | 0 | 68964 | Reserve |
| 36 | Bramhangoan 100 MW (Aggrek) | IPP | 100 | 0 | 0 | 0 | Reserve |
| 37 | Aggreko Aurahati 100MW | IPP | 0.85'23+0.95'91 | 100 | 0 | 0 | Reserve |
| 38 | Summit Gazipur-1. 150MW | IPP | 149 | 149 | 84 | 790560 | High Voltage. |
| Dhaka area Total | | | | 5798 | 3016 | 55315583 | |
| 39 | Chattogram ST-1 (Raozan) | PDB | 1'210 | 180 | 120 | 2800000 | |
| | Chittagong ST-2 (Raozan) | PDB | 1'210 | 180 | 0 | 0 | Gas shortage |
| 40 | Raozan 25 MW (RPCL) | IPP | 3'8.9 | 25 | 25 | 473400 | |
| | Teknaf Solartech 20MW | Teknaf Solartech Energ | 20 | 20 | 0 | 137160 | |
| 41 | Patenga 50MW | IPP | 8'6.98 | 50 | 50 | 939840 | Engine problem |
| 42 | Kaptal Hydro: Unit-1,2,3,4, 5 | PDB | 2'40+3'50 | 230 | 40 | 899000 | Low water level |
| 43 | Sikalbaha ST 60MW | PDB | 1'60 | 40 | 0 | 0 | Under maint. |
| 44 | Sikalbaha 225MW | PDB | 1'150+1'175 | 225 | 0 | 0 | Test run. |
| 45 | Sikalbaha Peaking GT | PDB | 1'150 | 150 | 0 | 0 | Under maint. |
| 46 | Sikalbaha (Energis) | RPP | 4'12.5+2'11.9+1'3+1'1.5 | 51 | 50 | 1022400 | |
| 47 | Hathazari peaking | PDB | 1'18.9 | 98 | 64 | 294136 | |
| 48 | Dohazari Peaking | PDB | 6'17 | 102 | 68 | 555961 | Low demand |
| 49 | Juldah (Acorn) | QRPP | 8'13.45 | 100 | 75 | 1148640 | |
| | Juldah 100 MW Unit-3 | IPP | 0 | 100 | 50 | 1068480 | Engine problem |
| 50 | Barakunda (Regent) | SIPP, PDB | 8'2.90 | 22 | 22 | 500544 | |
| | Malancha, Ctg. EPZ (United) | | 5'8.73+3'9.34 | 0 | 36 | 600480 | |
| 51 | Chattogram ECPV 108 MW | IPP | 16'7 | 108 | 93 | 1512960 | Engine problem |
| Chattogram area Total | | | | 1681 | 693 | 11953001 | |
| 52 | Ashuganj ST: Unit- 3 | APSCl | 1'150 | 135 | 0 | 0 | Gas shortage |
| | Ashuganj ST: Unit- 4 | APSCl | 1'150 | 129 | 150 | 3344510 | |
| | Ashuganj ST: Unit- 5 | APSCl | 1'150 | 134 | 135 | 3075526 | |
| 53 | Ashuganj CCPP 225 MW | APSCl | 1'142+1'175 | 221 | 195 | 4605000 | FGMO |
| 54 | Ashuganj CCPP(North) | APSCl | 1'360 | 360 | 0 | 281600 | Under maint. |
| 55 | Ashuganj CCPP(South) | APSCl | 1'360 | 360 | 14 | 1479000 | synchronized at 19:44. |
| 56 | Ashuganj Engines TSK | APSCl | 14'3.968 | 45 | 36 | 808424 | Engine problem |
| 57 | Ashuganj (Precision) 55MW | RPP | 15'4 | 55 | 7 | 170400 | Gas shortage |
| 58 | Ashuganj (United) 53MW | QRPP | 14'4 | 53 | 5 | 120000 | Gas shortage |
| 59 | Ashuganj 195MW Modular | IPP | 20'9.73+1'116 | 195 | 63 | 953454 | Gas shortage |
| 60 | Ashuganj (Midland) 51MW | IPP | 6'9.34 | 51 | 40 | 840210 | Engine problem |
| | Midland 150MW | IPP | 23'7.015 | 150 | 11 | 458327 | Red hot at 230 KV bus |
| 61 | B.Barja (Aggreko) 85MW | QRPP | 86'1.10 | 85 | 85 | 1616719 | |
| 62 | Daudkandi Peaking 52MW | PDB | 6'8.92 | 52 | 0 | 6968 | Reserve |
| 63 | Chandpur CCPP | PDB | 1'106+1'57 | 163 | 100 | 2340890 | |
| | Chandpur Desh 200MW | IPP | 0 | 200 | 125 | 1663200 | High Voltage. |
| 64 | Feni (Doreen) 22MW | SIPP, PDB | 8'2.90 | 22 | 19 | 442764 | |
| 65 | Feni, Mohipal (Doreen) | SIPP, REB | 4'2.90 | 11 | 11 | 208800 | |
| ** | Tripura | Imported power | 0 | 160 | 126 | 2108160 | |
| 66 | Jangalla (Summit) 33MW | SIPP, PDB | 4'8.73 | 33 | 25 | 608500 | Engine problem |
| 67 | Lakdhanj 52 MW | IPP | 6'8.92 | 52 | 0 | 0 | Reserve |
| 68 | Summit Cumilla 25MW | SIPP, PDB | 3'3.67+2'6.97 | 25 | 22 | 525180 | |
| 69 | Daudkandi bangla trak | IPP | 154'1.4 | 200 | 0 | 0 | Reserve |
| Cumilla Area Total | | | | 2891 | 1169 | 25658632 | |
| 70 | Mymensingh RPCL 210MW | IPP | 4'35+1'70 | 202 | 107 | 2659280 | Gas shortage |
| 71 | Tangal (Doreen) 22MW | SIPP, PDB | 8'2.90 | 22 | 22 | 522936 | |
| 72 | Jamalpur 95MW | IPP | 12'8.924 | 95 | 87 | 1581120 | Engine problem |
| 73 | Sarishabari (Solar) | IPP | 1'3 | 3 | 0 | 12800 | |
| 74 | United Mymensingh PPL | IPP | 200 | 200 | 200 | 2246400 | |
| Mymensingh Area Total | | | | 522 | 416 | 7022536 | |
| 75 | Fenchugonj CCPP-1 | PDB | 2'32+1'33 | 70 | 30 | 684000 | GT-1 under maint. |
| 76 | Fenchugonj CCPP-2 | PDB | 2'35+1'35 | 90 | 61 | 1437740 | |
| 77 | Kushira 163 MW CCPP GT | IPP | 1'109+1'54 | 163 | 100 | 3264331 | Frequency control |
| 78 | Shajbazar 330 MW | PDB | 3'110 | 330 | 0 | 0 | Under maint. |
| 79 | Fenchugonj (Barakatullah) 51MW | RPP | 19'2.90 | 51 | 50 | 1169400 | |
| 80 | Fenchugonj (EPL) 44MW | RPP | 12'3.5+5'2 | 44 | 50 | 1200000 | |
| 81 | Hobiganj 1164 MW | SIPP, REB | 4'2.90 | 11 | 11 | 264000 | |
| 82 | Shajbazar GT: Unit- 8, 9 | RPP | 2'35 | 66 | 67 | 1436000 | FGMO |
| 83 | Shajbazar 86MW | RPP | 32'2.90 | 86 | 84 | 1363200 | |
| 84 | Shajbazar (EPL) 50MW | RPP | 27'2.0 | 50 | 48 | 779040 | |
| 85 | Sylhet GT 150 MW | PDB | 1'142 | 142 | 0 | 0 | under maint. |
| 86 | Sylhet GT 20 MW | PDB | 1'20 | 20 | 19 | 130000 | |
| 87 | Sylhet (EPL) 50MW | RPP | 27'2 | 50 | 23 | 549700 | |
| 88 | Shahjahanulla 25 MW | SIPP, REB | 3'9.34 | 25 | 16 | 552456 | |
| 89 | Summit Bibiana- 2 | IPP | 1'222+1'119 | 341 | 260 | 7701000 | FGMO |
| | Bibiyana-3 285MW | PDB | 285 MW | 0 | 0 | 0 | On test |
| 90 | Sylhet (Desh) 10MW | RPP | 6'1.95 | 10 | 10 | 240120 | |
| Sylhet Area Total | | | | 1549 | 829 | 20770987 | |
| 91 | Bheramara GT-1,2,3 | PDB | 3'20 | 46 | 0 | 0 | Reserve |
| ** | Bheramara (HVDC) | Imported power | 2'500 | 1000 | 697 | 11936727 | |
| 92 | Khulna (KPCL-1 & 3) | IPP | 19'6.5 | 0 | 0 | 0 | Contract Expired |
| 93 | Khulna (KPCL-2) | QRPP | 7'17 | 115 | 115 | 656640 | |
| 94 | Faridpur Peaking | PDB | 8'6.89 | 54 | 43 | 168480 | |
| 95 | Khulna CCPP 225MW | NWPGL | 1'150+1'175 | 230 | 0 | 0 | Reserve |
| 96 | Gopalganj Peaking | PDB | 16'6.98 | 109 | 60 | 311040 | Low demand |
| 97 | Bheramara 360 MW | NWPGL | 1'278+1'132 | 410 | 400 | 9239040 | |
| 98 | Noapara (KZA) 40MW | QRPP | 5'8.5 | 40 | 40 | 751875 | |
| | Khulna (Aggreco) 55MW | QRPP | 71'0.85 | 0 | 0 | 0 | Contract Expired |
| 99 | Bangla Trak Noapara | IPP | 70'1.4 | 100 | 0 | 0 | Reserve |
| | Labon Chora 105 MW | IPP | 6'18.445 | 105 | 70 | 1254720 | Engine problem |
| Khulna Area Total | | | | 2209 | 1425 | 24318522 | |
| 100 | Summit Barisal 110 MW | IPP | 7'17.076 | 110 | 99 | 490560 | Low demand |
| 101 | Barisal GT: Unit-1, 2 | PDB | 2'20 | 30 | 0 | 0 | Reserve |
| 102 | Bhola (Venture) 33MW | RPP | 1'34.50 | 33 | 13 | 299785 | Engine problem |
| 103 | Bhola CCPP 194MW | PDB | 2'63+1'68 | 194 | 86 | 2730850 | FGMO>-1 tripped at 05:2 |
| 104 | Bhola Aggreko 95MW | QRPP | 96'1.10 | 95 | 96 | 2197881 | |
| Barisal Area Total | | | | 462 | 294 | 5719076 | |
| 105 | Baghabari GT 71MW | PDB | 1'71 | 71 | 0 | 0 | Gas shortage |
| | Baghabari GT 100MW | PDB | 1'100 | 100 | 0 | 0 | Under maint. |
| 106 | Baghabari Peaking 50MW | PDB | 6'8.9 | 52 | 43 | 207697 | |
| 107 | Bera Peaking | PDB | 9'8.29 | 71 | 34 | 166134 | |
| 108 | Amnura 50MW | QRPP | 7'7.79 | 50 | 40 | 731120 | Engine problem |
| 109 | Katakhali (Northern) | QRPP | 6'8.9 | 50 | 50 | 387878 | |
| 110 | Katakhali Peaking | PDB | 6'8.7 | 50 | 0 | 0 | Reserve |
| 111 | Sirajgonj Unit-1 225MW | NWPGL | 1'150+1'175 | 210 | 0 | 0 | Gas shortage |
| 112 | Sirajgonj Unit-2 225MW | NWPGL | 1'150+1'175 | 220 | 0 | 0 | Gas shortage |
| 113 | Sirajgonj Unit-3 225MW | NWPGL | 1'141 | 141 | 188 | 4893818 | |
| | Sirajgonj Unit-4. 414 MW (Gas) | SNWPGL | 1'282 | 282 | 0 | 0 | Gas shortage |
| 114 | Santahar Peaking | PDB | 6'8.7 | 50 | 29 | 153921 | |
| 115 | Bogra (GBB) | RPP | 6'4 | 22 | 22 | 518880 | |
| 116 | Bogra (EPL) | RPP | 5'3.3+5'2 | 10 | 14 | 340380 | |
| 117 | Ullapara (Summit) | SIPP, REB | 4'2.90 | 11 | 11 | 205200 | |
| 118 | Rajlanka 52 MW | IPP | 6'8.92 | 52 | 43 | 961440 | |
| 119 | Chapainawabganj-100 MW | PDB | 12'8.924 | 104 | 102 | 694424 | |
| | Paramount Baghabari | IPP | 200 MW | 0 | 0 | 188181 | |
| | | | | | | | |