

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	715000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	295	7339800	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	240	5007272	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	355	8823003	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	4700	Reserve
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	360	7808000	
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	430	9210125	Frequency control
10	Meghnaghat (IEL)	QRPP	12*9	100	25	109440	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	60	532032	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	597008	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	26688	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	232020	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	22000	Reserve
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	225	385187	
21	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	58	386640	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	46	604368	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	893520	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	16	28320	High Voltage.
26	Northern 55 MW	IPP	3*19.3	55	55	747764	
27	Southern 55MW	IPP	3*19.3	55	35	90580	Engine problem
28	Bosila 108MW	IPP	12*8.75+1*3.5	108	31	430080	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	50	1178880	Engine problem
30	Summit Masana	SIPP, REB	4*8.73	33	33	736800	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	795900	
32	Gazipur (RPCL)	IPP	6*8.9	52	42	702756	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	107	353780	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	95	496800	High Voltage.
<b>Dhaka area Total</b>				<b>5798</b>	<b>2754</b>	<b>48258563</b>	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	160	3100000	
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	446940	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	140400	
41	Patenga 50MW	IPP	8*6.98	50	50	954720	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	40	875000	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	32	916800	Low demand
47	Hathazari peaking	PDB	1*8.9	98	0	84472	Reserve
48	Dohazari Peaking	PDB	6*17	102	34	132066	
49	Juidah (Acorn)	QRPP	8*13.45	100	70	1041480	Engine problem
	Juidah 100 MW Unit-3	IPP	0	100	53	1238400	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	19	468048	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	28	587040	
51	Chattogram ECPV 108 MW	IPP	16*7	108	93	874560	Engine problem
<b>Chattogram area Total</b>				<b>1681</b>	<b>604</b>	<b>10859926</b>	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	150	2899235	
	Ashuganj ST: Unit- 5	APSCl	1*150	134	135	2684624	
53	Ashuganj CCPP 225 MW	APSCl	1*142+1*75	221	0	1484000	Under maint.
54	Ashuganj CCPP(North)	APSCl	1*360	360	280	5945100	ST under maint.
55	Ashuganj CCPP(South)	APSCl	1*360	360	301	7404000	FGMO
56	Ashuganj Engines TSK	APSCl	14*3.968	45	36	660096	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	56	838560	
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	40	702134	Engine problem
	Midland 150MW	IPP	23*7.015	150	31	588800	Ashuganj Bus red hot.
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	1739357	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	4712	Reserve
63	Chandpur CCPP	PDB	1*106+1*57	163	100	2353720	
	Chandpur Desh 200MW	IPP	0	200	72	1254240	High Voltage.
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	439056	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	214380	
**	Tripura	Imported power	0	160	122	2304000	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	493700	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	487000	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1478</b>	<b>32817641</b>	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	107	2529800	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	523440	
72	Jamalpur 95MW	IPP	12*8.924	95	87	1614720	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	10650	
74	United Mymensingh PPL	IPP	200	200	200	3000000	
<b>Mymensingh Area Total</b>				<b>522</b>	<b>416</b>	<b>7678610</b>	
75	Fenchugonj CCPP-1	PDB	2*32+1*33	70	30	684000	GT-1 under maint.
76	Fenchugonj CCPP-2	PDB	2*35+1*35	90	61	1478000	
77	Kushara 163 MW CCPP GT	IPP	1*109+1*54	163	163	3456524	
78	Shajibazar 330 MW	PDB	3*110	330	96	2250000	GT-1 under maint.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	50	1083600	
80	Fenchugonj (EPL) 44MW	RPP	12*3.6+5*2	44	50	1170000	
81	Hobiganj 116MW	SIPP, REB	4*2.90	11	11	264000	
82	Shajibazar GT: Unit- 8, 9	RPP	2*35	66	58	1352000	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	86	1399680	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	1138680	
85	Sylhet GT 150 MW	PDB	1*142	142	106	679510	
86	Sylhet GT 20 MW	PDB	1*20	20	20	302000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	23	546800	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	285312	Engine problem
89	Summit Bibiana- 2	IPP	1*222+1*119	341	265	7198200	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	205200	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1094</b>	<b>23493506</b>	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	701	12290182	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	115	484800	
94	Faridpur Peaking	PDB	8*6.89	54	38	156900	
95	Khulna CCPP 225MW	NWPGL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	65	233600	
97	Bheramara 360 MW	NWPGL	1*278+1*132	410	380	8320608	
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	725250	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	50	52800	Low demand
	Labon Chora 105 MW	IPP	6*18.445	105	72	1423680	Engine problem
<b>Khulna Area Total</b>				<b>2209</b>	<b>1461</b>	<b>23687820</b>	
100	Summit Barisal 110 MW	IPP	7*17.076	110	72	526848	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	0	287231	Engine problem
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	143	2560903	FGMO & GT-1 under maint.
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	33	1731424	Engine problem
<b>Barisal Area Total</b>				<b>462</b>	<b>248</b>	<b>5106406</b>	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	43	158785	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	40	704520	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	24	318542	
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	0	0	Gas shortage
112	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	210	0	339500	Gas shortage
113	Sirajgonj Unit-3 225MW	NWPGL	1*141	141	182	4579809	FGMO
	Sirajgonj Unit-4. 414 MW (Gas)	SNWPGL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	37	184074	
115	Bogra (GBB)	RPP	6*4	22	22	516240	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	15	345816	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	209754	
118	Rajlanka 52 MW	IPP	6*8.92	52	43	808320	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	102	892948	
	Paramount Baghabari	IPP	200 MW	0	19	62727	
<b>Raj</b>							