

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	720000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	299	3222600	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	QRPP	1*240+1*122	365	250	6576081	
3	Ghorashal 78MW (MAX)	QRPP	2*40	78	0	37632	Gas shortage
4	Ghorashal (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	362	8663810	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	16200	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	366	7954000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	450	9228275	
10	Meghnaghat (IEL)	QRPP	12*9	100	7	15360	Low demand
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Reserve
12	Madanganj 102MW	QRPP	6*17	100	15	64128	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	106535	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	335880	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	92	2481000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	7	9600	Low demand
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	170	3765729	Frequency control
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	40	111312	Low demand
23	Katpoti 51 MW	IPP	7*7.9	51	43	77232	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	775800	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	32	142080	Low demand
26	Northern 55 MW	IPP	3*19.3	55	37	254074	Engine problem
27	Southern 55MW	IPP	3*19.3	55	17	77320	Low demand
28	Bosila 108MW	IPP	12*8.75+1*3.5	108	18	312000	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	50	1150120	Engine problem
30	Summit Madona	SIPP, REB	4*8.73	33	33	811000	
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	791300	
32	Gazipur (RPCL)	IPP	6*8.9	52	42	661904	Engine problem
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	30	1003000	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	44	516960	Low demand
Dhaka area Total				5798	2603	49880932	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	357300	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	74115	
41	Patenga 50MW	IPP	8*6.98	50	50	584640	
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	78	1764669	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	151	3577236	Gas shortage
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	40	915360	Engine problem
47	Hathazari peaking	PDB	1*18.9	98	0	19232	Reserve
48	Dohazari Peaking	PDB	6*17	102	51	74692	Low demand
49	Juidah (Acorn)	QRPP	8*13.45	100	42	621480	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	84	1552000	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	530448	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	28	622080	
51	Chattogram ECPV 108 MW	IPP	16*7	108	45	264000	Low demand
Chattogram area Total				1681	616	10960452	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	150	2829970	
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Under maint.
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	184	4534000	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	150	3020000	ST under maint.
55	Ashuganj CAPP(South)	APSCL	1*360	360	309	7587500	FGMO
56	Ashuganj Engines TSK	APSCL	14*3.968	45	36	741816	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	322080	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	73	1555636	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	5	413536	Gas shortage
	Midland 150MW	IPP	23*7.015	150	51	137160	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	40	637593	Line Over Load
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	5016	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	100	2365040	
	Chandpur Desh 200MW	IPP	0	200	110	876960	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	456616	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	225360	
**	Tripura	Imported power	0	160	124	2402880	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	283700	Engine problem
67	Lakhdhanj 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	518260	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1422	29032123	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	157	3676680	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	403380	
72	Jamalpur 95MW	IPP	12*8.924	95	87	1439040	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	11250	
74	United Mymensingh PPL	IPP	200	200	192	1207200	
	United Jamalpur PPL	IPP	115 MW	0	24	495600	
Mymensingh Area Total				522	482	7233150	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	30	689000	GT-1 under maint.
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	61	1466160	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	130	3357163	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	0	0	Under maint.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	438000	
80	Fenchugonj (EPL) 44MW	RPP	12*3.9+5*2	44	41	376000	
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	11	233160	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	46	1379880	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	50	667200	Line Over Load
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	730440	
85	Sylhet GT 150 MW	PDB	1*142	142	80	1978480	Frequency control
86	Sylhet GT 20 MW	PDB	1*20	20	20	176000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	23	465600	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	173976	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	265	7203000	FGMO
90	Bibiyana-3 285MW	PDB	285 MW	0	320	6745000	On test
	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	104040	
Sylhet Area Total				1549	1213	26183699	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	677	12357818	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	115	560640	
94	Faridpur Peaking	PDB	8*6.89	54	44	184320	
95	Khuina CAPP 225MW	NWPGLCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*9.98	109	92	343936	
97	Bheramara 360 MW	NWPGLCL	1*278+1*132	410	300	8705376	Frequency control
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	799875	
	Khuina (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	20	21120	Low demand
	Labon Chora 105 MW	IPP	6*18.445	105	105	1714080	
Khuina Area Total				2209	1393	24687165	
100	Summit Barisal 110 MW	IPP	7*17.076	110	57	442940	
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	9973	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	12	280407	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	30	888000	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	27	2019978	Synchronized at 18:45.
Barisal Area Total				462	126	3641298	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	171252	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	40	723870	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	8	137644	Low demand
110	Katakhal Peaking	PDB	6*8.7	50	7	16039	Low demand
111	Sraigonj Unit-1 225MW	NWPGLCL	1*150+1*75	210	20	290100	Gas shortage
112	Sraigonj Unit-2 225MW	NWPGLCL	1*150+1*75	220	186	4513145	FGMO
113	Sraigonj Unit-3 225MW	NWPGLCL	1*141	141	185	4809284	FGMO
	Sraigonj Unit-4 414 MW(Gas)	SNWPGLCL	1*282	282	0	0	Gas shortage
114	Santahar Peaking	PDB	6*8.7	50	29	132990	
115	Bogra (GBB)	RPP	6*4	22	22	510000	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	15	352224	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	223404	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	989280	
119	Chapainawabganj-100 MW	PDB	12*8.924				