

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	712000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	190	4504500	
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	300	6921609	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	20	374752	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	22	349182	Gas shortage
5	Haripur GT: Unit-1, 2	SBU_PDB	2*32	40	40	862800	
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	352	8500230	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	0	0	Under maint.
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	350	8528775	Low demand
10	Meghnaghat (IEL)	QRPP	12*9	100	0	0	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Machine problem
12	Madanganj 102MW	QRPP	6*17	100	15	71064	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	220212	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	231120	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	72	2334000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	113	748128	Under maint.
21	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	40	129168	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	47	262944	Engine problem
24	Banco Energy 54MW	IPP	3*18	54	54	578880	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3*19.3	55	55	623806	
27	Southern 55MW	IPP	3*19.3	55	17	41090	Low demand
28	Bosila 108MW	IPP	12*8.75+1*3.5	108	45	537600	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	52	1344660	Engine problem
30	Summit Masana	SIPP, REB	4*8.73	33	33	798100	
31	Summit Rugganj	SIPP, REB	4*8.73	33	21	569600	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	51	802116	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	55	459160	Low demand
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	65	115200	Low demand
<b>Dhaka area Total</b>				<b>5798</b>	<b>2121</b>	<b>40720696</b>	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	150	3200000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	346500	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	131782	
41	Patenga 50MW	IPP	8*6.98	50	50	755520	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	74	1686280	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	42	759360	Engine problem
47	Hathazari peaking	PDB	1*8.9	98	24	15271	
48	Dohazari Peaking	PDB	6*17	102	51	116624	
49	Juidah (Acorn)	QRPP	8*13.45	100	74	1001160	Engine problem
	Juidah 100 MW Unit-3	IPP	0	100	74	1436160	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	20	467424	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	25	561120	
51	Chattogram ECPV 108 MW	IPP	16*7	108	106	869760	
<b>Chattogram area Total</b>				<b>1681</b>	<b>835</b>	<b>14246961</b>	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	80	2194692	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	80	530954	Gas shortage
53	Ashuganj CAPP 225 MW	APSCl	1*142+1*75	221	186	4498000	FGMO
54	Ashuganj CAPP(North)	APSCl	1*360	360	300	5886700	FGMO
55	Ashuganj CAPP(South)	APSCl	1*360	360	272	7105500	FGMO
56	Ashuganj Engines TSK	APSCl	14*3.968	45	35	606240	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	170880	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	217454	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	621030	Engine problem
	Midland 150MW	IPP	23*7.015	150	12	20070	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	798530	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	8128	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	100	1961740	
	Chandpur Desh 200MW	IPP	0	200	108	672000	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	390960	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	212220	
**	Tripura	Imported power	0	160	128	2459520	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	288600	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	540520	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1529</b>	<b>29091738</b>	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	154	3561920	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	350352	
72	Jamalpur 95MW	IPP	12*8.924	95	86	742080	
73	Sarishabari (Solar)	IPP	1*3	3	0	14100	
74	United Mymensingh PPL	IPP	200	200	120	441600	High voltage
	United Jamalpur PPL	IPP	115 MW	0	0	399600	On test
<b>Mymensingh Area Total</b>				<b>522</b>	<b>382</b>	<b>5509652</b>	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	31	621000	GT-1 under maint.
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	60	1431923	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	100	3184412	Low demand
78	Shajibazar 330 MW	PDB	3*110	330	262	6685000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	561000	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	608000	
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	11	176456	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	57	1358496	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	86	707520	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	49	616320	
85	Sylhet GT 150 MW	PDB	1*142	142	0	0	FGMO
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	
87	Sylhet (EPL) 50MW	RPP	27*2	50	24	384080	Low demand
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	320352	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	270	5891250	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	4436700	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	127980	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1088</b>	<b>27110489</b>	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC )	Imported power	2*500	1000	852	16587636	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	0	78720	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	44	176640	
95	Khuina CAPP 225MW	NWPGCL	1*150+1*75	230	175	2643360	Low demand
96	Gopalganj Peaking	PDB	16*9.98	109	55	218240	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	250	7298208	Frequency control
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	566625	
	Khuina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	55680	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	17	385920	Low demand
<b>Khuina Area Total</b>				<b>2209</b>	<b>1433</b>	<b>28011029</b>	
100	Summit Barisal 110 MW	IPP	7*17.076	110	32	110400	High voltage
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	25	461300	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	173	4221392	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	55	835293	
<b>Barisal Area Total</b>				<b>462</b>	<b>285</b>	<b>5618385</b>	
105	Baghabari GT 71MW	PDB	1*71	71	70	1680000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	43	92932	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	40	600820	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	279428	
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sraigonj Unit-1 225MW	NWPGCL	1*150+1*75	210	150	4324518	FGMO
112	Sraigonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Gas shortage
113	Sraigonj Unit-3 225MW	NWPGCL	1*141	141	145	4157272	FGMO
	Sraigonj Unit-4 414 MW(Gas)	SNWPGCL	1*282	282	300	1727500	
114	Santahar Peaking	PDB	6*8.7	50	23	84121	
115	Bogra (GBB)	RPP	6*4	22	22	486720	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	17	307656	
117	Ulapara (Summit)	SIPP, REB	4*2.90	11	11	223794	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	800640	
119	Chapainawabganj-100 MW	PDB	12*8.924	104	70	525896	
</							