

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	735000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	0	800100	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	315	6279564	Frequency Control.
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	50	435904	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	108	1428091	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	40	631100	
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	367	8261630	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	0	0	Under maint.
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	200	5941875	Grid maint.
10	Meghnaghat (IEL)	QRPP	12*9	100	0	0	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Machine problem
12	Madanganj 102MW	QRPP	6*17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	68205	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	79848	
16	Siddhirgonj ST 210MW	PDB	1*210	115	110	2542365	
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	90	1310000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	117	1749255	Machine problem
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	24	62208	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	0	0	Machine problem
24	Banco Energy 54MW	IPP	3*18	54	45	162000	Engine problem
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3*19.3	55	18	72941	Low demand
27	Southern 55MW	IPP	3*19.3	55	17	267360	Low demand
28	Bosila 108MW	IPP	12*9.75+1*3.5	108	35	120360	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*8.67+4*8.73	80	58	1103100	Engine problem
30	Summit Masora	SIPP, REB	4*8.73	33	38	587200	
31	Summit Rugganj	SIPP, REB	4*8.73	33	25	343900	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	41	473772	Low demand
33	Tongi GT	PDB	1* 105	105	40	929005	
34	Summit Gazipur -2	IPP	18*17.076	300	0	0	Reserve
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	48	110880	Low demand
Dhaka area Total				5798	1853	34496263	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	120	2800000	
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	388139	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	124470	
41	Patenga 50MW	IPP	8*6.98	50	47	565920	
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	30	732000	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	227	3234695	
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	16	283680	Low demand
47	Hathazari peaking	PDB	1*8.9	98	68	84048	
48	Dohazari Peaking	PDB	6*17	102	77	228258	
49	Juidah (Acorn)	QRPP	8*13.45	100	0	0	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	75	1233600	Engine problem
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	19	455280	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	24	459840	
51	Chattogram ECPV 108 MW	IPP	16*7	108	26	272640	Low demand
Chattogram area Total				1681	754	10862570	
52	Ashuganj ST: Unit- 3	APSCl	1*150	135	0	197720	Gas shortage
	Ashuganj ST: Unit- 4	APSCl	1*150	129	100	2275850	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	110	2163888	Gas shortage
53	Ashuganj CAPP 225 MW	APSCl	1*142+1*75	221	184	4374000	FGMO
54	Ashuganj CAPP(North)	APSCl	1*360	360	360	7734900	
55	Ashuganj CAPP(South)	APSCl	1*360	360	368	6969000	
56	Ashuganj Engines TSK	APSCl	14*3.968	45	40	605232	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	99360	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	85000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	150545	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	25	264812	Gas shortage
	Midland 150MW	IPP	23*7.015	150	0	0	Engine problem
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	85	955419	
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	6388	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	50	1541820	FGMO
	Chandpur Desh 200MW	IPP	0	200	0	0	Reserve
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	138636	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	88020	
**	Tripura	Imported power	0	160	104	1880640	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	133300	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	15	231200	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1517	29895710	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	183	3888920	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	309384	
72	Jamalpur 95MW	IPP	12*8.924	95	80	724800	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	15000	
74	United Mymensingh PPL	IPP	200	200	50	429600	Low demand
	United Jamalpur PPL	IPP	115 MW	0	0	20400	On test
Mymensingh Area Total				522	335	5388104	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	58	1147000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	20	497400	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	163	1599545	
78	Shajibazar 330 MW	PDB	3*110	330	230	4913000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	50	411600	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	596000	
81	Hobiganj 14 MW	SIPP, REB	4*2.90	11	11	63024	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	56	1306368	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	85	475200	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	48	727200	
85	Sylhet GT 150 MW	PDB	1*142	142	110	2326730	
86	Sylhet GT 20 MW	PDB	1*20	20	19	141000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	24	370880	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	17	109752	Engine problem
89	Summit Bibiana- 2	IPP	1*222+1*119	341	320	6906250	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	52380	
Sylhet Area Total				1549	1271	21643129	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	847	16130909	
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	16	25920	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	0	0	Reserve
95	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Under maint.
96	Gopalganj Peaking	PDB	16*6.98	109	50	124672	
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	350	6926112	Frequency Control.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	161625	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	53	107520	Low demand
Khulna Area Total				2209	1356	23476758	
100	Summit Barisal 110 MW	IPP	7*17.076	110	16	27840	High voltage
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	14	315000	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	164	4035968	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	84	532454	Engine problem
Barisal Area Total				462	278	4911262	
105	Baghabari GT 71MW	PDB	1*71	71	70	990000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	0	0	Reserve
107	Bera Peaking	QRPP	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	33	500880	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	43	72247	Engine problem
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sraigonj Unit-1 225MW	NWPGCL	1*150+1*75	210	196	4529655	FGMO
112	Sraigonj Unit-2 225MW	NWPGCL	1*150+1*75	220	181	3755754	FGMO
113	Sraigonj Unit-3 225MW	NWPGCL	1*141	141	196	4300736	FGMO
	Sraigonj Unit-4 414 MW(Gas)	SNWPGCL	1*282	282	0	0	On test
114	Santahar Peaking	PDB	6*8.7	50	37	33753	
115	Bogra (GBB)	RPP	6*4	22	22	379200	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	14	219240	
117	Ulapara (Summit)	SIPP, REB	4*2.90	11	11	154584	
118	Rajlanka 52 MW	IPP	6*8.92	52	43	705120	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	85	222644	