

Date : 4-Mar-19								Page -2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks		
			Unit No. X Capacity	MW	MW	MW			
1	Ghorasal ST: Unit-1,2	PDB	2'55	85	35	731000	#1 Under maint.		
	Ghorasal GT: Unit-3	PDB	1'210	170	198	1839000			
	Ghorasal GT: Unit-4	PDB	1'210	180	0	0	On test		
	Ghorasal ST: Unit-5	PDB	1'210	190	195	4756500			
2	Ghorasal ST: Unit-7	PDB	1'243+1'122	365	330	6668654			
3	Ghorashal 78MW (MAX)	QRPP	2'40	78	20	270024	Gas shortage		
4	Ghorashal (Regent)	IPP	34'3.35	108	52	625182	Gas shortage		
5	Haripur GT: Unit-1, 2	SBU, PDB	2'32	40	40	795700			
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	363	8642896	FGMO		
7	Haripur NEPC 110MW	IPP	8'15	110	0	0	Reserve		
8	Haripur Power CCPP 350MW	IPP	1'235+1'125	360	0	0	Under maint.		
9	Meghnaghat CCPP 450MW	IPP	2'150+1'150	450	400	8372300	Frequency Control.		
10	Meghnaghat (EL)	QRPP	12'8.9	100	7	13440	Low demand		
11	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	0	0	Machine problem		
12	Madanganj 102MW	QRPP	6'17	100	0	0	Reserve		
13	Madanganj-55 MW	(IPP)	3'17.08+1'11.3	55	40	291693	Low demand		
14	Keraniganj (Powerpac) 100MW	QRPP	8'13.45	100	0	0	Reserve		
15	Narshingdi (Doreen)	SIIP, REB	8'2.90	22	22	229536			
16	Siddhirgonj ST 210MW	PDB	1'210	115	110	2614500			
17	Siddhirgonj GT Unit-1& 2	EGCB	2'105	210	0	247000	Gas shortage		
18	Siddhirgonj (Desh)	QRPP	96'1.2	100	0	0	Reserve		
19	Siddhirgonj (Dutch Bangla)	QRPP	12'8.9	100	0	0	Reserve		
20	Siddhirgonj CCPP-335 MW	EGCB	1'217	217	117	2813946	Machine problem		
21	Paglia (DPA)	QRPP	100'0.5	0	0	0	Contract Expired		
22	Gagnagar (Orion)	IPP	12'8.924	102	24	85248	Low demand		
23	Katpotti 51 MW	IPP	7'7.9	51	41	91296	Low demand		
24	Banco Energy 54MW	IPP	3'18	54	35	330480	Low demand		
25	Kodda 149MW	BPDB-RPCL	9'17.06	149	0	0	Reserve		
26	Northern 55 MW	IPP	3'19.3	55	0	29096	Reserve		
27	Southern 55MW	IPP	3'19.3	55	0	79800	Reserve		
28	Bosila 108MW	IPP	12'8.775+1'3.5	108	48	161280	Engine problem		
29	Summit Power (Madhabdi+Ashulka)	SIIP, REB	3'3.67+4'8.73	80	58	1293180	Engine problem		
30	Summit Maona	SIIP, REB	4'8.73	33	33	796800			
31	Summit Ruppang	SIIP, REB	4'8.73	33	33	782000			
32	Gasipur (RPCL)	IPP	6'8.9	52	43	419160	Engine problem		
33	Tongi GT	PDB	11'105	105	40	962674	Gas shortage		
34	Summit Gasipur -2	IPP	18'17.076	300	0	0	Reserve		
35	APR Energy Keraniganj	IPP	256'1.4	300	0	0	Reserve		
36	Bramhangonj 100 MW (Aggreko)	IPP	100	100	0	0	Reserve		
37	Aggreko Aurahati 100MW	IPP	0.85'23+0.95'91	100	0	0	Reserve		
38	Summit Gasipur-1 150MW	IPP	149	149	11	28800	Low demand		
Dhaka area Total				5798	2295	43971185			
39	Chattogram ST-1 (Raozan)	PDB	1'210	180	150	3100000	Gas shortage		
	Chittong ST-2 (Raozan)	PDB	1'210	180	0	0	Gas shortage		
40	Raozan 25 MW (RPCL)	IPP	3'8.9	25	18	226296	Engine problem		
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	134865			
41	Patenga 50MW	IPP	8'6.98	50	29	289440	Engine problem		
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	41	940484	Low water level		
43	Sikalbaha ST 60MW	PDB	1'60	40	0	0	Under maint.		
44	Sikalbaha 225MW	PDB	1'150+1'175	225	201	4859363			
45	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.		
46	Sikalbaha (Energis)	RPP	4'12.5+2'11.9+1'3+1'1.5	51	40	679680	Engine problem		
47	Hathazari peaking	PDB	11'8.9	98	12	16953	Low demand		
48	Dohazari Peaking	PDB	6'17	102	17	31200	Low demand		
49	Juldah (Acorn)	QRPP	8'13.45	100	45	305760	Low demand		
	Juldah 100 MW Unit-3	IPP	0	100	101	1332480			
50	Barabkunda (Regent)	SIIP, PDB	8'2.90	22	20	385296			
	* Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	29	453120			
51	Chattogram ECPV 108 MW	IPP	16'7	108	51	73920	Low demand		
Chattogram area Total				1681	754	12828857			
52	Ashuganj ST: Unit- 3	APSCl	1'150	135	70	1680620	Gas shortage		
	Ashuganj ST: Unit- 4	APSCl	1'150	129	70	1682150	Gas shortage		
	Ashuganj ST: Unit- 5	APSCl	1'150	134	0	0	Under maint.		
53	Ashuganj CCPP 225 MW	APSCl	1'142+1'175	221	186	4532000	FGMO		
54	Ashuganj CCPP(North)	APSCl	1'360	360	300	6437000			
55	Ashuganj CCPP(South)	APSCl	1'360	360	300	6303500			
56	Ashuganj Engines TSK	APSCl	14'3.968	45	40	5576704	Engine problem		
57	Ashuganj (Precision) 55MW	RPP	15'4	55	5	134400	Gas shortage		
58	Ashuganj (United) 53MW	QRPP	14'4	53	5	120000	Gas shortage		
59	Ashuganj 195MW Modular	IPP	20'9.73+1'116	195	8	150545	Line problem		
60	Ashuganj (Midland) 51MW	IPP	6'9.34	51	0	0	Reserve		
	Midland 150MW	IPP	23'7.015	150	0	0	Reserve		
61	B. Bania (Aggreko) 85MW	QRPP	86'1.10	85	85	564993	FGMO		
62	Daudkandi Peaking 52MW	PDB	6'8.92	52	5	2224	Low demand		
63	Chandpur CCPP	PDB	1'106+1'57	163	90	1592877			
	Chandpur Desh 200MW	IPP	0	200	17	396960	Low demand		
64	Feni (Doreen) 22MW	SIIP, PDB	8'2.90	22	22	322236			
65	Feni, Mohipal (Doreen)	SIIP, REB	4'2.90	11	11	224100			
**	Tripura	Imported power	0	160	116	2253120			
66	Jangalia (Summit) 33MW	SIIP, PDB	4'8.73	33	30	162400			
67	Lakdhanvi 52 MW	IPP	6'8.92	52	0	0	Reserve		
68	Summit Cumilla 25MW	SIIP, PDB	3'3.67+2'6.97	25	15	363850	Engine problem		
69	Daudkandi bangla trak	IPP	154'1.4	200	0	0	Reserve		
Cumilla Area Total				2891	1375	27479679			
70	Mymensingh RPCL 210MW	IPP	4'35+1'70	202	199	4451240	Gas shortage		
71	Tangail (Doreen) 22MW	SIIP, PDB	8'2.90	22	22	327852			
72	Jamalpur 95MW	IPP	12'8.924	95	87	899520	Engine problem		
73	Sarishabari (Solar)	IPP	1'3	3	0	9400			
74	United Mymensingh PPL	IPP	200	200	30	290400	Low demand		
	United Jamalpur PPL	IPP	115 MW	115	0	0	Reserve		
Mymensingh Area Total				637	338	5978412			
75	Fenchugonj CCPP-1	PDB	2'32+1'33	70	60	1201000			
76	Fenchugonj CCPP-2	PDB	2'35+1'35	90	71	1573800			
77	Kushara 163 MW CCPP GT	IPP	1'109+1'54	163	163	3266400			
78	Shajibazar 330 MW	PDB	3'110	330	154	3432000	FGMO		
79	Fenchugonj (Barakattullah) 51MW	RPP	19'2.90	51	52	597600			
80	Fenchugonj (EPL) 44MW	RPP	12'3.3+5'2	44	25	600000	Frequency Control.		
81	Hohiganj 11MW	SIIP, REB	4'2.90	11	11	209552			
82	Shajibazar GT: Unit- 8, 9	PDB	2'35	66	41	1265280	FGMO		
83	Shajibazar 86MW	RPP	32'2.90	86	80	798720			
84	Shajibazar (EPL) 50MW	RPP	27'2.0	50	47	689040			
85	Sylhet GT 150 MW	PDB	1'142	142	109	2424810	Frequency Control.		
86	Sylhet GT 20 MW	PDB	1'20	20	0	0	Reserve		
87	Sylhet (EPL) 50MW	RPP	27'2	50	24	445560	Engine problem		
88	Shahjahanulla 25 MW	SIIP, REB	3'9.34	25	25	146160			
89	Summit Bibiana- 2	IPP	1'222+1'119	341	300	7358400	FGMO		
	Bibiya-3 285MW	PDB	285 MW	0	0	80500	On test		
90	Sylhet (Desh) 10MW	RPP	6'1.95	10	10	44460			
Sylhet Area Total				1549	1172	24142742			
91	Bheramara GT-1,2,3	PDB	3'20	46	0	0	Reserve		
**	Bheramara (HVDC)	Imported power	2'500	1000	854	16312727			
92	Khulna (KPCL-1 & 3)	IPP	19'6.5	0	0	0	Contract Expired		
93	Khulna (KPCL-2)	QRPP	7'17	115	16	35520	Low demand		
94	Faridpur Peaking	PDB	8'6.89	54	6	20640	Low demand		
95	Khulna CCPP 225MW	NWPGCL	1'150+1'175	230	0	0	Reserve		
96	Gopalganj Peaking	PDB	16'6.98	109	50	142592	Low demand		
97	Bheramara 360 MW	NWPGCL	1'278+1'132	410	380	7108992	Frequency Control.		
98	Noapara (KZA) 40MW	QRPP	5'8.5	40	32	238500			
	Khulna (Aggreco) 55MW	QRPP	71'0.85	0	0	0	Contract Expired		
99	Bangla Trak Noapara	IPP	70'1.4	100	0	0	Reserve		
	Labon Chora 105 MW	IPP	6'18.445	105	105	408000			
Khulna Area Total				2209	1443	24266971			
100	Summit Barisal 110 MW	IPP	7'17.076	110	32	126720	Low demand		
101	Barisal GT: Unit-1, 2	PDB	2'20	30	0	0	Reserve		
102	Bhola (Venture) 33MW	RPP	1'34.50	33	25	371000	Engine problem		
103	Bhola CCPP 194MW	PDB	2'63+1'168	194	144	4257820			
104	Bhola Aggreko 95MW	QRPP	96'1.10	95	68	679990			
Barisal Area Total				462	269	5433530			
105	Baghabari GT 71MW	PDB	1'71	71	65	1495000			
106	Baghabari GT 100MW	PDB	1'100	100	0	0	Under maint.		
107	Baghabari Peaking 50MW	PDB	6'8.9	52	0	0	Reserve		
	Bera Peaking	PDB	9'8.29	71	0	0	Reserve		
108	Amnura 50MW	QRPP	7'7.79	50	50	329040			
109	Katakhat (Northern)	QRPP	6'8.9	50	16	29843	Low demand		
110	Katakhat Peaking	PDB	6'8.7	50	0	0	Reserve		
111	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	192	4175582	FGMO		
112	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	188	3966618	FGMO		
113	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	0	0	FGMO		
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1'282	282	0	0	On test		
114	Santahar Peaking	PDB	6'8.7	50	37	57726			
115	Bogra (GBB)	RPP	6'4	22	22	396720			
116	Bogra (EPL)	RPP	5'3.3+5'2	10	15	295488			
117	Ullapara (Summit)	SIIP, REB	4'2.90	11	11	206496			
118	Rajkanta 52 MW	IPP	6'8.92	52	43	494880	Engine problem		
119	Chapainawabganj-100 MW	PDB	12'8.924	104	51	145200	Low demand		
	Paramount Baghabari	IPP	200 MW	200	0	0</			