

Date : 7-Mar-19

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	734000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	0	0	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	170	4236750	
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	320	7403236	Gas shortage
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	40	802816	Gas shortage
4	Ghorasal (Regent)	IPP	3*43.35	108	108	1224227	
5	Haripur GT: Unit-1, 2	SBU_PDB	2*32	40	40	363400	
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	367	8766470	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	0	0	Under maint.
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	450	8782625	
10	Meghnaghat (IEL)	QRPP	12*9	100	0	0	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	0	0	Machine problem
12	Madanganj 102MW	QRPP	6*17	100	30	63720	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	50	265791	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	207288	
16	Siddhirgonj ST 210MW	PDB	1*210	115	110	2623950	
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	115	2866000	Gas shortage
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	115	1624637	Machine problem
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	30	136512	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	34	190656	Low demand
24	Banco Energy 54MW	IPP	3*18	54	54	457200	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	0	0	Reserve
26	Northern 55 MW	IPP	3*19.3	55	55	233164	
27	Southern 55MW	IPP	3*19.3	55	0	0	Reserve
28	Bosila 108MW	IPP	12*8.75+1*13.5	108	64	286560	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP REB	3*8.67+4*8.73	80	51	1277340	Engine problem
30	Summit Madona	SIPP REB	4*8.73	33	33	782400	
31	Summit Rugganj	SIPP REB	4*8.73	33	33	754000	
32	Gazipur (RPCL)	IPP	6*8.9	52	10	447936	Low demand
33	Tongi GT	PDB	1* 105	105	0	662918	Gas shortage
34	Summit Gazipur- 2	IPP	18*17.076	300	0	15050	Reserve
35	APR Energy , Keranigonj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggrek)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	19	31680	Low demand
Dhaka area Total				5798	2355	45252326	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	135	3200000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	99540	
	Teknaf Solartech 20MW	Teknaf Solartech Energ	20	20	0	58320	
41	Patenga 50MW	IPP	8*6.98	50	43	78720	Engine problem
42	Kaptal Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1621960	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	201	4813822	Frequency Control.
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	37	580800	Engine problem
47	Hathazari peaking	PDB	1*18.9	98	0	24320	Reserve
48	Dohazari Peaking	PDB	6*17	102	17	13032	Low demand
49	Juidah (Acorn)	QRPP	8*13.45	100	12	271320	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	101	854400	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	21	496608	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	13	451680	
51	Chattogram ECPV 108 MW	IPP	16*7	108	4	31440	Low demand
Chattogram area Total				1681	679	12601962	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	70	1650962	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	80	1899840	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Under maint.
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	185	4589000	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	340	7733800	
55	Ashuganj CAPP(South)	APSCL	1*360	360	250	6594500	Gas shortage
56	Ashuganj Engines TSK	APSCL	14*3.968	45	40	680544	
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	128160	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	12000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Low demand
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	515100	Low demand
	Midland 150MW	IPP	23*7.015	150	65	65580	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	8	90856	Low demand
63	Chandpur CAPP	PDB	1*106+1*57	163	0	56990	Under maint.
	Chandpur Desh 200MW	IPP	0	200	142	1585920	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	0	219636	Under maint.
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	257220	
**	Tripura	Imported power	0	160	124	2289600	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	33	391800	
67	Lakdhanvi 52 MW	IPP	6*8.92	52	0	0	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	22	437200	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1423	29319435	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	208	4566320	
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	395604	
72	Jamalpur 95MW	IPP	12*8.924	95	88	740160	
73	Sarishabari (Solar)	IPP	1*3	3	0	12350	
74	United Mymensingh PPL	IPP	200	200	30	254400	Low demand
	United Jamalpur PPL	IPP	115 MW	115	0	0	Reserve
Mymensingh Area Total				637	348	5968834	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	60	1197000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	60	1418542	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	163	3142220	
78	Shajbazar 330 MW	PDB	3*110	330	192	4265000	FGMO
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	51	618000	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	35	605000	
81	Hobiganj 140 MW	SIPP, REB	4*2.90	11	11	93216	
82	Shajbazar GT: Unit- 8, 9	PDB	2*35	66	46	1286976	FGMO
83	Shajbazar 86MW	RPP	32*2.90	86	84	1063680	
84	Shajbazar (EPL) 50MW	RPP	27*2.0	50	46	806400	
85	Sylhet GT 150 MW	PDB	1*142	142	115	2383400	Frequency Control.
86	Sylhet GT 20 MW	PDB	1*20	20	19	72000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	47	677380	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	23	288504	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	300	7793500	FGMO
	Bibiana-3 285MW	PDB	285 MW	0	0	151300	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	9	123660	
Sylhet Area Total				1549	1261	25985778	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	850	16635636	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	16	68160	Low demand
94	Faridpur Peaking	PDB	8*6.89	54	0	23520	Reserve
95	Khuina CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*9.98	109	86	241152	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	270	8041824	Frequency Control.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	394875	
	Khuina (Aggreko) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	105	447360	
Khuina Area Total				2209	1367	25852527	
100	Summit Barisal 110 MW	IPP	7*17.076	110	48	174720	Low demand
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	20	324800	Engine problem
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	164	4195351	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	777250	
Barisal Area Total				462	328	5472121	
105	Baghabari GT 71MW	PDB	1*71	71	65	1352000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	0	0	Reserve
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.9	50	50	544940	
109	Katakhal (Northern)	QRPP	6*8.9	50	0	0	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sraigonj Unit-1 225MW	NWPGCL	1*150+1*75	210	169	4566518	FGMO
112	Sraigonj Unit-2 225MW	NWPGCL	1*150+1*75	220	177	4372518	FGMO
113	Sraigonj Unit-3 225MW	NWPGCL	1*141	220	182	4375381	FGMO
	Sraigonj Unit-4 414 MW(Gas)	SNWPGCL	1*282	282	0	0	On test
114	Santahar Peaking	PDB	6*8.7	50	0	16073	Reserve
115	Bogra (GBB)	RPP	6*4	22	22	439200	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	14	268812	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	0	148788	Machine problem
118	Rajlanka 52 MW	IPP	6*8.92	52	45	625920	Engine problem
119	Chapainawabganj-100 MW	PDB	12*8.924	104	51	123384	Low demand
	Paramount Baghabari	IPP	2				