

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	36	782000	Unit-1 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	74	2074700	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	100	2527000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2362500	
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	250	6243136	
3	Ghorasal 78MW (MAX)	IPB	2*40	78	75	1132096	
4	Ghorasal (Regent)	IPB	3*43.35	108	107	1204954	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	354	8050420	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	23500	Reserve
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	302	7169000	Frequency control
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	350	8360625	Frequency control
10	Meghnaghat (IEL)	QRPP	12*9	100	0	64320	Reserve
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	250	5774924	Frequency control
12	Madanganj 102MW	QRPP	6*17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	159250	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	51154	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	240984	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	120	2733000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	9600	Reserve
20	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	0	0	Under maint.
21	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	24	565200	Low demand
23	Katpotti 51 MW	IPP	7*7.9	51	48	444480	
24	Banco Energy 54MW	IPP	3*18	54	54	806760	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	64	631680	Low demand
26	Northern 55 MW	IPP	3*19.3	55	55	636699	
27	Southern 55MW	IPP	3*19.3	55	55	582930	
28	Bosila 108MW	IPP	12*9.75+1*13.5	108	49	416840	
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*9.73	80	57	1335660	Engine problem
30	Summit Masona	SIPP, REB	4*8.73	33	33	794100	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	821100	
32	Gazipur (RPCL)	IPP	6*8.9	52	50	696814	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	0	60220	Reserve
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1. 150MW	IPP	149	149	49	455040	Low demand
Dhaka area Total				5798	2728	57246486	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2300000	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	16	154975	Engine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	120285	
41	Patenga 50MW	IPP	8*6.98	50	50	504000	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	80	1809065	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4767205	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under S/D
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	51	1141920	
47	Hathazari peaking	PDB	1*8.9	98	0	85071	Reserve
48	Dohazari Peaking	PDB	6*17	102	80	261499	
49	Juidah (Acorn)	QRPP	8*13.45	100	50	348240	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	100	2094720	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	504240	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	15	328320	
51	Chattogram ECPV 108 MW	IPP	16*7	108	105	1401600	
Chattogram area Total				1681	992	18721140	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	80	1923456	Gas shortage
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	223	5151000	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	280	6858500	Gas shortage
55	Ashuganj CAPP(South)	APSCL	1*360	360	250	6416000	Gas shortage
56	Ashuganj Engines TSK	APSCL	14*3.968	45	37	636768	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	128160	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	110	1472000	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	447000	Engine problem
	Midland 150MW	IPP	23*7.015	150	30	50180	Reserve
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	5384	Reserve
63	Chandpur CAPP	PDB	1*106+1*57	163	100	1099350	
	Chandpur Desh 200MW	IPP	0	200	100	1350120	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	491868	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	138600	Engine problem
**	Tripura	Imported power	0	160	142	2762880	
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	363700	Engine problem
67	Lakhanvi 52 MW	IPP	6*8.92	52	0	37853	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	18	316840	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1480	29769659	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	181	4605720	Gas shortage
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	338184	
72	Jamalpur 95MW	IPP	12*8.924	95	65	246720	Low demand
73	Sarishabari (Solar)	IPP	1*3	3	0	8350	
74	United Mymensingh PPL	IPP	200	200	7	60000	Low demand
	United Jamalpur PPL	IPP	115 MW	115	107	1466400	Engine problem
Mymensingh Area Total				637	380	6725374	
75	Fenchugonj CAPP-1	PDB	2*32+1*33	70	60	1205000	
76	Fenchugonj CAPP-2	PDB	2*35+1*35	90	74	1716400	
77	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	163	3215274	
78	Shajibazar 330 MW	PDB	3*110	330	335	4463000	
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	25	407400	
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	651000	
81	Hobiganj 110MW	SIPP, REB	4*2.90	11	11	210000	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	40	1212672	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	85	830400	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	47	735480	
85	Sylhet GT 150 MW	PDB	1*142	142	103	2275130	
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	Machine problem
87	Sylhet (EPL) 50MW	RPP	27*2	50	44	692820	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	25	295320	
89	Summit Bibiana- 2	IPP	1*222+1*119	341	285	7343800	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	119160	
Sylhet Area Total				1549	1357	25372856	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	947	20043636	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	105	514560	Engine problem
94	Faridpur Peaking	PDB	8*6.89	54	37	314880	
95	Khuina CAPP 225MW	NWPGL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*9.98	109	74	730496	
97	Bheramara 360 MW	NWPGL	1*278+1*132	410	200	5589216	Line O/L
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	198000	
	Khuina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	105	1530240	
	Madhumati Power Plant	IPP	100 MW	0	0	0	On test
Khuina Area Total				2209	1508	28921028	
100	Summit Barisal 110 MW	IPP	7*17.076	110	110	1556160	
101	Barisal GT: Unit-1, 2	PDB	2*20	30	26	141717	
102	Bhola (Venture) 33MW	RPP	1*34.50	33	32	562277	
103	Bhola CAPP 194MW	PDB	2*63+1*68	194	120	288500	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	22614360	
Barisal Area Total				462	385	25163014	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	289703	
107	Bera Peaking	PDB	9*8.29	71	49	193802	
108	Amnura 50MW	QRPP	7*7.9	50	35	126310	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	133597	
110	Katakhal Peaking	PDB	6*8.7	50	0	27968	Reserve
111	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	180	4573282	FGMO
112	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	185	4286491	FGMO
113	Sirajgonj Unit-3 225MW	NWPGL	0	1141	220	0	Gas shortage
	Sirajgonj Unit-4. 414 MW(Gas)	SNWPGL	1*282	282	427	10283091	On test
114	Santahar Peaking	PDB	6*8.7	50	30	106550	
115	Bogra (GBB)	RPP	6*4	22	22	402720	
116	Bogra (EPL)	RPP	5*3.4+5*2	10	15	298620	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	242042	
118	Rajlanka 52 MW	IPP	6*8.92	52	33	461760	Low demand