

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	36	792000	Unit-1 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	74	1921800	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	100	2401000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2835000	
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	250	5623354	Frequency control
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	0	387296	
4	Ghorasal (Regent)	IPP	34*3.35	108	105	788272	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	350	8427212	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	310	6631000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	450	8210250	
10	Meghnaghat (JEL)	QRPP	12*8.9	100	0	7680	Reserve
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	210	5529367	Frequency control
12	Madanganj 102MW	QRPP	6*17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	0	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	329400	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	80	2677000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	0	0	Under maint.
21	Paglia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	50	155664	Low demand
23	Kalpottli 51 MW	IPP	7*7.9	51	24	274320	
24	Banco Energy 54MW	IPP	3*18	54	54	670320	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	82	488640	Low demand
26	Northern 55 MW	IPP	3*19.3	55	18	459146	Low demand
27	Southern 55MW	IPP	3*19.3	55	55	496480	
28	Bosila 105MW	IPP	12*8.775+1*13.5	108	8	42240	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	58	1113720	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	0	725000	Tripped at 18:42
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	729900	
32	Gazipur (RPCL)	IPP	6*8.9	52	50	654804	
33	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	0	0	Reserve
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	18	270720	Low demand
Dhaka area Total				5798	2554	52641585	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	110	2400000	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1*210	180	150	3100000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	18	115380	Engine problem
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	121770	
41	Patenga 50MW	IPP	8*6.98	50	50	606240	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	40	1270860	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	214	4876179	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under S/D
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	41	879840	Low demand
47	Hathazari peaking	PDB	1*8.9	98	40	111400	Low demand
48	Dohazari Peaking	PDB	6*17	102	34	134168	Low demand
49	Juidah (Acorn)	QRPP	8*13.45	100	88	522600	
	Juidah 100 MW Unit-3	IPP	0	100	100	1525440	
50	Barakunda (Regent)	SIPP, PDB	8*2.90	22	22	461760	
	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	22	534240	
51	Chattogram ECPV 108 MW	IPP	16*7	108	105	637440	
Chattogram area Total				1681	1034	17297317	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	80	1923456	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	202	4826000	FGMO
54	Ashuganj CCPP(North)	APSCL	1*360	360	360	7160500	
55	Ashuganj CCPP(South)	APSCL	1*360	360	330	6700500	Gas shortage
56	Ashuganj Engines TSK	APSCL	14*3.968	45	39	685224	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	128640	Gas shortage
58	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	110	1722909	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	384830	Gas shortage
	Midland 150MW	IPP	23*7.015	150	50	160580	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
63	Chandpur CCPP	PDB	1*106+1*57	163	0	373860	Under maint.
	Chandpur Desh 200MW	IPP	0	200	200	2887680	
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	500868	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	137880	
**	Tripura	Imported power	0	160	0	889920	S/D for D/W
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	141500	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	42	656179	Low demand
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	17	339950	Engine problem
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1540	29546676	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	204	4666600	
71	Tangali (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	206676	
72	Jamalpur 95MW	IPP	12*8.924	95	80	410880	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	7800	
74	Uniled Mymensingh PPL	IPP	200	200	7	38400	Low demand
	Uniled Jamalpur PPL	IPP	115 MW	115	106	627600	
Mymensingh Area Total				637	417	5957956	
75	Fenchugonj CCPP-1	PDB	2*32+1*33	70	30	868000	
76	Fenchugonj CCPP-2	PDB	2*35+1*35	90	40	670680	Frequency control
77	Kushlira 163 MW CCPP GT	IPP	1*109+1*54	163	100	3027845	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	330	6999000	
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	25	289800	High Voltage
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	50	482000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	133136	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	64	1227744	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	85	1077120	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	47	800280	
85	Sylhet GT 150 MW	PDB	1*142	142	115	2583770	
86	Sylhet GT 20 MW	PDB	1*20	20	0	0	Machine problem
87	Sylhet (EPL) 50MW	RPP	27*2	50	42	511180	
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	8	31680	Tripped at 19:04
89	Summit Bibiana- 2	IPP	1*222+1*119	341	280	6755000	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	0	5220	Reserve
Sylhet Area Total				1549	1227	25562455	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	839	15913455	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	115	679680	
94	Faridpur Peaking	PDB	8*6.89	54	32	688320	
95	Khuina CCPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*9.98	109	47	587392	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	200	5437440	Line O/L
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	170625	
	Khuina (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	90	1490880	Low demand
	Madhumati Power Plant	IPP	100 MW	0	0	0	on test.
Khuina Area Total				2209	1363	24967792	
100	Summit Barisal 110 MW	IPP	7*17.076	110	110	1701120	
101	Barisal GT: Unit-1, 2	PDB	2*20	30	26	184713	
102	Bhola (Venture) 33MW	RPP	1*34.50	33	33	560366	
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	120	2801000	ST under maintenance
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2277235	
Barisal Area Total				462	386	7524434	
105	Baghabari GT 71MW	PDB	1*71	71	0	0	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	332782	
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7*7.79	50	37	182870	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	50	246252	
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	184	4863282	FGMO
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	187	4413582	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	0	0	Gas shortage
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282	282	198	6274820	On test
114	Santahar Peaking	PDB	6*8.7	50	29	112985	
115	Bogra (GBB)	RPP	6*4	22	22	323280	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	15	200124	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	248184	
118	Rajlanka 52 MW	IPP	6*8.92	52	43	2	