

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present		Energy Generated	Remarks
				Capacity	Hour		
1	Ghorasal ST: Unit-1,2	PDB	2'55	85	38	850000	Unit-1 under maint.
	Ghorasal GT: Unit-3	PDB	1'210	170	134	2801000	On test
	Ghorasal GT: Unit-4	PDB	1'210	180	150	1403000	On test
	Ghorasal ST: Unit-5	PDB	1'210	190	120	2923200	
2	Ghorasal ST: Unit-7	PDB	1'243+1'122	365	300	6846000	
3	Ghorasal 75MW (MAX)	QRP	2'40	78	0	0	Gas shortage
4	Ghorasal (Regent)	IPP	34'3.35	108	12	307363	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2'32	40	20	151400	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	0	6527000	Machine Problem
7	Haripur NEPC 110MW	IPP	8'15	110	0	0	Reserve
8	Haripur Power CCPP 360MW	IPP	1'235+1'125	360	360	7411000	
9	Meghnaghat CCPP 450MW	IPP	2'150+1'150	450	380	8838125	Frequency control
10	Meghnaghat (IEL)	QRPP	12'8.9	100	0	6720	Reserve
11	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	250	6300160	Gas shortage
12	Madanganj 102MW	QRPP	6'17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3'17.08+1'11.3	55	0	21416	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8'13.45	100	0	0	Reserve
15	Narsingdi (Doreen)	SIPP, REB	8'2.90	22	16	326124	Engine problem
16	Siddhirgonj ST 210MW	PDB	1'210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2'105	210	130	2070000	FGMO
18	Siddhirgonj (Desh)	QRPP	96'1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12'8.9	100	0	0	Reserve
20	Siddhirgonj CCPP-335 MW	EGCB	1'217	217	120	2638728	Gas shortage
21	Pagla (DPA )	QRPP	100'0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12'8.924	102	7	181872	Low demand
23	Kalpott 51 MW	IPP	7'7.9	51	6	276096	
24	Banco Energy 54MW	IPP	3'18	54	54	879120	
25	Kodda 149MW	BPDB-RPCL	9'17.06	149	98	665760	Low demand
26	Northern 55 MW	IPP	3'19.3	55	55	637429	
27	Southern 55MW	IPP	3'19.3	55	35	466000	Low demand
28	Bosila 105MW	IPP	12'8.775+1'13.5	108	58	429120	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3'3.67+4'8.73	80	56	6701100	Engine problem
30	Summit Maona	SIPP, REB	4'8.73	33	33	794300	
31	Summit Rugganji	SIPP, REB	4'8.73	33	33	723000	
32	Gazipur (RPCL)	IPP	6'8.9	52	51	791400	
33	Tongi GT	PDB	1' 105	105	0	284799	Gas shortage
34	Summit Gazipur-2	IPP	18'17.076	300	0	12540	Reserve
35	APR Energy ,Keraniganj	IPP	256'1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85'23+0.95'91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	100	828000	Low demand
<b>Dhaka area Total</b>				<b>5798</b>	<b>2616</b>	<b>63091772</b>	
39	Chattogram ST-1 (Raozan)	PDB	1'210	180	110	2600000	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1'210	180	120	1300000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3'8.9	25	25	311828	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	147420	
41	Patenga 50MW	IPP	8'6.98	50	50	847200	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	109	1897013	Low water level
43	Sikalbaha ST 60MW	PDB	1'60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1'150+1'175	225	203	4899345	FGMO
45	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under S/D
46	Sikalbaha (Energis)	RPP	4'12.5+2'11.9+1'3+1'1.5	51	41	775200	Engine problem
47	Hathazari peaking	PDB	1'18.9	98	40	191616	
48	Dohazari Peaking	PDB	6'17	102	68	479631	
49	Juidah (Acom)	QRPP	8'13.45	100	60	408600	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	100	1516800	
50	Barabkunda (Regent)	SIPP, PDB	8'2.90	22	22	524640	
*	Malancha, Ctg. EPZ (Uniled)		5'8.73+3'9.34	0	16	465600	
51	Chattogram ECPV 108 MW	IPP	16'7	108	98	1176960	Engine problem
<b>Chattogram area Total</b>				<b>1681</b>	<b>1062</b>	<b>17541853</b>	
52	Ashuganj ST: Unit- 3	APSCL	1'150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1'150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1'150	134	0	0	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1'142+1'175	221	220	4689000	FGMO
54	Ashuganj CCPP(North)	APSCL	1'360	360	300	6843000	
55	Ashuganj CCPP(South)	APSCL	1'360	360	300	6885500	
56	Ashuganj Engines TSK	APSCL	14'3.968	45	40	865008	
57	Ashuganj (Precision) 55MW	RPP	15'4	55	30	252960	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14'4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20'9.73+1'16	195	110	2760000	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6'9.34	51	45	457484	Machine Problem
	Midland 150MW	IPP	23'7.015	150	50	110400	Low demand
61	B. Baria (Aggreko) 85MW	QRPP	86'1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6'8.92	52	0	0	Reserve
63	Chandpur CCPP	PDB	1'106+1'57	163	50	1918160	
	Chandpur Desh 200MW	IPP	0	200	125	718560	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8'2.90	22	19	424728	
65	Feni, Mohipal (Doreen)	SIPP, REB	4'2.90	11	11	242460	
**	Tripura	Imported power	0	160	160	730240	
66	Jangalla (Summit) 33MW	SIPP, PDB	4'8.73	33	33	576100	
67	Lakdhanvi 52 MW	IPP	6'8.92	52	25	44342	Low demand
68	Summit Cumilla 25MW	SIPP, PDB	3'3.67+2'6.97	25	21	339870	
69	Daudkandi bangla trak	IPP	154'1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1544</b>	<b>27756812</b>	
70	Mymensingh RPCL 210MW	IPP	4'35+1'70	202	160	4318600	
71	Tangal (Doreen) 22MW	SIPP, PDB	8'2.90	22	20	293724	
72	Jamalpur 95MW	IPP	12'8.924	95	80	504960	Engine problem
73	Sarishabari (Solar)	IPP	1'3	3	0	14650	
74	Uniled Mymensingh PPL	IPP	200	200	100	408000	Low demand
	Uniled Jamalpur PPL	IPP	115 MW	115	109	1203600	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>469</b>	<b>6743534</b>	
75	Fenchugonj CCPP-1	PDB	2'32+1'33	70	60	1391000	
76	Fenchugonj CCPP-2	PDB	2'35+1'35	90	73	1551240	
77	Kushlira 163 MW CCPP GT	IPP	1'109+1'54	163	70	176702	Low demand
78	Shajibazar 330 MW	PDB	3'110	330	254	5638000	Frequency control
79	Fenchugonj (Barakatullah) 51MW	RPP	19'2.90	51	47	619200	
80	Fenchugonj (EPL) 44MW	RPP	12'3.3+5'2	44	46	663000	
81	Hobiganj 11MW	SIPP, REB	4'2.90	11	11	207264	
82	Shahjibazar GT: Unit- 8, 9	PDB	2'35	66	53	1331904	FGMO
83	Shahjibazar 86MW	RPP	32'2.90	86	85	1141440	
84	Shahjibazar (EPL) 50MW	RPP	27'2.0	50	45	717480	
85	Sylhet GT 150 MW	PDB	1'142	142	110	2490330	FGMO
86	Sylhet GT 20 MW	PDB	1'20	20	0	9000	
87	Sylhet (EPL) 50MW	RPP	27'2	50	29	423700	Frequency control
88	Shahjahanulla 25 MW	SIPP, REB	3'9.34	25	25	570888	
89	Summit Bibiana- 2	IPP	1'222+1'119	341	280	6844500	FGMO
	Bibiyana-3 285MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6'1.95	10	10	71640	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1198</b>	<b>23847288</b>	
91	Bheramara GT-1,2,3	PDB	3'20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2'500	1000	946	19914182	
92	Khuilna (KPCL-1 & 3)	IPP	19'6.5	0	0	0	Contract Expired
93	Khuilna (KPCL-2)	QRPP	7'17	115	66	288000	Low demand
94	Faridpur Peaking	PDB	8'6.89	54	36	191200	
95	Khuilna CCPP 225MW	NWPGCL	1'150+1'175	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16'6.98	109	0	49536	Reserve
97	Bheramara 360 MW	NWPGCL	1'278+1'132	410	0	0	Under maint.
98	Noapara (KZA) 40MW	QRPP	5'8.5	40	24	95250	
	Khuilna (Aggreco) 55MW	QRPP	71'0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70'1.4	100	0	0	Reserve
	Labon Chora 105 MW	IPP	6'18.445	105	90	1027040	Low demand
	Madhumati Power Plant	IPP	100 MW	0	57	728064	on test.
<b>Khuilna Area Total</b>				<b>2209</b>	<b>1219</b>	<b>22293272</b>	
100	Summit Barisal 110 MW	IPP	7'17.076	110	48	1180800	Low demand
101	Barisal GT: Unit-1, 2	PDB	2'20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1'34.50	33	32	503663	
103	Bhola CCPP 194MW	PDB	2'63+1'68	194	120	3045000	ST under maintenance
104	Bhola Aggreko 95MW	QRPP	96'1.10	95	53	1815060	Low demand
<b>Barisal Area Total</b>				<b>462</b>	<b>253</b>	<b>6544523</b>	
105	Baghabari GT 71MW	PDB	1'71	71	60	1340000	
	Baghabari GT 100MW	PDB	1'100	100	0	945000	Under maint.
106	Baghabari Peaking 50MW	PDB	6'8.9	52	34	147974	
107	Bera Peaking	PDB	9'8.29	71	0	0	Reserve
108	Amnura 50MW	QRPP	7'7.79	50	35	253570	Engine problem
109	Katakhal (Northern)	QRPP	6'8.9	50	24	38408	Low demand
110	Katakhal Peaking	PDB	6'8.7	50	28	28555	
111	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	154	4434918	FGMO
112	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	145	4300009	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	150	4340145	FGMO
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1'282	282	300	5961182	Frequency control
114	Santabar Peaking	PDB	6'8.7	50	36	110842	
115	Bogra (GBB)	RPP	6'4	22	22	388320	
116	Bogra (EPL)	RPP	5'3.3+5'2	10	14	218448	
117	Ullapara (Summit)	SIPP, REB	4'2.90	11	11	242928	
118	Rajlanka 52 MW	IPP	6'8.92	52	52		