

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	38	853000	Unit-1 under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	159	2779700	On test
	Ghorasal GT: Unit-4	PDB	1*210	180	100	2637000	On test
	Ghorasal ST: Unit-5	PDB	1*210	190	120	2967300	
2	Ghorasal ST: Unit-7	QRP	1*243+1*122	365	280	654772	Frequency control
3	Ghorasal 75MW (MAX)	QRP	2*40	78	76	327172	
4	Ghorasal (Regent)	IPP	34*3.35	108	110	778863	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	20	478200	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	333	7482000	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	0	Reserve
8	Haripur Power CCGP 360MW	IPP	1*235+1*125	360	300	7094000	Frequency control
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	450	8574500	
10	Meghnaghat (IEL)	QRPP	12*8.9	100	0	0	Reserve
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	270	6267375	FGMO
12	Madanganj 102MW	QRPP	6*17	100	0	0	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	18002	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	0	Reserve
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	19	309816	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	79	2332000	FGMO
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Reserve
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
20	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	227	4240365	
21	Paglia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	16	108432	Low demand
23	Kalpottli 51 MW	IPP	7*7.9	51	24	219600	Low demand
24	Banco Energy 54MW	IPP	3*18	54	54	780120	
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	82	369120	Low demand
26	Northern 55 MW	IPP	3*19.3	55	18	387467	Low demand
27	Southern 55MW	IPP	3*19.3	55	21	459560	Low demand
28	Bosila 105MW	IPP	12*8.775+1*13.5	108	60	282240	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	90	56	1091460	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	25	669000	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	25	574000	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	50	523236	
33	Tongi GT	PDB	1* 105	105	40	919248	Gas shortage
34	Summit Gazipur -2	IPP	18*17.076	300	0	0	Reserve
35	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	15	57600	Low demand
Dhaka area Total				5798	3067	60122643	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	110	2600000	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1*210	180	120	2900000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	114707	
	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	138510	
41	Patenga 50MW	IPP	8*6.98	50	46	731520	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	78	1839960	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	205	4853773	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	145	2059808	
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	41	903840	Engine problem
47	Hathazari peaking	PDB	1*8.9	98	0	56576	Reserve
48	Dohazari Peaking	PDB	6*17	102	34	208870	
49	Juidah (Acom)	QRPP	8*13.45	100	10	302520	Low demand
	Juidah 100 MW Unit-3	IPP	0	100	100	1906560	
50	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	19	404336	
	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	30	666240	
51	Chattogram ECPV 108 MW	IPP	16*7	108	52	528960	Low demand
Chattogram area Total				1681	1015	20292180	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
53	Ashuganj CCGP 225 MW	APSCL	1*142+1*75	221	197	4811000	FGMO
54	Ashuganj CCGP(North)	APSCL	1*360	360	320	6920000	Frequency control
55	Ashuganj CCGP(South)	APSCL	1*360	360	320	6565500	Frequency control
56	Ashuganj Engines TSK	APSCL	14*3.968	45	40	814896	
57	Ashuganj (Precision) 55MW	RPP	15*4	55	5	129600	Gas shortage
58	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	185	1689454	
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	380492	Engine problem
	Midland 150MW	IPP	23*7.015	150	0	0	Reserve
61	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
63	Chandpur CCGP	PDB	1*106+1*57	163	50	1193070	
	Chandpur Desh 200MW	IPP	0	200	105	595200	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	19	300636	
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	75240	
**	Tripura	Imported power	0	160	162	2729280	
66	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	171100	Engine problem
67	Lakdhanvi 52 MW	IPP	6*8.92	52	16	38213	Low demand
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	400410	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1526	26734091	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	207	4623080	
71	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	202176	
72	Jamalpur 95MW	IPP	12*8.924	95	82	501120	Engine problem
73	Sarishabari (Solar)	IPP	1*3	3	0	15150	
74	Uniled Mymensingh PPL	IPP	200	200	40	177600	Low demand
	Uniled Jamalpur PPL	IPP	115 MW	115	107	127300	
Mymensingh Area Total				637	456	5646426	
75	Fenchugonj CCGP-1	PDB	2*32+1*33	70	56	1395000	
76	Fenchugonj CCGP-2	PDB	2*35+1*35	90	52	1562040	
77	Kushia 163 MW CCGP GT	IPP	1*109+1*54	163	163	2990209	
78	Shajibazar 330 MW	PDB	3*110	330	173	5324000	Under ST synch. process.
79	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	0	286600	Under maint.
80	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	46	574000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	219168	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	65	1185792	FGMO
83	Shajibazar 86MW	RPP	32*2.90	86	88	957120	
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	45	614880	
85	Sylhet GT 150 MW	PDB	1*142	142	107	2538000	FGMO
86	Sylhet GT 20 MW	PDB	1*20	20	19	100000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	32	342440	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	489888	Engine problem
89	Summit Bibiana- 2	IPP	1*222+1*119	341	290	6797900	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	100	1169400	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	80820	
Sylhet Area Total				1549	1273	26627257	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	836	17689454	
92	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khuina (KPCL-2)	QRPP	7*17	115	115	566400	
94	Faridpur Peaking	PDB	8*6.89	54	34	190560	
95	Khuina CCGP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	39	223872	Low demand
97	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	290250	
	Khuina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	4800	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	90	631220	Low demand
	Madhumati Power Plant	IPP	100 MW	0	108	2619792	on test.
Khuina Area Total				2209	1262	22216348	
100	Summit Barisal 110 MW	IPP	7*17.076	110	48	230400	Low demand
101	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	34	58957	
103	Bhola CCGP 194MW	PDB	2*63+1*68	194	120	2498000	ST under maintenance
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	1001178	
Barisal Area Total				462	299	4288535	
105	Baghabari GT 71MW	PDB	1*71	71	60	1410000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
106	Baghabari Peaking 50MW	PDB	6*8.9	52	50	259985	
107	Bera Peaking	PDB	9*8.29	71	40	164999	Low demand
108	Amnura 50MW	QRPP	7*7.79	50	35	348600	Engine problem
109	Katakhal (Northern)	QRPP	6*8.9	50	0	0	Reserve
110	Katakhal Peaking	PDB	6*8.7	50	0	0	Reserve
111	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	191	4478527	FGMO
112	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	195	4149609	FGMO
113	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	196	4208118	FGMO
	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282	282	0	2036545	under S/D
114	Santahar Peaking	PDB	6*8.7	50	28	168768	
115	Bogra (GBB)	RPP	6*4	22	22	449280	
116	Bogra (EPL)	RPP	5*3.3+5*2	10	17	309276	
117	Ullapara (Summit)	SIPP, REB	4*2.90	11	11	188984	
118	Rajlanka 52 MW	IPP	6*8.92	52	52	506880	