

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
					Generation	MW	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	36	699000	#1 Under maint.
	Ghorasal GT: Unit-3	PDB	1*210	170	134	3691800	Low demand
	Ghorasal GT: Unit-4	PDB	1*210	180	200	4100000	Low demand
	Ghorasal GT: Unit-5	PDB	1*210	190	0	0	Gas line maint.
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	250	6504545	Low demand
3	Ghorasal 70MW (MAX)	QRPP	2*40	78	30	718144	Gas shortage
4	Ghorasal (Regen)	IPP	34*3.35	108	105	836363	Gas shortage
5	Haripur GT: Unit-1, 2	SBU_PDB	2*32	40	0	0	under maintenance
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	340	8238080	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	0	191700	Reserve
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	252	6473000	Low demand
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	400	8865250	Low demand
10	Meghnaghat (IEL)	QRPP	12*8.9	100	0	528960	Reserve
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	290	6785920	FGMO
12	Madanganj 102MW	QRPP	6*17	100	0	239232	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	186345	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	107408	Reserve
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	0	267120	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Reserve
18	Siddhirgonj (Desh)	QRPP	96*1.2	100	0	0	Contract Expired
19	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	0	27840	Reserve
20	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	110	3429511	Low demand
21	Paglia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
22	Gagnagar (Orion)	IPP	12*8.924	102	0	324576	Reserve
23	Kaipottli 51 MW	IPP	7*7.9	51	42	161520	Low demand
24	Banco Energy 54MW	IPP	3*18	54	0	671040	Reserve
25	Kodda 149MW	BPDB-RPCL	9*17.06	149	16	929760	Low demand
26	Northern 55 MW	IPP	3*18.3	55	0	545270	Reserve
27	Southern 55MW	IPP	3*18.3	55	0	484030	Reserve
28	Bosila 105MW	IPP	12*8.775+1*13.5	100	51	902400	Engine problem
29	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	90	47	891980	Engine problem
30	Summit Maona	SIPP, REB	4*8.73	33	0	496500	Engine problem
31	Summit Rugganj	SIPP, REB	4*8.73	33	33	692500	Engine problem
32	Gazipur (RPCL)	IPP	6*8.9	52	25	705528	Low demand
33	Tongi GT	PDB	1* 105	105	40	983397	Gas shortage
34	Summit Gazipur-2	IPP	18*17.076	300	0	612220	Reserve
35	APR Energy, Keraniganj	IPP	256*1.4	300	0	0	Reserve
36	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
37	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
38	Summit Gazipur-1 150MW	IPP	149	149	0	757440	Reserve
	Gazipur 100 MW	RPCL	100 MW	0	0	93600	on test
	Dhaka area Total			5798	2401	61141979	
39	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2200000	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	8	240997	Low demand
	Teknaf Solartech 20MW Teknaf Solartech Energy		20	20	0	38475	
41	Patenga 50MW	IPP	8*6.98	50	47	900960	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	0	373140	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	217	5450571	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	90	3083888	FGMO
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	16	386880	Engine problem
47	Hathazari peaking	PDB	11*8.9	98	51	632480	Low demand
48	Dohazari Peaking	PDB	6*17	102	51	777203	Low demand
49	Juidah (Acom)	QRPP	8*13.45	100	10	646440	Low demand
	Juidah 100 MW Unit-3	IPP	8*2.90	22	14	1765440	
50	Barabkunda (Regeni)	SIPP, PDB	5*8.73+3*9.34	0	32	786240	Engine problem
*	Malancha, Ctg. EPZ (United)		16*7	108	52	960980	Engine problem
51	Chattogram ECPV 108 MW	IPP	16*7	108	52	960980	Engine problem
	Chattogram area Total			1681	788	18557018	
52	Ashuganj ST: Unit-3	APSCl	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit-4	APSCl	1*150	120	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	0	0	Gas shortage
53	Ashuganj CCPP 225 MW	APSCl	1*142+1*75	221	195	4898000	FGMO
54	Ashuganj CCPP(North)	APSCl	1*360	360	270	6790000	Frequency control
55	Ashuganj CCPP(South)	APSCl	1*360	360	270	6646000	Frequency control
56	Ashuganj Engines TSK	APSCl	14*3.968	45	33	702936	Gas shortage
57	Ashuganj (Precision) 55MW	RPP	15*4	55	52	515520	Gas shortage
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*116	195	81	1789818	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	760940	Gas shortage
	Midland 150MW	IPP	23*7.015	150	0	856440	Reserve
61	B.Barla (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
62	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
63	Chandpur CCPP	PDB	1*106+1*57	163	0	0	under maintenance
	Chandpur Desh 200MW	IPP	0	200	52	630000	Low demand
64	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	319932	Engine problem
65	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	221580	
**	Tripura	Imported power	0	160	122	2935680	Low demand
66	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	5	393300	Engine problem
67	Lakshani 52 MW	IPP	6*8.92	52	0	500630	Reserve
68	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	12	397170	
69	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
	Cumilla Area Total			2891	1173	28277946	
70	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	100	3165240	Gas shortage
71	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	326772	
72	Jamalpur 95MW	IPP	12*8.924	95	8	872640	Low demand
73	Sarishabari (Solar)	IPP	1*3	3	0	3650	
74	United Mymensingh PPL	IPP	200	200	7	1368000	Low demand
	United Jamalpur PPL	IPP	115 MW	115	50	1540800	Low demand
	Mymensingh Area Total			637	187	7277102	
75	Fenchuganj CCPP-1	PDB	2*32+1*33	70	53	1301000	
76	Fenchuganj CCPP-2	PDB	2*35+1*35	90	58	1346886	
77	Kushinara 163 MW CCPP GT	IPP	1*109+1*54	163	100	2753476	Frequency control
78	Shajibazar 330 MW	PDB	3*110	330	154	3856000	FGMO
79	Fenchuganj (Barakatalah) 51MW	RPP	19*2.90	51	53	861600	
80	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	50	865000	
81	Hobiganj 11MW	SIPP, REB	4*2.90	11	0	112464	
82	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	56	1234000	FGMO & GT-8 Under maint.
83	Shajibazar 86MW	RPP	32*2.90	86	10	1038720	Low demand
84	Shajibazar (EPL) 50MW	RPP	27*2.0	50	46	870480	
85	Sylhet GT 150 MW	PDB	1*142	142	78	1835370	Frequency control
86	Sylhet GT 20 MW	PDB	1*20	20	19	345000	
87	Sylhet (EPL) 50MW	RPP	27*2	50	42	795220	Engine problem
88	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	5	385464	Engine problem
89	Summit Bibiana- 2	IPP	1*222+1*119	341	290	6893000	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	0	0	On test
90	Sylhet (Desh) 10MW	RPP	6*1.95	10	0	87480	
	Sylhet Area Total			1549	1014	24427960	
91	Bheramara GT-1,2,3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	490	13135272	Low demand
92	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
93	Khulna (KPCL-2)	QRPP	7*17	115	16	496320	Engine problem
94	Faridpur Peaking	PDB	8*6.89	54	20	165120	Low demand
95	Khulna CCPP 225MW	NWP GCL	1*150+1*75	230	0	0	Reserve
96	Gopalganj Peaking	PDB	16*6.98	109	0	122752	Reserve
97	Bheramara 360 MW	NWP GCL	1*278+1*132	410	0	0	Under maint.
98	Noapara (KZA) 40MW	QRPP	5*8.5	40	16	228750	Low demand
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
99	Bangla Trak Noapara	IPP	70*1.4	100	0	173760	Reserve
	Labon Chora 105 MW	IPP	6*18.445	105	53	960960	Low demand
	Madhumati Power Plant	IPP	100 MW	0	54	1261800	Low demand
	Khulna Area Total			2209	649	16544534	
100	Summit Barisal 110 MW	IPP	7*17.076	110	0	552000	Low demand
101	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	0	Reserve
102	Bhola (Venture) 33MW	RPP	1*34.50	33	19	449404	Low demand
103	Bhola CCPP 194MW	PDB	2*63+1*68	194	152	4173820	
104	Bhola Aggreko 95MW	QRPP	96*1.10	95	27	1313292	FGMO
	Barisal Area Total			462	198	6488516	
105	Baghabari GT 71MW	PDB	1*71	71	65	1350000	
	Baghabari GT 100MW	PDB	1*100	100	0	1432000	Gas shortage
106	Baghabari Peaking 50MW	PDB	6*8.9	52	0	5768	Reserve
107	Bera Peaking	PDB	9*8.29	71	0	0	Reserve
108	Aminura 50MW	QRPP	7*7.79	50	12	175530	Engine problem
109	Katakhali (Northern)	QRPP	6*8.9	50	0	119090	Reserve
110	Katakhali Peaking	PDB	6*8.7	50	0	53505	Reserve
111	Siraigoni Unit-1 225MW	NWP GCL	1*150+1*75	210	195	4539700	FGMO
112	Siraigoni Unit-2 225MW	NWP GCL	1*150+1*75	220	196	4415600	FGMO
113	Siraigoni Unit-3 225MW	NWP GCL	1*141	220	201	4270264	FGMO
	Siraigoni Unit-4 414 MW (Gas)	SNWP GCL	1*282	282	250	7002450	
114	Santahar Peaking	PDB	6*8.7	50	0	98701	Reserve