

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1582000	
	Ghorasal GT: Unit-3	PDB	1*210	170	134	3170300	
	Ghorasal GT: Unit-4	PDB	1*210	180	0	1547000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	330	7245364	Frequency control
3	Ghorasal 25MW (MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal (Regen)	IPP	3*3.35	108	0	0	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	335	8170500	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	110	864800	
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	351	7705000	
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	350	9292125	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	100	1113600	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	266	6640058	FGMO
12	Madanganj 102MW	QRPP	6*17	100	100	582672	
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	826067	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	90	616149	Engine problem
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	289152	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	98	925440	
19	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	0	0	Gas shortage
0	Paglia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	100	1646496	
21	Kalpoti 51 MW	IPP	7*7.9	51	48	1090512	
22	Banco Energy 54MW	IPP	3*18	54	54	957240	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	146	2341920	
24	Northern 55 MW	IPP	3*19.3	55	56	1163178	
25	Southern 55MW	IPP	3*19.3	55	55	1137600	
26	Bosila 105MW	IPP	12*8.775+1*3.5	108	54	1137600	Engine problem
27	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	50	1118220	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	0	673500	Engine problem
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	812200	
30	Gazipur (RPCL)	IPP	6*8.9	52	10	1003800	Engine problem
31	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	300	1974654	
33	APR Energy , Keraniganj	IPP	256*1.4	300	85	206121	Low demand
34	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	50	130675	Low demand
35	Aggreko Auraha 100MW	IPP	0.85*23+0.95*91	100	51	129353	Low demand
36	Summit Gazipur-1 150MW	IPP	149	149	149	3058560	
0	Gazipur 100 MW	RPCL	100 MW	0	0	0	on test
Dhaka area Total				5698	3653	69164256	
37	Chattoagram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittagong ST-2 (Raozan)	PDB	1*210	180	150	3700000	Gas shortage
38	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	503771	
39	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	112590	
40	Patenga 50MW	IPP	8*6.98	50	40	1090080	Engine problem
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	38	833340	Low water level
42	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
43	Sikalbaha 225MW	PDB	1*150+1*175	225	230	5452015	FGMO
44	Sikalbaha Peaking GT	PDB	1*150	150	145	3310036	FGMO
45	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	16	454080	Engine problem
46	Hathazari peaking	PDB	11*8.9	98	74	974024	
47	Dohazari Peaking	PDB	6*17	102	85	983535	
48	Juidah (Acom)	QRPP	8*13.45	100	88	1574520	Engine problem
49	Juidah 100 MW Unit-3	IPP	0	100	100	2342400	
50	Barabkunda (Regeni)	SIPP, PDB	8*2.90	22	15	368440	Engine problem
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	39	513120	
51	Chattoagram ECPV 108 MW	IPP	16*7	108	98	2089920	
Chattoagram area Total				1681	1141	24302071	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	120	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
53	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	186	4873000	FGMO
54	Ashuganj CCPP(North)	APSCL	1*360	360	200	5138900	ST Under Maint.
55	Ashuganj CCPP(South)	APSCL	1*360	360	270	7456000	Frequency control
56	Ashuganj Engines TSK	APSCL	14*3.968	45	36	833328	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	55	1318560	
58	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	167	3897454	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	905110	Engine problem
61	Midland 150MW	IPP	23*7.015	150	127	2187927	Engine problem
62	B.Barla (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
63	Daudkandi Peaking 52MW	PDB	6*8.92	52	42	155056	
64	Chandpur CCPP	PDB	1*106+1*57	163	100	2330190	
65	Chandpur Desh 200MW	IPP	0	200	197	3095520	
66	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	481500	
67	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	260280	Engine problem
**	Tripura	Imported power	0	166	166	3649920	
68	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	728200	Engine problem
69	Lakshani 52 MW	IPP	6*8.92	52	49	991790	
70	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	501100	Engine problem
71	Daudkandi bangla trak	IPP	154*1.4	200	80	241920	Low demand
Cumilla Area Total				2891	1800	38965755	
72	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	101	3080920	Gas shortage
73	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	430741	
74	Jamalpur 95MW	IPP	12*8.924	95	85	1887360	Engine problem
75	Sarishabari (Solar)	IPP	1*3	3	0	13300	
76	United Mymensingh PPL	IPP	200	200	190	2844000	
77	United Jamalpur PPL	IPP	115 MW	115	105	2480400	
Mymensingh Area Total				637	501	10736721	
78	Fenchuganj CCPP-1	PDB	2*32+1*33	70	56	1222000	
79	Fenchuganj CCPP-2	PDB	2*35+1*35	90	48	1145400	
80	Kushkhura 163 MW CCPP GT	IPP	1*109+1*54	163	163	3367352	
81	Shajibazar 330 MW	PDB	3*110	330	311	7138000	FGMO
82	Fenchuganj (Barakatullah) 51MW	RPP	19*2.90	51	0	97800	Engine problem
83	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	50	957000	
84	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	113904	
85	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	63	1437792	FGMO
86	Shajibazar 86MW	RPP	32*2.90	86	79	1731840	
87	Shajibazar (EPL) 50MW	RPP	27*2.0	50	46	1025280	
88	Sylhet GT 150 MW	PDB	1*142	142	114	2863290	
89	Sylhet GT 20 MW	PDB	1*20	20	18	251000	
90	Sylhet (EPL) 50MW	RPP	27*2	50	41	824600	Engine problem
91	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	16	359016	Engine problem
92	Summit Bibiana- 2	IPP	1*222+1*119	341	270	6780500	FGMO
	Bibiyan-3 285 MW	PDB	285 MW	0	250	6816100	On test
93	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	171000	
Sylhet Area Total				1549	1546	36291874	
94	Bheramara GT-1,2,3	PDB	3*20	46	48	257300	
**	Bheramara (HVDC)	Imported power	2*500	1000	942	22611636	
	Khuina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
95	Khuina (KPCL-2)	QRPP	7*17	115	115	1760640	
96	Faridpur Peaking	PDB	8*6.89	54	32	316320	
97	Khuina CCPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
98	Gopalganj Peaking	PDB	16*6.98	109	64	603648	
99	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
100	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	662625	
0	Khuina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
101	Bangla Trak Noapara	IPP	70*1.4	100	97	1003200	
102	Labon Chora 105 MW	IPP	6*18.445	105	105	1853760	
103	Madhumati Power Plant	IPP	100 MW	105	106	2531800	
Khuina Area Total				2314	1549	37600929	
104	Summit Barisal 110 MW	IPP	7*17.076	110	110	1205760	
105	Barisal GT: Unit- 1, 2	PDB	2*20	30	12	59022	Low demand
106	Bhola (Venture) 33MW	RPP	1*34.50	33	45	760038	
107	Bhola CCPP 194MW	PDB	2*63+1*68	194	175	3754021	
108	Bhola Aggreko 95MW	QRPP	96*1.10	95	61	1908951	FGMO
Barisal Area Total				462	403	7687792	
109	Baghabari GT 71MW	PDB	1*71	71	0	797000	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	0	0	Gas shortage
110	Baghabari Peaking 50MW	PDB	6*8.9	52	50	686760	
111	Bera Peaking	PDB	9*8.29	71	34	398405	
112	Aminura 50MW	QRPP	7*7.79	50	50	620490	
113	Katakhal (Northern)	QRPP	6*8.9	50	50	596511	
114	Katakhal Peaking	PDB	6*8.7	50	47	384836	
115	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	159	4522155	FGMO
116	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	128	4274391	FGMO
117	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	171	4832045	FGMO
118	Sirajgonj Unit-4 414 MW(Gas)	NWPGCL	1*282+1*132	414	250	7353720	Frequency control
119	Santahar Peaking	PDB	6*8.7	50	34	403629	
120	Bogra (GBB)	RPP	6*4	22	22	485280	
121	Bogra (EPL)	RPP	5*3.3+5*2	10	15	366876	
122	Ullapara (Summit)	SIPP, REB	4*2.90				