

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1610000	
	Ghorasal GT: Unit-3	PDB	1*210	170	134	3337900	Gas shortage
	Ghorasal ST: Unit-4	PDB	1*210	180	150	3544000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	350	6612391	Frequency control
3	Ghorasal 75MW (MAX)	QRPP	2*40	78	0	139552	Gas shortage
4	Ghorasal (Regen)	IPP	34*3.35	108	50	293772	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	40	311800	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	332	8143870	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	55	285900	Low demand
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	347	7370000	
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	400	8815000	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	55	707520	Low demand
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	260	6535011	FGMO
12	Madanganj 102MW	QRPP	6*17	100	0	158880	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	15	379968	Low demand
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	0	181215	Reserve
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	257976	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	160	1485000	Gas shortage
18	Siddhirgonj (Dutch Bangla)	QRPP	96*1.2	0	0	0	Contract Expired
19	Siddhirgonj CAPP-335 MW	QRPP	12*8.9	100	0	63360	Reserve
20	Pagla (DPA)	QRPP	100*0.5	0	0	0	Gas shortage
21	Gagnagar (Orion)	IPP	12*8.924	102	74	992160	Contract Expired
22	Kalpottli 51 MW	IPP	7*7.9	51	48	1077600	Low demand
23	Banco Energy 54MW	IPP	3*18	54	54	1029240	
24	Kodda 149MW	BPDB-RPCL	9*17.06	149	149	1981920	
25	Northern 55 MW	IPP	3*19.3	55	37	765585	
26	Southern 55MW	IPP	3*19.3	55	55	764000	
27	Bosila 105MW	IPP	12*8.775+1*13.5	108	56	1047360	Engine problem
28	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	90	49	1013820	Engine problem
29	Summit Maona	SIPP, REB	4*8.73	33	33	771600	
30	Summit Rugganj	SIPP, REB	4*8.73	33	33	819600	
31	Gazipur (RPCL)	IPP	6*8.9	52	48	973968	Engine problem
32	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
33	Summit Gazipur -2	IPP	18*17.076	300	75	1166730	Low demand
34	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
35	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
36	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
37	Summit Gazipur-1 150MW	IPP	149	149	135	2338560	Engine problem
38	Gazipur 100 MW	RPCL	100 MW	0	0	0	on test
Dhaka area Total				5698	3287	64995258	
37	Chattogram ST-1 (Raozan)	PDB	1*210	180	0	0	Gas shortage
	Chittgong ST-2 (Raozan)	PDB	1*210	180	150	3700000	Gas shortage
38	Raazan 25 MW (RPCL)	IPP	3*8.9	25	25	481325	
39	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	118800	
40	Patenga 50MW	IPP	8*6.98	50	47	1056960	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	34	829500	Low water level
42	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
43	Sikalbaha 225MW	PDB	1*150+1*175	225	230	5412757	FGMO
44	Sikalbaha Peaking GT	PDB	1*150	150	130	2750234	FGMO
45	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	24	514560	Engine problem
46	Hathazari peaking	PDB	11*8.9	98	80	684423	
47	Dohazari Peaking	PDB	6*17	102	70	792736	
48	Juldah (Acom)	QRPP	8*13.45	100	96	1055760	Engine problem
49	Juldah 100 MW Unit-3	IPP	8*2.90	100	90	2181120	
50	Barakunda (Regeni)	SIPP, PDB	8*2.90	22	17	393984	Engine problem
51	Malancha, Ctg. EPZ (Uniled)	IPP	5*8.73+3*9.34	0	35	648480	
52	Chattogram ECPV 108 MW	IPP	16*7	108	97	971520	
Chattogram area Total				1691	1125	21592159	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	120	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
53	Ashuganj CAPP 225 MW	APSCL	1*142+1*75	221	185	4594000	FGMO
54	Ashuganj CAPP(North)	APSCL	1*360	360	250	3924200	ST Under Maint.
55	Ashuganj CAPP(South)	APSCL	1*360	360	300	7437000	Frequency control
56	Ashuganj Engines TSK	APSCL	14*3.968	45	36	807912	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	56	1251360	
58	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	117	3663272	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	878510	Engine problem
61	Midland 150MW	IPP	23*7.015	150	121	2199640	Engine problem
62	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
63	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	61904	Reserve
64	Chandpur CAPP	PDB	1*106+1*57	163	100	2316600	
65	Chandpur Desh 200MW	IPP	0	200	197	2749920	
66	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	506628	
67	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	259920	
**	Tripura	Imported power	0	160	186	3658560	
68	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	0	133400	Engine problem
69	Lakdhanvi 52 MW	IPP	6*8.92	52	50	1197638	
70	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	482720	Engine problem
71	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1691	36243184	
72	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	146	3337560	Gas shortage
73	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	442440	
74	Jamalpur 95MW	IPP	12*8.924	95	94	1652160	
75	Sarishabari (Solar)	IPP	1*3	3	0	13100	
76	Uniled Mymensingh PPL	IPP	200	200	150	2191200	Due to bad weather
77	Uniled Jamalpur PPL	IPP	115 MW	115	106	2514000	Engine problem
Mymensingh Area Total				637	516	10150460	
78	Fenchuganj CAPP-1	PDB	2*32+1*33	70	54	1315000	
79	Fenchuganj CAPP-2	PDB	2*35+1*35	90	48	1152120	
80	Kushinara 163 MW CAPP GT	IPP	1*109+1*54	163	130	3170110	Low demand
81	Shajibazar 330 MW	PDB	3*110	330	309	7134000	FGMO
82	Fenchuganj (Barakatalah) 51MW	RPP	19*2.90	51	46	170400	Engine problem
83	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	50	1131000	
84	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	211152	
85	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	63	1352928	FGMO
86	Shajibazar 86MW	RPP	32*2.90	86	82	1440640	
87	Shajibazar (EPL) 50MW	RPP	27*2.0	50	46	960480	
88	Sylhet GT 150 MW	PDB	1*142	142	109	2498960	
89	Sylhet GT 20 MW	PDB	1*20	20	18	413000	
90	Sylhet (EPL) 50MW	RPP	27*2	50	42	900160	Engine problem
91	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	467416	
92	Summit Bibiana- 2	IPP	1*222+1*119	341	270	6628200	FGMO
93	Bibiyana-3 285 MW	PDB	285 MW	0	300	4255100	On test
93	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	245880	
Sylhet Area Total				1549	1612	33446546	
94	Bheramara GT-1,2,3	PDB	3*20	46	44	205000	
**	Bheramara (HVDC)	Imported power	2*500	1000	943	22629818	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
95	Khulna (KPCL-2)	QRPP	7*17	115	115	1825920	
96	Faridpur Peaking	PDB	8*6.89	54	33	319200	
97	Khulna CAPP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
98	Gopalganj Peaking	PDB	16*6.98	109	53	519040	
99	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
100	Noapara (KZA) 40MW	QRPP	5*8.5	40	33	578625	
0	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
101	Bangla Trak Noapara	IPP	70*1.4	100	97	972480	
102	Labon Chora 105 MW	IPP	6*18.445	105	105	2016960	
103	Madhumati Power Plant	IPP	100 MW	105	104	2241936	
Khulna Area Total				2314	1527	37308979	
104	Summit Barsal 110 MW	IPP	7*17.076	110	110	1439040	
105	Barsal GT: Unit-1, 2	PDB	2*20	30	0	23050	Low demand
106	Bhola (Venture) 33MW	RPP	1*34.50	33	44	788271	
107	Bhola CAPP 194MW	PDB	2*63+1*68	194	175	4276258	
108	Bhola Aggreko 95MW	QRPP	96*1.10	95	96	1281418	FGMO
Barsal Area Total				462	425	7808037	
109	Baghabari GT 71MW	PDB	1*71	71	55	316000	Gas shortage
	Baghabari GT 100MW	PDB	1*100	100	75	839000	Gas shortage
110	Baghabari Peaking 50MW	PDB	6*8.9	52	50	653216	
111	Bera Peaking	PDB	9*8.29	71	39	271035	
112	Aminura 50MW	QRPP	7*7.79	50	50	692640	
113	Kalakhali (Northern)	QRPP	6*8.9	50	50	577368	
114	Kalakhali Peaking	PDB	6*8.7	50	0	127846	Reserve
115	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	183	4614482	FGMO
116	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	184	4186136	FGMO
117	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	193	4640936	FGMO
118	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282+1*132	414	409	7976820	Frequency control
119	Santahar Peaking	PDB	6*8.7	50	23	578997	
120	Bogra (GBB)	RPP	6*4	22	22	505680	
121	Bogra (EPL)	RPP	5*3.3+5*2	10	15	356688	
122	Ullap						