

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	74	1650000	
	Ghorasal GT: Unit-3	PDB	1*210	170	0	1715400	Tripped at 15:45.
	Ghorasal GT: Unit-4	PDB	1*210	180	140	2197000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	340	6571318	Frequency control
3	Ghorasal 75MW (MAX)	QRPP	2*40	78	50	793408	Gas shortage
4	Ghorasal (Regen)	IPP	34*3.35	108	107	1342363	Gas shortage
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	326	8213510	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	55	558200	Low demand
8	Haripur Power CCGP 360MW	IPP	1*235+1*125	360	353	7856000	
9	Meghnaghat CCGP 450MW	IPP	2*150+1*150	450	380	8646375	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	60	626880	Low demand
11	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	280	6897658	FGMO
12	Madanganj 102MW	QRPP	6*17	100	48	303072	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	464403	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	50	271751	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	19	403668	Engine problem
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1 & 2	EGCB	2*105	210	150	2421000	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	24	342720	Low demand
19	Siddhirgonj CCGP-335 MW	EGCB	1*217	217	0	0	Gas shortage
0	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	64	1136448	Low demand
21	Katpotti 51 MW	IPP	7*7.9	51	48	1013808	Engine problem
22	Banco Energy 54MW	IPP	3*18	54	35	733320	Engine problem
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	149	1477920	
24	Northern 55 MW	IPP	3*19.3	55	56	1009257	
25	Southern 55MW	IPP	3*19.3	55	55	968000	
26	Bosila 105MW	IPP	12*8.775+1*13.5	108	61	937320	Engine problem
27	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	90	53	1167720	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	33	735600	
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	788900	
30	Gazipur (RPCL)	IPP	6*8.9	52	48	1045008	
31	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	195	1984690	Low demand
33	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
34	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	135	2809440	
	Gazipur 100 MW	RPCL	100 MW	0	0	70000	on test
<b>Dhaka area Total</b>				<b>5698</b>	<b>3476</b>	<b>67152757</b>	
37	Chattogram ST-1 (Raoozan)	PDB	1*210	180	0	0	Gas shortage
	Chittgong ST-2 (Raoozan)	PDB	1*210	180	180	3800000	Gas shortage
38	Raoozan 25 MW (RPCL)	IPP	3*8.9	25	25	482041	
39	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	133245	
40	Patenga 50MW	IPP	8*6.98	50	46	1039680	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	38	802200	Low water level
42	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
43	Sikalbaha 225MW	PDB	1*150+1*175	225	229	5380392	FGMO
44	Sikalbaha Peaking GT	PDB	1*150	150	130	3098348	FGMO
45	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	32	765600	Engine problem
46	Hathazari peaking	PDB	11*8.9	98	67	452856	
47	Dohazari Peaking	PDB	6*17	102	85	686455	
48	Juidah (Acom)	QRPP	8*13.45	100	100	1337160	
49	Juidah 100 MW Unit-3	IPP	8*2.90	22	13	2386560	
50	Barabkunda (Regeni)	SIPP, PDB	8*2.90	22	13	269520	Engine problem
*	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	30	528960	
51	Chattogram ECPV 108 MW	IPP	16*7	108	103	1976640	
<b>Chattogram area Total</b>				<b>1681</b>	<b>1178</b>	<b>23139657</b>	
52	Ashuganj ST: Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj ST: Unit- 4	APSCL	1*150	120	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
53	Ashuganj CCGP 225 MW	APSCL	1*142+1*75	221	182	4807000	FGMO
54	Ashuganj CCGP(North)	APSCL	1*360	360	255	5324300	ST Under Maint.
55	Ashuganj CCGP(South)	APSCL	1*360	360	300	6831000	Frequency control
56	Ashuganj Engines TSK	APSCL	14*3.968	45	37	800424	Engine problem
57	Ashuganj (Precision) 55MW	RPP	15*4	55	57	689280	
58	Ashuganj (Uniled) 53MW	QRPP	14*4	53	5	120000	Gas shortage
59	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	78	2274909	Gas shortage
60	Ashuganj (Midland) 51MW	IPP	6*9.34	51	45	913782	Engine problem
61	Midland 150MW	IPP	23*7.015	150	150	1117381	
62	B.Barla (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
63	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	65056	Reserve
64	Chandpur CCGP	PDB	1*106+1*57	163	100	2138980	
65	Chandpur Desh 200MW	IPP	0	200	200	2264640	
66	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	21	415944	
67	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	238320	
**	Tripura	Imported power	0	160	172	3428160	
68	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	33	545800	
69	Lakdhanvi 52 MW	IPP	6*8.92	52	52	693413	
70	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	12	472620	
71	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1710</b>	<b>32950009</b>	
72	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	150	3484840	Machine problem.
73	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	17	408096	
74	Jamalpur 95MW	IPP	12*8.924	95	95	1157760	
75	Sarishabari (Solar)	IPP	1*3	3	0	16050	
76	Uniled Mymensingh PPL	IPP	200	200	200	1375200	
77	Uniled Jamalpur PPL	IPP	115 MW	115	90	1434000	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>552</b>	<b>7875946</b>	
78	Fenchuganj CCGP-1	PDB	2*32+1*33	70	60	1384000	
79	Fenchuganj CCGP-2	PDB	2*35+1*35	90	50	461620	
80	Kushihara 163 MW CCGP GT	IPP	11*109+1*54	163	130	1645274	Frequency control
81	Shajibazar 330 MW	PDB	3*110	330	310	7283000	FGMO
82	Fenchuganj (Barakatlullah) 51MW	RPP	19*2.90	51	53	836400	
83	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	50	872000	
84	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	225984	
85	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	64	1397472	FGMO
86	Shajibazar 86MW	RPP	32*2.90	86	82	1201920	
87	Shajibazar (EPL) 50MW	RPP	27*2.0	50	46	925560	Engine problem
88	Sylhet GT 150 MW	PDB	1*142	142	108	2432620	Frequency control
89	Sylhet GT 20 MW	PDB	1*20	20	19	375000	
90	Sylhet (EPL) 50MW	RPP	27*2	50	44	890800	Engine problem
91	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	551880	
92	Summit Bibiana- 2	IPP	1*222+1*119	341	260	6653500	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	85	2049800	On test
93	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	204660	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1406</b>	<b>29391390</b>	
94	Bheramara GT-1,2,3	PDB	3*20	46	44	275400	
**	Bheramara (HVDC )	Imported power	2*500	1000	939	22466909	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
95	Khulna (KPCL-2)	QRPP	7*17	115	115	956160	
96	Faridpur Peaking	PDB	8*6.89	54	33	209280	
97	Khulna CCGP 225MW	NWPGCL	1*150+1*75	230	0	0	Reserve
98	Gopalganj Peaking	PDB	16*6.98	109	77	415488	
99	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
100	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	429375	
0	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
101	Bangla Trak Noapara	IPP	70*1.4	100	99	508800	
102	Labon Chora 105 MW	IPP	6*18.445	105	70	1544160	Engine problem
103	Madhumati Power Plant	IPP	100 MW	105	108	1945873	
<b>Khulna Area Total</b>				<b>2314</b>	<b>1525</b>	<b>28751445</b>	
104	Summit Barsal 110 MW	IPP	7*17.076	110	110	959040	
105	Barsal GT: Unit-1, 2	PDB	2*20	30	20	103215	
106	Bhola (Venture) 33MW	RPP	1*34.50	33	37	465134	
107	Bhola CCGP 194MW	PDB	2*63+1*68	194	176	4310621	FGMO
108	Bhola Aggreko 95MW	QRPP	96*1.10	95	95	2002590	
<b>Barsal Area Total</b>				<b>462</b>	<b>439</b>	<b>7840600</b>	
109	Baghabari GT 71MW	PDB	1*71	71	50	1340000	
	Baghabari GT 100MW	PDB	1*100	100	70	1978000	
110	Baghabari Peaking 50MW	PDB	6*8.9	52	43	163720	
111	Bera Peaking	PDB	9*8.29	71	0	556505	Reserve
112	Amnura 50MW	QRPP	7*7.79	50	50	493990	
113	Katakhal (Northern)	QRPP	6*8.9	50	24	139098	Low demand
114	Katakhal Peaking	PDB	6*8.7	50	45	193308	
115	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	180	4473945	FGMO
116	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	164	4212882	FGMO
117	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	167	4780000	FGMO
118	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282+1*132	414	300	7989360	Frequency control
119	Santahar Peaking	PDB	6*8.7	50	41	280469	
120	Bogra (GBB)	RPP	6*4	22	22	504480	
121	Bogra (EPL)	RPP	5*3.3+5*2	10	8	336052	