

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	800000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal GT: Unit-4	PDB	1*210	180	200	4856000	
	Ghorasal ST: Unit-5	PDB	1*240	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	350	8261900	
3	Ghorasal 78MW (MAX)	QRPP	2*40	76	45	1506848	Low demand
4	Ghorasal (Regent)	IPP	3*43.35	108	104	2379454	
5	Haripur GT: Unit-1, 2	SRU, PDB	2*32	40	20	495000	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	328	8311810	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	110	771400	
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	303	7630000	Frequency control
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	225	5074500	GT-1 Under maint
10	Meghnaghat (IEL)	QRPP	12*8.9	100	94	1028160	
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	270	6758487	FGMO
12	Madanganj 102MW	QRPP	6*17	100	38	237240	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	531815	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	40	287747	Low demand
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	22	465984	
16	Siddhirganj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirganj GT Unit-1& 2	EGCB	2*105	210	140	4106000	Frequency control
18	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
19	Siddhirganj (Dutch Bangla)	QRPP	12*8.9	100	50	208320	Low demand
19	Siddhirganj CAPP-335 MW	EGCB	1*217	217	170	4688657	Frequency control
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	101	1537200	
21	Katpotti 51 MW	IPP	7*7.9	51	49	323904	
22	Banco Energy 54MW	IPP	3*18	54	54	1251360	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	145	2580960	
24	Northern 55 MW	IPP	3*19.3	55	55	1179295	
25	Southern 55MW	IPP	3*19.3	55	55	1156990	
26	Bosila 108MW	IPP	12*8.775+1*13.5	108	99	881280	Engine problem
27	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	49	1121640	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	25	595200	Engine problem
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	817500	
30	Gazipur (RPCL)	IPP	6*8.9	52	49	1084308	
31	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	95	592145	Low demand
33	APR Energy , Keraniganj	IPP	256*1.4	300	0	130251	Reserve
34	Bramhangon 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	53617	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	149	2656800	
37	Gazipur 100 MW	RPCL	100 MW	105	89	2132400	Engine problem
Dhaka area Total				5803	3586	76494172	
38	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2300000	Gas shortage
39	Chittagong ST-2 (Raozan)	PDB	1*210	180	100	2500000	Gas shortage
40	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	462414	
41	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	73170	
42	Patenga 50MW	IPP	8*6.98	50	47	988880	
43	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	36	831480	Low water level
44	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
45	Sikalbaha 225MW	PDB	1*150+1*175	225	205	5079977	FGMO
46	Sikalbaha Peaking GT	PDB	1*150	150	130	3103034	FGMO
47	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	25	447840	Engine problem
48	Baraka Sikabaha PL	IPP	105 MW	105	105	2508246	
49	Hathazari peaking	PDB	11*8.9	98	74	455000	
50	Dohazari Peaking	PDB	6*17	102	68	421831	
51	Julidai (Acom)	QRPP	8*13.45	100	100	1130640	
52	Julidai 100 MW Unit-3	IPP	0	100	100	2418240	
53	Barakunda (Regent)	SIPP, PDB	8*2.90	22	21	462528	
54	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	37	504000	
55	Chattogram ECPV 108 MW	IPP	16*7	108	104	2111040	
56	Kapali Solar	PDB	7.4 MW	0	0	26040	
57	Anwara United	United Group	300 MW	0	50	245890	on test
Chattogram area Total				1786	1327	26080250	
58	Ashuganj ST: Unit- 3	APSCCL	1*150	135	80	2441842	Gas shortage
59	Ashuganj ST: Unit- 4	APSCCL	1*150	129	0	0	Gas shortage
60	Ashuganj ST: Unit- 5	APSCCL	1*150	134	0	0	Gas shortage
61	Ashuganj CAPP 225 MW	APSCCL	1*142+1*75	221	215	5032000	FGMO
62	Ashuganj CAPP(North)	APSCCL	1*360	360	300	8026000	Frequency control
63	Ashuganj CAPP(South)	APSCCL	1*360	360	325	6569000	Frequency control
64	Ashuganj Engines TSK	APSCCL	14*3.968	45	0	0	Gas Line maint.
65	Ashuganj (Precision) 55MW	RPP	15*4	55	53	1274880	
66	Ashuganj (United) 53MW	QRPP	14*4	53	0	0	Engine problem
67	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	786181	Gas shortage
68	Ashuganj (Midland) 51MW	IPP	6*9.34	51	40	776688	Engine problem
69	Midland 150MW	IPP	23*7.015	150	12	1102320	Low demand
70	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
71	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	56800	Reserve
72	Chandpur CAPP	PDB	1*106+1*57	163	95	2296020	
73	Chandpur Desh 200MW	IPP	200	200	200	4359360	
74	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	505980	
75	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	148500	Engine problem
76	Tripura	Imported power	0	160	184	3999360	
77	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	16	405200	Engine problem
78	Lakshmi 52 MW	IPP	6*8.92	52	52	1016006	
79	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	19	486500	Engine problem
80	Daudkandi bangla trak	IPP	15*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1629	39282637	
81	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	146	3372720	GT-1 Under maint
82	Fangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	20	412308	
83	Jamalpur 95MW	IPP	12*8.924	95	96	2095520	
84	Sarishabari (Solar)	IPP	1*3	3	0	8250	
85	United Mymensingh PPL	IPP	200	200	180	2988800	High voltage
86	United Jamalpur PPL	IPP	115 MW	115	95	2096400	Engine problem
Mymensingh Area Total				637	537	10957998	
87	Fenchugonj CAPP-1	PDB	2*32+1*33	70	56	1318000	
88	Fenchugonj CAPP-2	PDB	2*35+1*35	90	57	1368120	
89	Kushlara 163 MW CAPP GT	IPP	1*109+1*54	163	130	3487197	Frequency control
90	Shajibazar 330 MW	PDB	3*110	330	170	3872000	FGMO
91	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	1149000	
92	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	49	1143936	
93	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	260976	
94	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	62	1414752	FGMO
95	Shajibazar 86MW	RPP	32*2.90	86	81	1740480	
96	Shajibazar (EPL) 50MW	RPP	27*2.0	50	10	891000	Engine problem
97	Sylhet GT 150 MW	PDB	1*142	142	103	2750060	
98	Sylhet GT 20 MW	PDB	1*20	20	18	429000	
99	Sylhet (EPL) 50MW	RPP	27*2	50	47	1024880	
100	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	562800	
101	Summit Bibiana- 2	IPP	1*222+1*119	341	0	0	Gas field shut down
102	Bibiyana-3 285 MW	PDB	285 MW	0	250	6033000	On test
103	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	238320	
Sylhet Area Total				1549	1131	27683521	
104	Bheramara GT-1,2,3	PDB	3*20	46	32	128200	Low demand
105	Bheramara (HVDC)	Imported power	2*500	1000	931	16423273	
106	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	15	0	Contract Expired
107	Faridpur Peaking	QRPP	7*17	115	115	1848960	
108	Khulna CAPP 225MW	PDB	8*6.89	54	37	375360	
109	Sopelganj Peaking	NWPGCL	1*150+1*75	230	70	290450	Low demand
110	Bheramara 360 MW	PDB	18*6.98	109	57	453632	
111	Noapara (KZA) 40MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
112	Khulna (Aggreco) 55MW	QRPP	5*8.5	40	32	564750	Engine problem
113	Bangla Trak Noapara	QRPP	71*0.85	0	0	0	Contract Expired
114	Labon Chora 105 MW	IPP	70*1.4	100	100	508800	
115	Madhumati Power Plant	IPP	6*18.445	105	105	2231040	
116	Madhumati Power Plant	IPP	100 MW	105	87	2075184	Engine problem
Khulna Area Total				2314	1566	24899649	
117	Summit Barisal 110 MW	IPP	7*17.076	110	110	1502400	
118	Barisal GT: Unit- 1, 2	PDB	2*20	30	0	6705	Reserve
119	Bhola (Venture) 33MW	RPP	1*34.50	33	39	720291	
120	Bhola CAPP 194MW	PDB	2*63+1*68	194	144	3526651	FGMO
121	Bhola Aggreko 95MW	QRPP	96*1.10	95	97	2230031	
Barisal Area Total				462	390	7986078	
122	Baghabari GT 71MW	PDB	1*71	71	50	1280000	
123	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
124	Baghabari Peaking 50MW	PDB	6*8.9	52	43	592050	
125	Bera Peaking	PDB	9*8.29	71	32	250670	
126	Amnura 50MW	QRPP	7*7.9	50	40	809360	Engine problem
127	Katakhal (Northern)	QRPP	6*8.9	50	43	197229	Engine problem
128	Katakhal Peaking	PDB	6*8.7	50	44	225754	
129	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	184	4810309	FGMO
130	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	182	4229909	FGMO
131	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	191	4564836	FGMO
132	S						