POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

OF-LDC-08 Page -

Reporting Date : 17-.lun-19 Till now the maximum generation is : -29-May-19 12893 MW 21:00 Hrs on The Summary of Yesterday's Today's Actual Min Gen. & Probable Gen. & Demand 16-Jun-19 Generation & Demand Day Peak Generation 9487.0 MW 8670 MW 12:00 Min. Gen. at 8:00 Evening Peak Generation Available Max Generation 12094 0 MW 21.00 15124 MW 12600 MW 12094 0 MW Max Demand (Evening) : E.P. Demand (at gen end): 21.00 12096.0 MW 2524 MW Maximum Generation 22:00 Reserve(Generation end) Total Gen. (MKWH) Load Shed 0 MW 243.5 Load Factor 83.88%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum -490 MW 5:00 Energy MKWHR - MKWHR. Import from West grid to East grid :- Maximum MW Energy at

17-Jun-19 Water Level of Kaptai Lake at 6:00 A M on Actual: Ft.(MSL) 80.22 Ft.(MSL) 74.54 Rule curve :

Gas Consumed : Total = 1348.08 MMCFD. Oil Consumed (PDB):

HSD Liter

FO Liter

Cost of the Consumed Fuel (PDB+Pvt): Gas : Tk105.810.743

Coal Tk28,033,445 : Tk384,566,910 Total: Tk518,411,098

Load Shedding & Other Information

| Area | Yesterday | | Today | | |
|-----------------|-----------|------|----------------------------|------------------------------|-----------------------|
| | | | Estimated Demand (S/S end) | Estimated Shedding (S/S end) | Rates of Shedding |
| | MW | | MW | MW | (On Estimated Demand) |
| Dhaka | 0 | 0:00 | 4497 | 0 | 0% |
| Chittagong Area | 0 | 0:00 | 1533 | 0 | 0% |
| Khulna Area | 0 | 0:00 | 1374 | 0 | 0% |
| Rajshahi Area | 0 | 0:00 | 1242 | 0 | 0% |
| Comilla Area | 0 | 0:00 | 1122 | 0 | 0% |
| Mymensingh Area | 0 | 0:00 | 906 | 0 | 0% |
| Sylhet Area | 0 | 0:00 | 501 | 0 | 0% |
| Barisal Area | 0 | 0:00 | 233 | 0 | 0% |
| Rangpur Area | 0 | 0:00 | 698 | 0 | 0% |
| Total | 0 | | 12107 | 0 | |

Information of the Generating Units under shut down.

Planned Shut- Down Forced Shut-Down

1) Barapukuria ST: 7) Baghabari 100 MW

2) Khulna ST 110 N 8) Ghorasal Unit-1 ST

3) Sikalbaha ST 60 9) Ghorasal # 3,5

4) Bheramara 410 (10) Shahjibazar 330 MW

5) Siddhirganj ST

6) Ashugani #4,5

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

a) Sirajganj #3 CCPP GT & ST were synchronized at 10:02 & 11:16 respectively.

b) Rangpur 33 kV Bus section-2 was shut down at 08:40 due to red hot maintenance at bus Y-phase isolate About 40 MW power interruption occurred under Rangpur S/S 33 kV Maliganj feeder and was switched on at 09:40. area from 08:40 to 09:40.

c) Sylhet-Chatak 132 kV Ckt-1 was under shut down from 11:05 to 13:59 for C/M.

d) Dhamrai 132/33 kV T-1 & T-2 transformers tripped at 11:43 due to 33 kV feeder fault (Sky wire break) a About 40 MW power interruption occurred under Dhamrai S/S area from 11:43 to 12:03.

e) Kabirpur 132/33 kV T-2 transformer was shut down at 09:05 due to red hot maintenance at 33 kV Bus isolator of 33 kV EPZ feeder and was switched on at 10:30.

f) Kaliakoir-Kabirpur 132 kV Ckt-1 tripped at 10:43 showing Gen.trip, CB protection at Kabirpur end & dist.z About 40 MW power interruption occurred under Kabirpur S/S relay at Kaliakoir end and was switched on at 12:40. area from 10:43 to 12:40.

g) After maintenance Ghorasal-Ashuganj 230 kV Ckt-2 was switched on at 10:11.

h) Sikalbaha 132/33 kV T-3 transformer tripped at 14:37 showing O/C, E/F relay from both end and was sw About 15 MW power interruption occurred under Sikalbaha S/S on at 15:14. area from 14:37 to 15:14.

i) Faridpur 132/33 kV T-1 transformer was shut down at 15:04 due to red hot maintenance at 33 kV Y-phas About 30 MW power interruption occurred under Faridpur S/S incomer bus isolator and was switched on at 15:50. area from 15:05 to 15:50.

i) After maintenance Madertek 132/33 kV T-2 transformer was switched on at 18:34

k) After maintenance Dhanmondi 132/33 kV T-4 transformer was switched on at 20:38.

I) Bibiyana-2 CCPP ST tripped at 23:18 showing bearing vibration high and was synchronized at 03:05(17/6/19).

m) After maintenance Raozan #1 was synchronized at 22:54.

n) Fenchuganj 132/33 kV T-1 transformer tripped at 02:53(17/6/19) showing no relay and was switched on at 03:16(17/06/2019).

o) After maintenance Khulna-225 MW CCPP GT was synchronized at 23:19.

p) Bagerhat 132/33 kV T-2 transformer was shut down at 06:19(17/6/19) due to red hot maintenance at CB About 21 MW power interruption occurred under Bagerhat S/S DS loop and was switched on at 08:25(17/6/19). area from 06:19 to 08:25(17/6/19).

Sub Divisional Engineer **Executive Engineer** Superintendent Engineer Load Despatch Circle Network Operation Division Network Operation Division