

Sl. No.	Date : 22-Jun-19			Page -2			
	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
Unit No. X Capacity			MW	MW	MW		
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	836000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170	159	4894100	
	Ghorasal GT: Unit-4	PDB	1*210	180	200	4692000	
	Ghorasal ST: Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal ST: Unit-7	QRPP	1*243+1*122	365	200	5147000	ST under maint.
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	30	948640	Frequency control
4	Ghorasal (Regent)	IPP	3*4.35	108	107	1083090	
5	Haripur GT: Unit-1, 2	SB, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	332	8136710	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	55	142200	Low demand
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	313	7213000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	420	8886250	
10	Meghnaghat (IEL)	QRPP	12*8.9	100	74	191040	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	275	6369076	FGMO
12	Madanganj 102MW	QRPP	6*17	100	0	39960	Reserve
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	0	0	Reserve
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	70	299384	Low demand
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	22	427248	
16	Siddhirganj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirganj GT Unit-1& 2	EGCB	2*105	210	0	933000	Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirganj (Dutch Bangla)	QRPP	12*8.9	100	50	254400	Low demand
19	Siddhirganj CCPP-335 MW	EGCB	1*217	217	0	2509510	Machine problem
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	7	191040	Low demand
21	Katpotti 51 MW	IPP	7*7.9	51	49	296832	
22	Banco Energy 54MW	IPP	3*18	54	54	1053720	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	130	1140480	Engine problem
24	Northern 55 MW	IPP	3*19.3	55	55	785005	
25	Southern 55MW	IPP	3*19.3	55	55	854000	
26	Bosila 108MW	IPP	12*8.775+1*3.5	108	65	715200	Engine problem
27	Summit Power,(Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	56	1265280	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	33	808400	
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	803000	
30	Gazipur (RPCL)	IPP	8*8.9	52	50	853152	
31	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	112	536950	Low demand
33	APR Energy , Keraniganj	IPP	256*1.4	300	0	0	Reserve
34	Bramhangaoan 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	149	930240	
37	Gazipur 100 MW	RPCL	100 MW	105	106	2438400	
<b>Dhaka area Total</b>				<b>5803</b>	<b>3296</b>	<b>65672307</b>	
38	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2400000	
	Chittgong ST-2 (Raozan)	PDB	1*210	180	120	3000000	
39	Raazan 25 MW (RPCL)	IPP	3*8.25	25	25	211620	
40	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	132030	
41	Patenga 50MW	IPP	8*6.98	50	46	1104000	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	68	1007800	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	205	4913086	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	85	1512306	
46	Sikalbaha (Energy)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	33	504480	Engine problem
47	Baraka Sikalbaha PL	IPP	105 MW	105	0	0	Reserve
48	Hathazari peaking	PDB	11*8.9	98	82	555120	
49	Dohazari Peaking	PDB	6*17	102	51	699263	
50	Juidah (Acorn)	QRPP	8*13.45	100	50	444240	Low demand
51	Juidah 100 MW Unit-3	IPP	0	100	100	2314560	
52	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	21	502032	
*	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	18	370560	
53	Chattogram ECPV 108 MW	IPP	16*7	108	82	663360	Low demand
	Kaptai Solar	PDB	7.4 MW	0	0	36720	
	Anwara United	United Group	300 MW	0	278	5817854	on test
<b>Chattogram area Total</b>				<b>1786</b>	<b>1364</b>	<b>25089031</b>	
54	Ashuganj ST: Unit- 3	APSCL	1*150	135	125	2678106	
	Ashuganj ST: Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj CCPP 225 MW	APSCL	1*142+1*75	221	216	4687000	FGMO
56	Ashuganj CCPP(North)	APSCL	1*360	360	220	4560800	Frequency control
57	Ashuganj CCPP(South)	APSCL	1*360	360	360	7966000	
58	Ashuganj Engines TSK	APSCL	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55	56	1258560	
60	Ashuganj (United) 53MW	QRPP	14*4	53	5	120000	Gas shortage
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	618909	Gas shortage
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	782840	Machine problem
63	Midland 150MW	IPP	23*7.015	150	110	625600	Low demand
64	B.Bania (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Daudkandi Peaking 52MW	PDB	6*8.92	52	0	0	Reserve
66	Chandpur CCPP	PDB	1*106+1*57	163	90	2122420	
67	Chandpur Desh 200MW	IPP	0	200	200	2285760	
68	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	507204	
69	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	101520	
**	Tripura	Imported power	0	160	186	3446400	
70	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	566700	
71	Lakdhanvi 52 MW	IPP	6*8.92	52	52	430738	
72	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	21	431470	
73	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1739</b>	<b>33191027</b>	
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	100	2343040	Machine problem
75	Tangail (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	442404	
76	Jamajpur 95MW	IPP	12*8.924	95	86	1540800	Engine problem
77	Satishabari (Solar)	IPP	1*3	3	0	10550	
78	United Mymensingh PPL	IPP	200	200	182	2419200	
79	United Jamalpur PPL	IPP	115 MW	115	97	1804900	Engine problem
<b>Mymensingh Area Total</b>				<b>637</b>	<b>487</b>	<b>8560794</b>	
80	Fenchugonj CCPP-1	PDB	2*32+1*33	70	53	1271000	
81	Fenchugonj CCPP-2	PDB	2*35+1*35	90	57	1371600	
82	Kushlira 163 MW CCPP GT	IPP	1*109+1*54	163	100	3263741	Frequency control
83	Shajibazar 330 MW	PDB	3*110	330	310	6134000	FGMO
84	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	50	997800	
85	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	46	943200	
86	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	254112	
87	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	63	1437792	FGMO
88	Shajibazar 86MW	RPP	32*2.90	86	83	1618560	
89	Shajibazar (EPL) 50MW	RPP	27*2.0	50	42	916560	
90	Sylhet GT 150 MW	PDB	1*142	142	73	2479690	FGMO
91	Sylhet GT 20 MW	PDB	1*20	20	0	0	
92	Sylhet (EPL) 50MW	RPP	27*2	50	47	911260	
93	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	574296	
94	Summit Bibiana- 2	IPP	1*222+1*119	341	300	7353500	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	294	6010000	On test
95	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	241200	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1563</b>	<b>35778311</b>	
96	Bheramara GT-1,2,3	PDB	3*20	46	0	0	
**	Bheramara (HVDC)	Imported power	2*500	1000	922	22283636	
	Khulina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulina (KPCL-2)	QRPP	7*17	115	99	835200	Engine problem
98	Fandpur Peaking	PDB	8*6.89	54	24	192000	
99	Khulina CCPP 225MW	NWPGCL	1*150+1*75	230	120	3063760	Low demand
100	Goपालगं Peaking	PDB	16*9.98	109	64	451584	
101	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*8.5	40	0	3750	33 kV line problem
	Khulina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
103	Bangla Trak Noapara	IPP	70*1.4	100	100	677760	
104	Labon Chora 105 MW	IPP	6*18.446	105	105	1267200	
105	Madhumati Power Plant	IPP	100 MW	105	105	1632384	
<b>Khulina Area Total</b>				<b>2314</b>	<b>1539</b>	<b>30367274</b>	
106	Summit Barisal 110 MW	IPP	7*17.076	110	110	156660	
107	Barisal GT: Unit-1, 2	PDB	2*20	30	0	0	Reserve
108	Bhola (Venture) 33MW	RPP	1*34.50	33	38	602786	
109	Bhola CCPP 194MW	PDB	2*63+1*68	194	120	2879000	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95	89	1782292	
<b>Barisal Area Total</b>				<b>462</b>	<b>357</b>	<b>5421038</b>	
111	Baghabari GT 71MW	PDB	1*71	71	60	1410000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52	43	374856	
113	Bera Peaking	PDB	9*8.29	71	0	94898	
114	Amnura 50MW	QRPP	7*7.79	50	33	227093	Engine problem
115	Katakhal (Northern)	QRPP	6*8.9	50	43	487718	
116	Katakhal Peaking	PDB	6*8.7	50	44	314400	
117	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	188	4535727	FGMO
118	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	185	4397627	FGMO
119	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	195	4701436	FGMO
120	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282+1*132	414	370	8016515	
121	Santahar Peaking	PDB	6*8.7	50	28	256927	
122	Bogra (GBB)						