

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	35	846000	Gas shortage
	Ghorasal GT: Unit-3	PDB	1*210	170	229	5713300	
	Ghorasal GT: Unit-4	PDB	1*210	180	150	4146000	Gas shortage
	Ghorasal ST: Unit-5	PDB	1*210	190	110	945000	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	0	54500	Under maint.
	Ghorasal 78MW (MAX)	QRPP		78	40	1310848	Gas shortage
4	Ghorasal (Regent)	IPP	34*3.35	108	107	2028182	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*52	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	280	7952456	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	96	1066300	Engine problem
8	Haripur Power CAPP 360MW	IPP	1*235+1*125	360	320	7656000	Frequency control
9	Meghnaghat CAPP 450MW	IPP	2*150+1*150	450	450	9389500	
10	Meghnaghat (EL)	QRPP	12*8.9	100	100	1201920	
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	282	6636713	FGMO
12	Madanganj 102MW	QRPP	6*17	100	95	822696	Low demand
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	655989	
14	Keraniganj (Powerpac) 100MW	QRPP	8*13.45	100	50	749231	Low demand
15	Narsingdi (Doreen)	SIPP, REB	8*2.90	22	22	482544	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	100	1383360	
19	Siddhirgonj CAPP-335 MW	EGCB	1*217	217	0	5018	Gas shortage
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gagnagar (Orion)	IPP	12*8.924	102	101	1425744	
21	Katpotti 51 MW	IPP	7*7.9	51	42	270624	Engine problem
22	Banco Energy 54MW	IPP	3*18	54	54	1292400	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	140	2027520	Engine problem
24	Northern 55 MW	IPP	3*19.3	55	55	1158332	
25	Southern 55MW	IPP	3*19.3	55	55	1084700	
26	Bosila 108MW	IPP	12*8.775+1*3.5	108	75	1324800	Engine problem
27	Summit Power,(Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	57	1295520	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	25	723800	Engine problem
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	804900	
30	Gazipur (RPCL)	IPP	6*8.9	52	49	1008924	
31	Tongi GT	PDB	1* 105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	255	1819090	Low demand
33	APR Energy , Keraniganj	IPP	256*1.4	300	33	159457	Low demand
34	Bramhangaoon 100 MW (Aggreko)	IPP	100	100	0	0	Reserve
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Summit Gazipur-1 150MW	IPP	149	149	149	1936800	
37	Gazipur 100 MW	RPCL	100 MW	105	106	2432400	
<b>Dhaka area Total</b>				<b>5803</b>	<b>3750</b>	<b>71815568</b>	
38	Chattogram ST-1 (Raozan)	PDB	1*210	180	100	2400000	
	Chittogong ST-2 (Raozan)	PDB	1*210	180	120	2700000	
39	Raozan 25 MW (RPCL)	IPP	3*8.9	25	25	439025	
40	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	142830	
41	Patenga 50MW	IPP	8*6.98	50	46	1008960	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1604920	Low water level
43	Sikalbaha ST 60MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4943158	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	130	3107346	
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	33	500160	Engine problem
47	Baraka Sikabaha PL	IPP	105 MW	105	36	443270	Low demand
48	Hathazari peaking	PDB	11*8.9	98	82	834208	
49	Dohazari Peaking	PDB	6*17	102	68	591875	
50	Juidah (Acorn)	QRPP	8*13.45	100	100	876840	
51	Juidah 100 MW Unit-3	IPP	0	100	100	2289600	
52	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	21	435168	
*	Malanchara, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	21	447360	
53	Chattogram ECPV 108 MW	PDB	16*7	108	96	1741440	
	Kaptila Solar	PDB	7.4 MW	0	0	34440	
	Anwara United	United Group	300 MW	0	243	5447236	on test
<b>Chattogram area Total</b>				<b>1786</b>	<b>1495</b>	<b>29987836</b>	
54	Ashuganj ST: Unit- 3	APSCCL	1*150	135	125	3025116	
	Ashuganj ST: Unit- 4	APSCCL	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCCL	1*150	134	0	0	Gas shortage
55	Ashuganj CAPP 225 MW	APSCCL	1*142+1*75	221	213	4890000	FGMO
56	Ashuganj CAPP(North)	APSCCL	1*360	360	320	7866000	
57	Ashuganj CAPP(South)	APSCCL	1*360	360	280	7526500	
58	Ashuganj Engines TSK	APSCCL	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55	52	1280160	
60	Ashuganj (United) 53MW	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	518545	Gas shortage
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	732288	Machine problem
63	Midland 150MW	IPP	23*7.015	150	0	759418	Reserve
64	B.Bania (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Daudkandi Peaking 52MW	PDB	6*8.92	52	50	228704	
66	Chandpur CAPP	PDB	1*106+1*57	163	90	2131080	
67	Chandpur Desh 200MW	IPP	0	200	197	3854400	
68	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	494100	
69	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	8	179820	Engine problem
**	Tripura	Imported power	0	160	178	3826560	
70	Jangalla (Summit) 33MW	SIPP, PDB	4*8.73	33	25	607800	Engine problem
71	Lakdhanvi 52 MW	IPP	6*8.92	52	52	823474	
72	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	495620	
73	Daudkandi bangla trak	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1675</b>	<b>39203485</b>	
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	125	2394440	Machine problem
75	Jamalpur (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	480276	
76	Jamalpur 95MW (Solar)	IPP	12*8.924	95	85	2001600	Engine problem
77	Satishabri (Solar)	IPP	1*3	3	0	16100	
78	United Mymensingh PPL	IPP	200	200	190	3636000	Engine problem
79	United Jamalpur PPL	IPP	115 MW	115	96	2224900	Engine problem
<b>Mymensingh Area Total</b>				<b>637</b>	<b>518</b>	<b>10763216</b>	
80	Fenchuganj CAPP-1	PDB	2*32+1*33	70	53	1265000	
81	Fenchuganj CAPP-2	PDB	2*35+1*35	90	70	1886480	
82	Kushara 163 MW CAPP GT	IPP	1*109+1*54	163	100	3179896	Frequency control
83	Shajibazar 330 MW	PDB	3*110	330	305	2926000	FGMO
84	Fenchuganj (Barakatullah) 51MW	RPP	19*2.90	51	50	1108200	
85	Fenchuganj (EPL) 44MW	RPP	12*3.3+5*2	44	46	1085832	
86	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	219216	
87	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	61	1248768	FGMO
88	Shajibazar 86MW	RPP	32*2.90	86	81	1776960	
89	Shajibazar (EPL) 50MW	RPP	27*2.0	50	43	924840	
90	Sylhet GT 150 MW	PDB	1*142	142	84	2574890	FGMO
91	Sylhet GT 20 MW	PDB	1*20	20	0	0	Engine problem
92	Sylhet (EPL) 50MW	RPP	27*2	50	48	1023700	
93	Shahjanulla 25 MW	SIPP, REB	3*9.34	25	24	558624	
94	Summit Bibiana- 2	IPP	1*222+1*119	341	300	7664000	FGMO
95	Bibiyana-3 285 MW	PDB	285 MW	0	289	6820000	On test
	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	239040	
<b>Sylhet Area Total</b>				<b>1549</b>	<b>1575</b>	<b>34301086</b>	
96	Bheramara GT-1,2,3	PDB	3*20	46	30	214500	Low demand
**	Bheramara (HVDC)	Imported power	2*500	1000	913	21956363	
	Khulina (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulina (KPCL-2)	QRPP	7*17	115	115	1622400	
98	Fandpur Peaking	PDB	8*6.89	54	35	189600	
99	Khulina CAPP 225MW	NWPGL	1*150+1*75	230	130	2012160	Low demand
100	Goपालज Peaking	PDB	16*6.98	109	51	637952	
101	Bheramara 300 MW	NWPGL	1*278+1*132	410	0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*5.5	40	40	567000	
	Khulina (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
103	Bangla Trak Noapara	IPP	70*1.4	100	100	829440	
104	Labon Chora 105 MW	IPP	6*18.445	105	53	1294560	Low demand
105	Madhumati Power Plant	IPP	100 MW	105	85	2056896	Engine problem
<b>Khulina Area Total</b>				<b>2314</b>	<b>1552</b>	<b>31380871</b>	
106	Summit Barisal 110 MW	IPP	7*17.076	110	110	1372800	
107	Barisal GT: Unit-1, 2	PDB	2*20	30	12	46115	Low demand
108	Bhola (Venture) 33MW	RPP	1*34.50	33	39	681013	
109	Bhola CAPP 194MW	PDB	2*63+1*68	194	120	2879000	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95	94	2261938	
<b>Barisal Area Total</b>				<b>462</b>	<b>375</b>	<b>7240866</b>	
111	Baghabari GT 71MW	PDB	1*71	71	55	1370000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52	50	521184	
113	Bera Peaking	PDB	9*8.29	71	24	209473	
114	Amnara 50MW	QRPP	7*7.9	50	40	638940	Engine problem
115	Katakhal (Northern)	QRPP	6*8.9	50	43	869107	Engine problem
116	Katakhal Peaking	PDB	6*8.7	50	44	332547	
117	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	188	4752073	FGMO
118	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	186	4591073	FGMO
119	Sirajgonj Unit-3 225MW	NWPGL	1*141	220	201	5048936	FGMO
120	Sirajgonj Unit-4 414 MW (Gas)	SNWPGCL	1*282+1*132	414	350	8888454	Frequency control
121	Santahar Peaking	PDB	6*8.7	50	35	254133	
122	Bogra (GBB)	RPP	6*4	22	22		