

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal ST: Unit-1,2	PDB	2*55	85	70	1218000	
	Ghorasal GT: Unit-3	PDB	1*210	170	0	4306000	Machine problem
	Ghorasal GT: Unit-4	PDB	1*210	180	200	3790000	
	Ghorasal ST: Unit-5	PDB	1*210	190	110	2835000	Gas shortage
2	Ghorasal ST: Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorasal 78MW (MAX)	QRPP	2*40	78	50	1257536	Gas shortage
4	Ghorasal (Regent)	IPP	34*3.35	108	107	2435909	
5	Haripur GT: Unit-1, 2	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	330	8256110	FGMO
7	Haripur NEPC 110MW	IPP	8*15	110	36	824400	Low demand
8	Haripur Power CCPP 360MW	IPP	1*235+1*125	360	352	7944000	Frequency control
9	Meghnaghat CCPP 450MW	IPP	2*150+1*150	450	330	9201750	Frequency control
10	Meghnaghat (IEL)	QRPP	12*8.9	100	94	1203840	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	226	6548393	FGMO
12	Madanganj 102MW	QRPP	6*17	100	96	1038192	
13	Madanganj-55 MW	(IPP)	3*17.08+1*11.3	55	55	1005265	
14	Keranganj (Powerpac) 100MW	QRPP	8*13.45	100	85	969621	Low demand
15	Narshingdi (Doreen)	SIPP, REB	8*2.90	22	22	429876	
16	Siddhirgonj ST 210MW	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj GT Unit-1& 2	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj (Dutch Bangla)	QRPP	12*8.9	100	99	1443840	
19	Siddhirgonj CCPP-335 MW	EGCB	1*217	217	13	80290	Test
	Dipa (DPA)	QRPP	100*0.15	0	0	0	Contract Expired
20	Gazipur (Orion)	IPP	12*8.924	102	100	1807056	
21	Katpctt 51 MW	IPP	7*7.9	51	46	297744	Engine problem
22	Banco Energy 54MW	IPP	3*18	54	54	1290240	
23	Kodda 149MW	BPDB-RPCL	9*17.06	149	141	2333760	Engine problem
24	Northern 55 MW	IPP	3*19.3	55	55	1205177	
25	Southern 55MW	IPP	3*19.3	55	55	1160000	
26	Bosila 108MW	IPP	12*8.775+1*3.5	108	72	1698240	Engine problem
27	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	57	1265280	Engine problem
28	Summit Maona	SIPP, REB	4*8.73	33	33	778100	
29	Summit Rugganj	SIPP, REB	4*8.73	33	33	787200	
30	Gazipur (RPCL)	IPP	6*9.9	52	48	1141680	
31	Tongi GT	PDB	1*105	105	0	0	Gas shortage
32	Summit Gazipur -2	IPP	18*17.076	300	290	2408722	
33	APR Energy, Keranigonj	IPP	256*1.4	300	70	189295	Low demand
34	Bramhangonj 100 MW (Aggreko)	IPP	100	100	40	73436	Low demand
35	Aggreko Aurahati 100MW	IPP	0.85*23+0.95*91	100	22	60282	Low demand
36	Summit Gazipur-1 150MW	IPP	149	149	149	2629440	
37	Gazipur 100 MW	RPCL	100 MW	105	106	2544000	
Dhaka area Total				5803	3646	76446674	
38	Chattoogram ST-1 (Raozan)	PDB	1*210	180	100	2300000	
	Chittgong ST-2 (Raozan)	PDB	1*210	180	0	0	Gas shortage
39	Raazan 25 MW (RPCL)	IPP	3*8.9	25	25	594709	
40	Teknaf Solartech 20MW	Teknaf Solartech Energy	20	20	0	129600	
41	Patenga 50MW	IPP	8*6.98	50	46	1081440	
42	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	38	1145740	Low water level
43	Sikalbaha ST 68MW	PDB	1*60	40	0	0	Under maint.
44	Sikalbaha 225MW	PDB	1*150+1*175	225	205	4918717	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	130	3099064	
46	Sikalbaha (Energis)	RPP	4*12.5+2*11.9+1*3+1*11.5	51	33	509760	Engine problem
47	Baraka Sikalbaha PL	IPP	105 MW	105	35	624760	Low demand
48	Hathazari peaking	PDB	1*18.9	98	82	744016	
49	Dohazari Peaking	PDB	6*17	102	68	1610984	
50	Juldah (Acom)	QRPP	8*13.45	100	80	896760	Engine problem
51	Juldah 100 MW Unit-3	IPP	0	100	100	2440320	
52	Barabkunda (Regent)	SIPP, PDB	8*2.90	22	21	461904	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	14	456000	
53	Chattoogram ECPV 108 MW	IPP	16*7	108	96	1821120	
	Kaptai Solar	PDB	7.4 MW	0	0	26161	
	Anwara United	United Group	300 MW	0	244	5600290	on test
Chattoogram area Total				1766	1317	28461345	
54	Ashuganj ST: Unit- 3	APSCl	1*150	156	125	2936484	
	Ashuganj ST: Unit-4	APSCl	1*150	129	0	0	Gas shortage
	Ashuganj ST: Unit- 5	APSCl	1*150	134	0	0	Gas shortage
55	Ashuganj CCPP 225 MW	APSCl	1*142+1*75	221	217	5152000	FGMO
56	Ashuganj CCPP(North)	APSCl	1*360	360	300	8120000	Frequency control
57	Ashuganj CCPP(South)	APSCl	1*360	360	300	7399000	Frequency control
58	Ashuganj Engines TSK	APSCl	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj (Precision) 55MW	RPP	15*4	55	53	1286400	
60	Ashuganj (United) 53MW	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW Modular	IPP	20*9.73+1*16	195	8	200727	Gas shortage
62	Ashuganj (Midland) 51MW	IPP	6*9.34	51	35	735144	Machine problem
63	Midland 150MW	IPP	23*7.015	150	136	685820	Engine problem
64	B.Bana (Aggreko) 85MW	QRPP	8*11.10	85	0	0	Contract Expired
65	Daudkandi Peaking 52MW	PDB	6*8.92	52	50	129008	
66	Chandpur CCPP	PDB	1*108+1*57	163	50	1239820	
67	Chandpur Desh 200MW	IPP	0	200	196	3954240	
68	Feni (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	499248	
69	Feni, Mohipal (Doreen)	SIPP, REB	4*2.90	11	11	215460	
**	Tripura	Imported power	0	160	160	3859200	
70	Jangalia (Summit) 33MW	SIPP, PDB	4*8.73	33	25	615900	Engine problem
71	Laksharvi 52 MW	IPP	6*8.92	52	52	805013	
72	Summit Cumilla 25MW	SIPP, PDB	3*3.67+2*6.97	25	20	438810	
73	Daudkandi bangla trak	IPP	154*1.4	200	100	157440	Low demand
Cumilla Area Total				2891	1860	38399714	
74	Mymensingh RPCL 210MW	IPP	4*35+1*70	202	146	3412600	Machine problem
75	Tangal (Doreen) 22MW	SIPP, PDB	8*2.90	22	22	440152	
76	Jamalpur 95MW	IPP	12*8.924	95	83	2001600	Engine problem
77	Sarishabari (Solar)	IPP	1*3	3	0	10900	
78	United Mymensingh PPL	IPP	200	200	175	3873600	Engine problem
79	United Jamalpur PPL	IPP	115 MW	115	95	2293200	Engine problem
Mymensingh Area Total				637	521	12032052	
80	Fenchugonj CCPP-1	PDB	2*32+1*33	70	54	1281000	
81	Fenchugonj CCPP-2	PDB	2*35+1*35	90	70	1687920	
82	Kushiaara 163 MW CCPP GT	IPP	1*109+1*54	163	0	39706	Frequency control
83	Shajibazar 330 MW	PDB	3*110	330	196	6009000	FGMO
84	Fenchugonj (Barakatullah) 51MW	RPP	19*2.90	51	53	1229400	
85	Fenchugonj (EPL) 44MW	RPP	12*3.3+5*2	44	49	1140984	
86	Hobiganj 11MW	SIPP, REB	4*2.90	11	11	259968	
87	Shajibazar GT: Unit- 8, 9	PDB	2*35	66	40	1321632	FGMO
88	Shajibazar 86MW	RPP	32*2.90	66	77	1854720	
89	Shajibazar (EPL) 50MW	RPP	27*2.0	50	44	1029660	Engine problem
90	Sylhet GT 150 MW	PDB	1*142	142	110	5189827	FGMO
91	Sylhet GT 20 MW	PDB	1*20	20	0	0	Engine problem
92	Sylhet (EPL) 50MW	RPP	27*2	50	47	1050800	
93	Shahjahanulla 25 MW	SIPP, REB	3*9.34	25	24	549096	
94	Summit Bibiana- 2	IPP	1*222+1*119	341	275	7488028	FGMO
	Bibiyana-3 285 MW	PDB	285 MW	0	298	6283000	On test
95	Sylhet (Desh) 10MW	RPP	6*1.95	10	10	240480	
Sylhet Area Total				1549	1358	36655521	
96	Bheramara GT-1,2,3	PDB	3*20	46	46	334600	Low demand
**	Bheramara (HVDC)	Imported power	2*500	1000	908	21502545	
	Khulna (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulna (KPCL-2)	QRPP	7*17	115	115	1317120	
98	Fariapur Peaking	PDB	8*6.89	54	36	821920	
99	Khulna CCPP 225MW	NWPGCL	1*150+1*75	220	221	3433920	
100	Gopalganj Peaking	PDB	16*6.98	109	60	623488	
101	Bheramara 360 MW	NWPGCL	1*278+1*132	410	0	0	Under maint.
102	Noapara (KZA) 40MW	QRPP	5*8.5	40	40	511500	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
103	Bangla Trak Noapara	IPP	70*1.4	100	88	1092480	
104	Labon Chora 105 MW	IPP	6*18.445	105	72	639360	Low demand
105	Madhumati Power Plant	IPP	100 MW	105	85	1811088	Engine problem
Khulna Area Total				2314	1671	31688021	
106	Summit Barisal 110 MW	IPP	7*17.076	110	110	1586880	
107	Barisal GT: Unit-1, 2	PDB	2*20	30	0	13287	Reserve
108	Bhola (Venture) 33MW	RPP	1*34.50	33	36	680991	
109	Bhola CCPP 194MW	PDB	2*63+1*68	194	144	3007913	FGMO
110	Bhola Aggreko 95MW	QRPP	96*1.10	95	93	2155310	
Barisal Area Total				462	383	7444381	
111	Baghabari GT 71MW	PDB	1*71	71	55	1338000	
	Baghabari GT 100MW	PDB	1*100	100	0	0	Under maint.
112	Baghabari Peaking 50MW	PDB	6*8.9	52	50	1201624	
113	Bera Peaking	PDB	9*8.29	71	26	274367	
114	Ammura 50MW	QRPP	7*7.79	50	40	551730	Engine problem
115	Katakhal (Northern)	QRPP	6*8.9	50	43	748105	Engine problem
116	Katakhal Peaking	PDB	6*8.7	50	47	467133	
117	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	183	4768936	FGMO
118	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	179	4580982	FGMO
119	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	195	4987745	FGMO
120	Sirajgonj Unit-4 414 MW(Gas)	SNWPGCL	1*282+1*132	414	300	8591545	Frequency control
121	Santahar Peaking	PDB	6*8.7				