

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	70	1629000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	104	3000000	
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4536000	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	340	7535345	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	50	1437856	
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	72	1776227	
5	Haripur GT PP	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	339	7618976	
8	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	339	6971000	
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	400	8240000	frequency control.
10	Meghnaghat 100 MW (EL)	QRPP	12*8.9	100	100	762240	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	251	6214516	FGMO
12	Madanganj 102 PP(Summit)	QRPP	6*17	100	48	248952	Low demand
13	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	431939	
14	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	70	402068	Low demand
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	413748	
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
17	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	70	639360	
19	Siddhirgonj 335 MW CCPP	EGCB	1*217	217	0	671182	
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaganagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	927504	
21	Kaptoti 52 MW PP (Sitha)	IPP	7*7.9	51	47	968224	
22	Banco Energy 54MW	IPP	3*18	54	53	1058400	
23	Kodda 150MW PP	BPD&RPCL	9*17.06	149	113	1523040	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	933262	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	870004	
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1256680	Engine problem
27	Summit Power (Madhabdi+Ashulid	SIPP,REB	3*3.67+4*8.73	80	54	1219380	Engine problem
28	Maona 33 MW (Summit)	SIPP,REB	4*8.73	33	33	809000	
29	Rugganj 33 MW (Summit)	SIPP,REB	4*8.73	33	33	757200	
30	Gazipur 52 MW PP	IPP	6*8.9	52	50	944112	
31	Tong 80 MW GT PP	PDB	1*105	105	0	0	Gas shortage
32	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	110	903272	
33	Keraniganj 300 MW PP (ARR)	IPP	25*11.4	300	0	0	Reserve
34	Bramhangan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve
35	Aurabati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	105	1622880	Low demand
37	Gazipur 100 MW PP	RPCL	100 MW	105	87	4656870	Low demand
<b>Dhaka area Total</b>				<b>5693</b>	<b>3489</b>	<b>70969637</b>	
38	Chattoogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	0	0	Under maint.
39	Racozan 25 MW PP	IPP	3*8.9	25	25	344374	
40	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energy	20	20	0	21600	
41	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	45	885120	Engine problem
42	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	37	860000	Low water level
44	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4917147	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	130	3155232	
46	Sikalbaha E1 1MW PP (Engine)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	25	508800	Engine problem
47	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	35	693342	Low demand
48	Hathazari 100 MW peaking PP	PDB	1*118.9	98	84	446256	
49	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	68	400324	
50	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	391248	Low demand
51	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1962240	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	16	380160	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	29	40460	
53	Chattoogram 108 MW PP (ECPV)	IPP	167	108	96	1372800	Engine problem
	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	28800	
	Anwara 300 MW PP (United)	United Group	300 MW	300	247	4656870	on test
<b>Chattoogram area Total</b>				<b>2053</b>	<b>1251</b>	<b>23464773</b>	
54	Ashuganj TPP Unit-3	APSCL	1*150	135	128	2768080	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	182	4582000	FGMO
56	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	330	7255500	FGMO
57	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	330	7036500	
58	Ashuganj 50 MW PP	APSCL	14*3.968	45	0	0	Gas Line maint.
59	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1225920	
60	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW PP (APSCL-Ur	IPP	20*9.73+1*116	195	78	1906909	Gas shortage
62	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	790244	Machine problem
63	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	147	1535560	
64	B Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	70776	
66	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	95	232929	ST under maint.
67	Chandpur 200MW (Desh energy)	IPP	0	200	0	312840	
68	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	498928	
69	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	230940	
**	Imoport (Tripura)	Imported power	0	160	120	2648640	Load restricted from India.
70	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	776700	
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	788021	
72	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	331100	
73	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1838</b>	<b>37922608</b>	
74	RPCL 210MW CCPP	IPP	4*35+1*70	202	149	3330880	GT-1 under maint.
75	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	449136	
76	Jamapur 95 MW PP	IPP	12*8.924	95	94	959040	
77	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14850	
78	United Mymensingh 200 MW PP (	IPP	200	200	150	4125600	Engine problem
79	Jamapur 115 MW PP (United)	IPP	115 MW	115	93	1228800	Engine problem
<b>Mymensingh Area Total</b>				<b>637</b>	<b>508</b>	<b>10108306</b>	
80	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	54	1280000	
81	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	50	1344920	
82	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3306354	frequency control.
83	Shajibazar 330 MW CCPP	PDB	3*110	330	154	3440000	FGMO & ST Under maint
84	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	50	948600	
85	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	1008648	
86	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	261888	
87	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	63	1414080	FGMO
88	Shajibazar 86MW PP (Shajibaz	RPP	32*2.90	86	80	1380480	
89	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	45	990720	
90	Sylhet 150 MW CCPP	PDB	1*142	142	104	2599860	FGMO
91	Sylhet 20 MW GTPP	PDB	1*20	20	15	416000	
92	Sylhet 50MW PP (EPL)	RPP	27*2	50	46	926800	
93	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	23	513600	
94	Bibiana-III 341 MW CCPP (Summi	IPP	1*222+1*119	341	315	7535800	FGMO
	Bibiana-III 400 MW CCPP	PDB	285 MW	285	279	5181000	On test
95	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	245880	
<b>Sylhet Area Total</b>				<b>1834</b>	<b>1478</b>	<b>32793730</b>	
96	Bheramara GT-1,2,3	PDB	3*200	46	32	154300	
**	Bheramara (HVDC )	Imported power	2*500	1000	922	22102545	
	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
97	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	99	1341120	Engine problem
98	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	36	229920	
99	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
100	Capalganj 108 MW Peaking PP	PDB	16*6.98	109	65	445568	
101	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Under maint.
102	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	40	139125	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
103	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	100	613440	
104	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1808640	
105	Madhumati 100 MW PP	IPP	100 MW	105	87	1770336	Engine problem
<b>Khulna Area Total</b>				<b>2314</b>	<b>1486</b>	<b>28604994</b>	
106	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	110	1050240	
107	Barisal GT PP Unit-1& 2	PDB	2*20	30	12	69099	Low demand
108	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	37	567287	
109	Bhola 225 MW CCPP	PDB	2*63+1*68	194	173	4227788	FGMO
110	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	0	0	
<b>Barisal Area Total</b>				<b>462</b>	<b>332</b>	<b>5914414</b>	
111	Baghabari 71 MW GTTP	PDB	1*71	71	60	1395000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
112	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	372880	
113	Bera 70 MW Peaking PP	PDB	9*8.29	71	33	154904	
114	Amnura 50 MW PP	QRPP	7*7.79	50	40	588590	Engine problem
115	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	43	451730	Engine problem
116	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	39	116642	
117	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	196	4617809	FGMO
118	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	198	4429436	FGMO
119	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	209	4698955	FGMO
120	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL					