

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	Generation	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	70	1611000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Gas shortage
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	170	4158000	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	260	6371636	Gas shortage
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	4743170	Gas shortage.
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	274	6647000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	320	7566250	Gas shortage
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	100	1632860	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3538153	GT-2 S/D due to gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	100	791544	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	42	599663	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	82	872383	Engine problem
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	351288	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	1183680	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217	217	1	1230291	Gas shortage
	Paiga (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
19	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.924	102	93	1629216	
20	Kaptoti 52 MW PP (Sinha)	IPP	7*7.9	51	47	1134720	
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	17	948960	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	128	2244000	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1217064	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1075776	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	34	883200	Engine problem
26	Summit Power (Madhabdi+Ashulid)	SIPP,REB	3*3.67+4*8.73	80	57	1266000	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	749000	
28	Rugganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	805100	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	1032288	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	3648430	
32	Konaniganj 300 MW PP (ARR)	IPP	25*11.4	300	56	61608	Low demand
33	Bramhanganj 100 MW PP (Aggr)	IPP	100	100	51	120066	Low demand
34	Aurabahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	54	112360	Low demand
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	2433600	
36	Gazipur 100 MW PP	RPCL	100 MW	105	103	2259600	
Dhaka area Total				5693	3004	63116306	
37	Chattoogram TPP-1	PDB	1*210	180	90	2300000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	0	0	Under maint.
38	Racozan 25 MW PP	IPP	3*8.9	25	25	517579	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy		20	0	19575	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	41	1003680	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	106	2273840	Unit-2 & 3 under maint.
42	Sikalbaha 225MW	PDB	1*150+1*175	225	171	4439191	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	100	2162031	FGMO
44	Sikalbaha E1 1MW PP(PEnergis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	0	0	Oil shortage.
45	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	35	716760	Transformer overload.
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	72	473416	
47	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	71	413419	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	30	457320	Low demand
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2128320	
50	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	18	417360	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	32	517440	
51	Chattoogram 108 MW PP (ECPV)	IPP	167	108	70	1135680	Line O/L
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	12120	
53	Anwara 300 MW PP (United)	United Group	300 MW	300	212	4872654	Transformer overload.
Chattoogram area Total				2053	1173	23860385	
54	Ashuganj TPP Unit-3	APSCL	1*150	135	125	2461614	
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	182	4446000	FGMO
56	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	160	2199300	ST tripped.
57	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	290	7024500	FGMO
58	Ashuganj 50 MW PP	APSCL	14*3.968	45	35	701784	Engine problem
59	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	48	1220160	
60	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	68	2040727	Gas shortage
62	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	954458	Engine problem
63	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	3019272	
64	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
65	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	263896	
66	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	89	2081440	ST under shut down.
67	Chandpur 200MW (Desh energy)	IPP	0	200	198	3701280	
68	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	480996	
69	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	164880	
**	Impoort (Tripura)	Imported power	0	160	158	3160320	Low demand
70	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	813400	
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	898042	
72	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	360380	
73	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	50	119040	Low demand
Cumilla Area Total				2891	1783	36111489	
74	RPCL 210MW CCPP	IPP	4*35+1*70	202	122	2783960	GT-1 under maint.
75	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	433312	
76	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	94	2133120	
77	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	4600	
78	Mymensingh 200 MW PP (United)	IPP	200	200	160	1659000	
79	Jamalpur 15 MW PP (United)	IPP	115 MW	115	92	698900	Engine problem
Mymensingh Area Total				637	508	7110592	
80	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	54	1281000	
81	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	70	1667760	
82	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3531796	
83	Shahjibazar 330 MW CCPP	PDB	3*110	330	202	4641000	ST under maint.
84	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	52	1170000	
85	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1129248	
86	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	256992	
87	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	64	1536000	FGMO
88	Shahjibazar 86MW PP (Shahjibaz)	RPP	32*2.90	86	76	1646400	
89	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	46	1051560	
90	Sylhet 150 MW CCPP	PDB	1*142	142	110	2464450	FGMO
91	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	
92	Sylhet 50MW PP (EPL)	RPP	27*2	50	22	834300	Engine problem
93	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	535200	
94	Bibiana-III 341 MW CCPP (Summit)	IPP	1*222+1*119	341	290	7672250	FGMO
95	Bibiana-III 400 MW CCPP	PDB	285 MW	285	250	4646000	
96	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	227520	
Sylhet Area Total				1834	1494	34291476	
97	Bheramara GTTP Unit-1, 2 & 3	PDB	3*20	46	32	150600	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	929	22335272	
	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
98	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	115	1832640	
99	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	37	286560	
100	Khulna 225 MW CCPP	NWPGL	1*150+1*75	230	0	0	Reserve
101	Capalganj 108 MW Peaking PP	PDB	16*6.98	109	57	417408	
102	Bheramara 300 MW CCPP	NWPGL	1*278+1*132	410	0	0	Under maint.
103	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	667875	
	Khulna (Aggreco) 55MW	QRPP	71*0.85	0	0	0	Contract Expired
104	Noapara 100 MW PP (Bangla Tra)	IPP	70*1.4	100	92	525120	Engine problem
105	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	90	2038560	Engine problem
106	Madhumati 100 MW PP	IPP	100 MW	105	70	1598688	Engine problem
Khulna Area Total				2314	1462	29852723	
107	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	876480	
108	Barisal GT PP Unit-1 & 2	PDB	2*20	30	0	0	Reserve.
109	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	456360	
110	Bhola 225 MW CCPP	PDB	2*63+1*68	194	173	4209007	
111	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	95	2165279	
Barisal Area Total				462	404	7707126	
112	Baghabari 71 MW GTTP	PDB	1*71	71	60	1420000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
113	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	272808	
114	Bera 70 MW Peaking PP	PDB	9*8.29	71	26	235507	
115	Amnara 50 MW PP(Sinha)	QRPP	7*7.79	50	40	264900	Engine problem
116	Katakhati 50 MW PP (Northern)	QRPP	6*8.9	50	34	256024	Engine problem
117	Katakhati 50 MW Peaking PP	PDB	6*8.7	50	39	169415	
118	Sirajgonj Unit-1 225MW	NWPGL	1*150+1*75	210	146	3572100	ST under maint.
119	Sirajgonj Unit-2 225MW	NWPGL	1*150+1*75	220	199	4352364	FGMO
120	Sirajgonj Unit-3 225MW	NWPGL	1*141	2			