

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	199	4859800	
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	200	4817000	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	70	1563296	
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	107	2481909	
5	Haripur G1PP	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	355	8408768	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*236+1*125	360	352	8111000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9925250	
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	100	1525440	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	290	6746444	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	100	835584	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	757244	
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	100	1004352	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	352224	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	1156800	
18	Siddhirganj 335 MW CCPP	EGCB	1*217	217	0	0	Gas shortage
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.924	102	102	1625472	
20	Katpochi 52 MW PP (Sinha)	IPP	7*7.9	51	48	293760	
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	1305720	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	125	2012640	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1177600	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1114193	
25	Bosila 108MW PP(ELC)	IPP	12*8.775+1*3.5	108	43	942720	Engine problem
26	Summit Power (Madhabdi+Ashula)	SIPP, REB	3*3.67+4*8.73	80	56	1222660	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	768500	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	785200	
29	Gazipur 52 MW PP	IPP	6*8.9	52	41	912876	Engine problem
30	Tongi 50 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summ)	IPP	18*17.076	300	300	3015926	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	167	659474	Low demand
33	Bramhangoon 100 MW PP (Aggr)	IPP	100	100	10	56803	Low demand
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	51	255220	Low demand
35	Kodda 149 MW PP Unit-1 (Summ)	IPP	149	149	149	2816640	
36	Gazipur 100 MW PP	RPCL	100 MW	105	103	2480400	
<b>Dhaka area Total</b>				<b>5723</b>	<b>3924</b>	<b>7390915</b>	
37	Chattoogram TPP-1	PDB	1*210	180	90	2200000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	100	2500000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	485011	
39	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energy	20	20	0	125415	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	47	927840	
41	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	165	3914813	#1 under maint.
42	Sikalbaha 228MW PP	PDB	1*150+1*175	225	208	4963924	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	135	3035346	FGMO
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	51	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	21	705051	Transformer over load
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve
47	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	392972	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	50	797260	Low demand
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2374280	
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	17	414288	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	30	490560	
51	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	70	1474560	Line over load
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	32640	
53	Anwara 300 MW PP (United)	United Group	300 MW	300	214	4446109	Transformer over load
<b>Chattoogram area Total</b>				<b>2053</b>	<b>1323</b>	<b>2928069</b>	
54	Ashuganj TPP Unit-3	APSCL	1*150	135	135	3242608	
	Ashuganj TPP Unit-4	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
55	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	214	4718000	FGMO
56	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	300	5490400	FGMO
57	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	320	7570000	FGMO
58	Ashuganj 50 MW PP	APSCL	14*3.968	45	33	761888	Engine problem
59	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	51	1178400	
60	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
61	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	150	2793454	Gas shortage
62	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	969696	Engine problem
63	Ashuganj 150MW PP (Midland)	IPP	23*1.015	150	50	2708145	Transformer over load
64	B.Baraka (Aggreko) 85MW	QRPP	8*6.110	85	0	0	Contract Expired
65	Pitas 50 MW Peaking PP	PDB	6*8.92	50	50	279928	
66	Chandpur 150 MW CCPP	PDB	1*108+1*57	163	142	3315090	
67	Chandpur 200MW (Desh energy)	IPP	0	200	200	4464960	
68	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	375732	
69	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	190800	
**	Impoport (Tripura)	Imported power	0	160	182	3571200	
70	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	745800	
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	1034544	
72	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	14	309270	Engine problem
73	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	120	585600	Low demand
<b>Cumilla Area Total</b>				<b>2891</b>	<b>2120</b>	<b>44305315</b>	
74	RPCL 210MW CCPP	IPP	4*35+1*70	202	144	3108680	GT-1 under maint.
75	Tangali 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	412092	
76	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	95	91	2196480	
77	Sarishabari 3 MW Solar Plant	IPP	3	3	0	12900	
78	Mymensingh 200 MW PP (United)	IPP	200	200	36	1658400	Engine problem
79	Jamalpur 115 MW PP (United)	IPP	115 MW	115	78	2278800	Engine problem
<b>Mymensingh Area Total</b>				<b>637</b>	<b>371</b>	<b>9667352</b>	
80	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	55	1277000	
81	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	63	1493160	
82	Kushia 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3224307	
83	Shahjibazar 330 MW CCPP	PDB	3*110	330	159	3685000	GT-2 under maint.
84	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	50	1166400	
85	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	1145808	
86	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	0	215136	Engine problem
87	Shahjibazar G1PP Unit- 8 & 9	PDB	2*35	66	61	1453824	FGMO
88	Shahjibazar 86MW PP (Shahjibaz)	RPP	32*2.90	86	77	1721280	
89	Shahjibazar 30MW PP (EPL)	RPP	27*2.0	50	43	985320	Engine problem
90	Sylhet 150 MW CCPP	PDB	1*142	142	117	2563190	FGMO
91	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Engine problem
92	Sylhet 50MW PP (EPL)	RPP	27*2	50	45	995900	Engine problem
93	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	491784	Engine problem
94	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	315	7409300	FGMO
95	Bibiyan-III 400 MW CCPP	PDB	285 MW	285	0	0	Under maint.
96	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	186120	
<b>Sylhet Area Total</b>				<b>1834</b>	<b>1222</b>	<b>28013529</b>	
97	Bheramara G1PP Unit-1,2 & 3	PDB	3*20	46	32	215100	
**	Bheramara (HVDC)	Imported power	2*500	1000	695	18246545	Load restricted by India
	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
98	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	115	2303040	
99	Fanipur 50 MW Peaking PP	PDB	8*6.89	54	38	420000	
100	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
101	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	50	620257	
102	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Under maint.
103	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	33	642000	Engine problem
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
104	Noapara 100 MW PP (Bangla Tra)	IPP	70*1.4	100	100	944640	
105	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	88	2021280	Engine problem
106	Madhumati 100 MW PP	IPP	100 MW	105	87	2023344	Engine problem
<b>Khulna Area Total</b>				<b>2314</b>	<b>1238</b>	<b>27436206</b>	
107	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1612800	
108	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	38110	Reserve
109	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	36	650363	
110	Bhola 225 MW CCPP	PDB	2*63+1*68	194	84	2014124	
111	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	98	2282078	
<b>Barisal Area Total</b>				<b>462</b>	<b>328</b>	<b>6597475</b>	
112	Baghabari 71 MW GTTP	PDB	1*71	71	60	1365000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
113	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	680232	
114	Bera 70 MW Peaking PP	PDB	9*8.29	71	13	106430	
115	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	40	852910	Engine problem
116	Katakhati 50 MW PP (Northern)	QRPP	6*8.9	50	42	363320	Engine problem
117	Katakhati 50 MW Peaking PP	PDB	6*8.7	50	41	803114	
118	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	195	4678800	FGMO
119	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	198	4643673	FGMO
120	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	206	4994645	FGMO
121	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	282	6791272	Frequency control.
122	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	143020	Reserve
123	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	510000	
124	Bogra 20 MW PP (Energyprima)	RPP	5*3.9+5*2	10	14	331416	
125	Ullasra 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	232832	
126	Natore 52 MW PP (Rajbanshi)	IPP	6*8.92	52	52	791040	
127	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	85	1317228	
128	Baghabari 200 MW PP (Paramou)	IPP	200 MW	200	0	0	Reserve
129	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2579040	
<b>Rajshahi Area Total</b>				<b>2070</b>	<b>1424</b>	<b>3181772</b>	
130	Barapukuria TPP Unit-1	PDB	1*125	85	20	541964	Synchronized at 20.40.
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.
131	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	199	4845200	
132	Rangpur 20 MW GTTP	PDB	1*20	20	0	0	Under maint.
133	Saidpur 20 MW GTTP	PDB	1*20	20	17	90000	
	Rangpur 113 MW PP (Confidence)	IPP	113 MW	0	0	330240	On test
<b>Rangpur Area Total</b>				<b>484</b>	<b>236</b>	<b>5807404</b>	
<b>Total</b>				<b>18468</b>	<b>12186</b>	<b>256280037</b>	
<b>Eastern Grid Total</b>				<b>13138&lt;/</b>			