

Date : 30-Aug-19							Page -2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	70	1560000	
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	0	3693800	Gas shortage
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	110	2740500	
2	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	380	8451927	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	35	246177	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	88	442227	Engine problem
5	Haripur GTTP	IPP	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	363	8724480	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	351	7586000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	370	8679125	Machine problem
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	100	100	667200	
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	280	6751127	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	100	530040	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	121212	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	50	250796	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	466920	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	22	183000	Synchronized at 20.52.
17	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
18	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	75	199680	Low demand
19	Siddhirgonj 335 MW CCGP	EGCB	1*217	217	0	1763891	
	Pagla (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	101	810720	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	46	835680	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	867240	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1347840	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	661258	Low demand
24	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	404216	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1304640	Engine problem
26	Summit Power,(Madhabdi+Ashulla)	SIPP,REB	3*3.67+4*8.73	80	40	1041900	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	805900	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	768500	
29	Sazipur 52 MW PP	IPP	6*8.9	52	51	1110156	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	1934510	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	130	1386720	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	88	2311536	Engine problem
Dhaka area Total				5693	3576	68658917	
37	Chattogram TPP-1	PDB	1*210	180	90	2200000	Gas shortage
38	Chattogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
39	Racozan 25 MW PP	IPP	3*8.9	25	25	297856	
40	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	118530	
41	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	1049760	
42	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	210	4922282	
43	Sikalbaha 225MW	PDB	1*150+1*175	225	178	4831259	FGMO
44	Sikalbaha Peaking GT	PDB	1*150	150	100	3066318	FGMO
45	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
48	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	82	618585	
49	Juidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	268440	Low demand
50	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1948800	
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	494400	
52	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	40	852000	
53	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	90	1188480	Engine problem
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	30360	
55	Arwara 300 MW PP (United)	IPP	300 MW	300	160	3525272	Line OIL
56	Jodiach Power	IPP	54.36	0	31	56617	on test
57	Karnaphuli Power Ltd.	IPP	110	110	17	312798	Line OIL
Chattogram area Total				2112	1324	2860757	
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
59	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
60	Ashuganj TPP Unit- 5	APSCL	1*150	134	135	2855130	
61	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	162	6430000	FGMO
62	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	330	8100800	FGMO
63	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	240	3693000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	683424	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	54	1273440	
66	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
67	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	55	819636	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	854642	Engine problem
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	100	1068872	Transformer overload.
70	B.Barua (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
71	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	39240	Reserve
72	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	132	3143760	
73	Chandpur 200MW (Desh energy)	IPP	0	200	200	3000960	
74	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	439416	
75	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	246060	
76	Impoort (Tripura)	Imported power	0	160	186	3819840	
77	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818000	
78	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	317299	
79	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	512050	Engine problem
80	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1802	38115569	
81	RPCL 210MW CCGP	IPP	4*35+1*70	202	153	3510480	Gas shortage
82	Tangali 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	508392	
83	Jamailpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	2269440	
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10000	
85	Mymensingh 200 MW PP (United)	IPP	200	200	200	2263200	
86	Jamailpur 115 MW PP (United)	IPP	115 MW	115	106	2560800	
Mymensingh Area Total				637	576	1122312	
87	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	97	70	1412000	
88	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	31	686520	
89	Kushiana 163 MW CCGP (KP)	IPP	1*108+1*54	163	100	3014861	
90	Shajibazar 330 MW CCGP	PDB	3*110	330	144	3284000	GT-2 under maint.
91	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	49	993000	
92	Fenchuganj 44MW (Energyprima)	RPP	12*3.345*2	44	48	1022184	
93	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	250416	
94	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1566528	FGMO
95	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	77	1775040	Engine problem
96	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	46	1020960	
97	Sylhet 150 MW CCGP	PDB	1*142	142	70	1927660	
98	Sylhet 20 MW GTTP	PDB	1*20	20	18	426866	
99	Sylhet 50MW PP (EPL)	RPP	27*2	50	46	991680	
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	565368	
101	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	310	7565500	FGMO
102	Bibiana-III 400 MW CCGP	PDB	285 MW	285	0	0	Test
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	245700	
Sylhet Area Total				1834	1109	26748283	
104	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
105	Bheramara (HVDC)	Imported power	2*500	1000	896	21602909	
106	Khulna 115 MW PP (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
107	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1019520	
108	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	25	352800	
109	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
110	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	51	653440	
111	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	320	8662048	Frequency control
112	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	381375	
113	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
114	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	698940	
115	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	1532640	
116	Madhumati 100 MW PP	IPP	100 MW	105	101	2280656	
Khulna Area Total				2314	1753	37185228	
117	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1132600	
118	Barisal GT PP Unit-1&2	PDB	2*20	30	0	0	Reserve
119	Bhida 33 MW PP (Venture)	RPP	1*34.50	33	39	683273	
120	Bhida 225 MW CCGP	PDB	2*63+1*168	194	168	4322114	
121	Bhida 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	2165338	
Barisal Area Total				462	414	8303625	
122	Baghabari 71 MW GTTP	PDB	1*71	71	55	1330000	
123	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
124	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	341976	
125	Bera 70 MW Peaking PP	PDB	9*8.29	71	25	165603	
126	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	50	474410	
127	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	42	996927	Engine problem
128	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	38	331437	
129	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	167	4754091	FGMO
130							