

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 31-Aug-19

Page -2

Sl No.	Name of the Power Stations	Producer	Installed Capacity	Presen	Peak	Enerrv	Remarks
				Capaci tv	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	70	155000	
	Ghorasal Repowered CAPP Unit-3	PDB	1*210	170	0	0	Gas shortage
	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	110	2601900	
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	380	8201500	
3	Ghorasal 78.5 MW PPI(MAX)	QRPP	2*40	78	50	1453536	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	92	2060590	Engine problem
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Gas shortage
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	345	8601600	FGMO
7	Haripur 360MW CAPP(HPL)	IPP	1*235+1*125	360	350	8035000	
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	370	8625625	Machine problem
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	93	765120	Engine problem
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	260	6720349	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	95	474168	
12	Madanganj 55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	42	303741	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	70	528408	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	427536	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	65	1521000	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	70	545280	Low demand
18	Siddhirgonj 335 MW CAPP	EGCB	1*217	217	12	84473	Gas shortage
	Paga (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
19	Gaganagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1136304	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	42	497616	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	1173960	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1536480	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	927283	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	614264	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1724160	Engine problem
26	Summit Power (Madhabdi+Ashulla)	SIPP, REB	3*3.67+4*8.73	80	46	1154760	Engine problem
27	Misna 33 MW PP(Summit)	SIPP	4*8.33	33	33	749700	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.33	33	33	730100	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	1238604	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	195	1500436	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*230+95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	133	2157120	
36	Gazipur 100 MW PP	RPCL	100 MW	105	89	2100168	Engine problem
Dhaka area Total				5693	3568	68750781	
37	Chattoagram TPP-1	PDB	1*210	180	90	2100000	Gas shortage
	Chattoagram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	567794	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Ene	20	20	0	98000	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	32	702240	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	207	4863787	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	205	4891825	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	130	2790912	FGMO
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+	0	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
47	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	667062	
48	Jaldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	30	302280	Low demand
49	Jaldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2273280	
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	509964	
51	Nitachona, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	22	5436360	
52	Chattoagram 108 MW PP (ECPV)	IPP	6*7	108	75	631680	Engine problem
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	36480	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	178	3450000	Line O/L
55	Jodiac Power	IPP	54.36	0	0	0	on test
56	Karnaphuli Power Ltd.	IPP	110	110	17	433234	Line O/L
Chattoagram area Total				2112	1338	27761598	
57	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
58	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
59	Ashuganj TPP Unit- 5	APSCL	1*150	134	100	2544572	
60	Ashuganj 225 MW CAPP	APSCL	1*142+1*175	221	161	4498000	FGMO
61	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	345	8061100	FGMO
62	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	240	5608500	FGMO
63	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	663696	Engine problem
64	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	53	1228320	
65	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
66	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	55	1338181	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1020864	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	70	1438545	Transformer overload.
69	B Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	62464	Reserve
71	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	132	3133430	
72	Chandpur 200MW (Desh energy)	IPP	0	200	200	3679200	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	371700	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	242820	
75	Imporpt (Tripura)	Imported power	0	160	192	3765280	
76	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.33	33	33	8087400	
77	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	361430	
78	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	516320	Engine problem
79	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1758	39361122	
80	RPCL 210MW CAPP	IPP	4*36+1*70	202	144	3504040	Gas shortage
81	Tangali 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	515844	
82	Jamapur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1946880	
83	Sarshabari 3 MW Solar Plant	IPP	1*3	3	0	4300	
84	Mymensingh 200 MW PP (United)	IPP	200	200	170	2630400	
85	Jamapur 115 MW PP (United)	IPP	115 MW	115	115	2648400	
Mymensingh Area Total				637	546	11249864	
86	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	59	1422000	
87	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	31	744000	
88	Kushnara 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3366196	
89	Shahjibazar 330 MW CAPP	PDB	3*110	330	240	4152000	GT-2 under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	46	1032000	
91	Fenchugonj 44MW (Energyprima)	RPP	12*3.34+5*2	44	49	1131336	
92	Shahjibazar 11MW PP (Confidence-E)	SIPP, REB	4*2.90	11	11	247584	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	66	1557504	FGMO
94	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	82	1705920	
95	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	46	1017720	
96	Syhet 150 MW CAPP	PDB	1*142	142	71	1854640	
97	Syhet 20 MW GTTP	PDB	1*20	20	18	436000	
98	Syhet 50MW PP (EPL)	RPP	27*2	50	46	997320	
99	Shahjahanilla 25 MW PP	SIPP, REB	3*9.34	25	24	535032	
100	Bisnaya-III 341 MW CAPP (Summit)	IPP	1*222+1*119	341	285	7515800	FGMO
101	Bisnaya-III 400 MW CAPP	PDB	285 MW	285	0	0	Test
102	Syhet 10MW PP (Desh)	RPP	6*1.95	10	10	246600	
Syhet Area Total				1834	1247	27961652	
103	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
104	Bheramara (HVDC)	Imported power	2*500	1000	913	21813090	
105	Khulna 115 MW PP (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
106	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	115	1837440	
107	Fandipur 50 MW Peaking PP	PDB	8*6.89	54	25	265920	
108	Khulna 225 MW CAPP	NWP/GCL	1*150+1*75	230	0	0	Reserve
109	Amnara 50 MW PP(Sinha)	QRPP	7*7.9	50	50	451800	
110	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	42	770235	Engine problem
111	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	40	578333	
112	Sirajgonj Unit-1 225MW	NWP/GCL	1*150+1*75	210	192	5027945	FGMO
113	Sirajgonj Unit-2 225MW	NWP/GCL	1*150+1*75	220	0	0	Gas shortage
114	Sirajgonj Unit-3 225MW	NWP/GCL	1*141	220	189	5085873	FGMO
115	Sirajgonj 400 MW CAPP Unit-4	SNWP/GCL	1*282+1*132	414	370	8875909	
116	Santahar 50 MW Peaking PP	PDB	6*8.7	50	28	200769	
117	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	511200	
118	Bogura 22 MW PP (Energyprima)	RPP	5*3.34+5*2	10	7	167600	Engine problem
119	Ullaspara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	226512	
120	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	650400	
121	Chapainawabganj 100 MW Peaking PP	PDB	12*8.924	104	93	1006920	
122	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve
123	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2150880	
Rajshahi Area Total				2070	1324	27472873	
124	Barapukuria TPP Unit-1	PDB	1*125	85	71	1716218	
125	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.
126	Barapukuria 275 MW TTP Unit-3	PDB	1*275	274	270	7286000	
127	Rangpur 20 MW GTTP	PDB	1*20	20	0	0	Under maint.
128	Saidpur 20 MW GTTP	PDB	1*20	20	0	0	Reserve
129	Rangpur 113 MW PP (Confidence)	IPP	113 MW	1			