

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	70	1568000	
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	0	0	Gas shortage
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	180	4432000	
	Ghorasal TPP Unit-5	PDB	1*210	190	110	2614500	
2	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	350	7734191	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	20	1287328	Transformer overload.
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	74	1911090	Transformer overload.
5	Haripur GTPP	SBU, PDB	2*92	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	360	8895490	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	321	7690000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	390	9018250	
9	Meghnaghat 100 MW (IEL)	QRPP	1*210	100	100	1275840	
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	260	6322240	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	97	673872	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	42	552712	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	40	738696	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	373104	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	85	811200	Engine problem
18	Siddhirgonj 335 MW CCGP	EGCB	1*217	217	11	816291	Gas shortage
	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
19	Gaggaraj 102 MW PP (Digital Power)	IPP	12*8.924	102	101	1421712	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	47	491	Engine problem
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	1123668	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1078080	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	707755	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	565057	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1571520	Engine problem
26	Summit Power (Madhabadi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	55	1242420	Engine problem
27	Misna 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	671700	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	669900	
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	843012	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	1457781	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	393555	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	71521	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	135	2161440	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	70	1680756	Engine problem
<b>Dhaka area Total</b>				<b>5693</b>	<b>3705</b>	<b>72375172</b>	
37	Chattogram TPP-1	PDB	1*210	180	90	2100000	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	296497	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	108000	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	32	686400	
41	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	210	4826596	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4953990	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	130	2295235	FGMO
	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired
44	Sikalbaha 105 MW PP (Baraka Sikalba)	IPP	105 MW	105	0	46000	Transformer overload.
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	568	Under S/D
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	68	372758	
47	Juldah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	10	257520	Line O/L
48	Juldah 100 MW Unit-3 (Acom)	IPP	0	100	100	2175360	
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	497616	
50	Malancha, Ctg. EPZ (Unlied)	IPP	5*8.73+3*9.34	0	32	480960	
51	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97	1131640	Line O/L
52	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	28920	
53	Arwara 300 MW PP (Unlied)	IPP	300 MW	300	143	3121309	Transformer overload.
54	Jodiac Power	IPP	3*18.55+1*3.6	54	54	596707	
55	Karnaphuli Power Ltd.	IPP	110	110	17	294398	Transformer overload.
<b>Chattogram area Total</b>				<b>2166</b>	<b>1353</b>	<b>2716674</b>	
56	Ashuganj TPP Unit-3	APSCl	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCl	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCl	1*150	134	100	2404320	Gas shortage
58	Ashuganj 225 MW CCGP	APSCl	1*142+1*75	221	217	4656000	FGMO
57	Ashuganj 450 MW CCGP(North)	APSCl	1*360	360	300	7949300	FGMO
58	Ashuganj 450 MW CCGP(South)	APSCl	1*360	360	300	4650000	FGMO
59	Ashuganj 50 MW PP	APSCl	14*3.968	45	33	651816	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1093920	
61	Ashuganj 53MW PP (Unlied)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCl-Unlied)	IPP	20*9.73+1*16	195	125	2057454	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	968790	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	100	1055490	Transformer overload.
65	B.Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	97624	
67	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	0	977080	Under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	193	3396960	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	429624	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	214380	
**	Impoort (Tripura)	Imported power	0	160	166	3649920	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818000	
72	Jangalia 52 MW PP (Lakdanawi)	IPP	6*8.92	52	52	491746	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	473860	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	99840	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1763</b>	<b>36736124</b>	
75	RPCL 210MW CCGP	IPP	4*35+1*70	202	138	3128250	Gas shortage
76	Tangali 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	431316	
77	Jamailpur 95 MW PP (Powerpac)	IPP	12*8.924	95	95	1699720	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	9250	
79	Mymensingh 200 MW PP (Unlied)	IPP	200	200	197	2592000	
80	Jamailpur 115 MW PP (Unlied)	IPP	115 MW	115	115	2644800	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>567</b>	<b>10492336</b>	
81	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	60	1411000	
82	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	43	918240	
83	Kushiana 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3304661	
84	Shajibazar 330 MW CCGP	PDB	3*110	330	240	5493000	GT-2 under maint.
85	Fenchugonj 51 MW PP (Barakattulah)	RPP	19*2.90	51	49	987000	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	48	1028232	
87	Hobiganj 11MW PP Cofidence-E	SIPP, REB	4*2.90	11	11	192624	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	61	1488960	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	79	1493760	Engine problem
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	45	875160	
91	Syhet 150 MW CCGP	PDB	1*142	142	70	1904910	
92	Syhet 20 MW GTTP	PDB	1*20	20	18	427000	
93	Syhet 50MW PP (EPL)	RPP	27*2	50	46	967860	Engine problem
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	462600	
95	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	270	7389000	FGMO
96	Bibiana-III 400 MW CCGP	PDB	285 MW	285	0	0	Test
97	Syhet 10MW PP (Desh)	RPP	6*1.95	10	0	239940	Tripped.
<b>Syhet Area Total</b>				<b>1834</b>	<b>1219</b>	<b>28583947</b>	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	906	21846545	
	Khulna 115 MW PP (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1351680	
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	30	299520	
101	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	60	380160	
103	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	330	6631648	Line O/L
104	Neapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.15	40	33	531375	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
105	Neapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	549120	
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	90	1845600	
107	Medhatmat 100 MW PP	IPP	100 MW	105	102	2193744	
<b>Khulna Area Total</b>				<b>2314</b>	<b>1766</b>	<b>37635392</b>	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1084800	
109	Barisal GT PP Unit-1&2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	32	606089	
111	Bhola 225 MW CCGP	PDB	2*63+1*68	194	167	2498096	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	1974345	
<b>Barisal Area Total</b>				<b>462</b>	<b>406</b>	<b>6163330</b>	
113	Baghabari 71 MW GTTP	PDB	1*71	71	55	1315000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	297312	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	37	209078	
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	50	443050	
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	34	612482	Engine problem
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	38	326222	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	182</		