

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1604000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	170	4488000	
	Ghorasal TPP Unit-5	PDB	1*210	190	190	3536000	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	270	2290609	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	1045856	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	12	1728136	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	339	8067070	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	244	6944900	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	300	7946850	Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	7	288960	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	120	3055069	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	15	169536	Low demand
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	0	57851	Reserve
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	209071	Reserve
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	357696	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	98880	Reserve
18	Siddhirganj 335 MW CCPP	EGCB	1*217	217	337	8147231	
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.924	102	64	625968	Low demand
21	Katpochi 52 MW PP (Sinha)	IPP	7*7.9	51	46	344736	Engine problem
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	1252080	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	2106240	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	940488	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	861591	
26	Bosila 108MW PP(ELC)	IPP	12*8.775+1*3.5	108	66	1479360	Engine problem
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	55	1221000	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	783200	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	30	609400	
30	Gazipur 52 MW PP	IPP	6*8.9	52	52	741768	Engine problem
31	Tongi 90 MW GTTP	IPP	1*105	105	0	0	Gas shortage
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	16*17.076	300	45	313636	Low demand
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
34	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	135	947520	Engine problem
37	Gazipur 100 MW PP	RPCL	100 MW	105	88	2101332	
<b>Dhaka area Total</b>				<b>5693</b>	<b>3006</b>	<b>64363134</b>	
37	Chattoogram TPP-1	PDB	1*210	180	95	2200000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	194376	
39	Teknaf 20MW PP (Solartech) Teknaf Solartech Energy		20	20	0	66420	
40	Patenga 50MW PP (Baraka)	IPP	6*6.96	50	50	817920	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	213	4653036	
42	Sikalbaha 228MW	PDB	1*150+1*175	225	207	4898469	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	140	2365412	
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Sil)	IPP	105 MW	105	0	0	Reserve
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	40312	
47	Dohazari -Kalash 100 MW Peakin	PDB	6*17	102	68	278250	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	256920	Line O/L
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1855680	
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	50328	
51	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	36	496800	
52	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	92	697920	
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	19080	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	107	2280763	Transformer overload.
55	Jodiack Power	IPP	3*18.55+1*3.6	54	34	929292	Transformer overload.
56	Kanapathuli Power Ltd	IPP	1*10	17	17	236980	Transformer overload.
<b>Chattoogram area Total</b>				<b>2166</b>	<b>1336</b>	<b>25437668</b>	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	80	2594662	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	196	4626000	
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	350	8027500	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	290	7505000	
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	681264	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	1135200	
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	55	886545	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	953256	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	10	510182	Transformer overload.
65	B Bara (Aggreko)	QRPP	86*1.10	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	30704	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	100	2366500	
68	Chandpur 200MW (Desh energy)	IPP	0	200	175	2822400	Engine problem
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	442872	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	167940	
**	Impoport (Tripura)	Imported power	0	160	178	3463680	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818000	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	522706	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	483680	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1691</b>	<b>38038091</b>	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	106	3050120	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	495072	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1984320	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11000	
79	Mymensingh 200 MW PP (United)	IPP	200	200	180	2107200	Line O/L
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	95	2276400	Engine problem
<b>Mymensingh Area Total</b>				<b>637</b>	<b>498</b>	<b>9924112</b>	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	60	1256000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	41	953280	
83	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	100	3091450	Frequency Control
84	Shajibazar 330 MW CCPP	PDB	3*110	330	242	5525000	
85	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	50	880200	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	95688	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	181152	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	64	1539456	FGMO
89	Shajibazar 86MW PP (Shajibaz)	RPP	32*2.90	86	77	1446720	
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	45	1006200	
91	Sylhet 150 MW CCPP	PDB	1*142	142	119	2335740	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	441000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	45	1020980	Engine problem
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	571584	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	305	7259450	FGMO
96	Bibiana-III 400 MW CCPP	PDB	285 MW	285	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	252000	
<b>Sylhet Area Total</b>				<b>1834</b>	<b>1260</b>	<b>27859900</b>	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	903	21691636	
99	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
100	Khulna 115 MW PP (KPCL-2)	IPP	19*6.5	115	115	1098240	
101	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	37	274080	
102	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	60	365568	
104	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	390	8186976	Frequency Control
105	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	406875	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
106	Noapara 100 MW PP (Bangla Tra)	IPP	70*1.4	100	100	513600	
107	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	105	1484160	
108	Madhumati 100 MW PP	IPP	100 MW	105	86	1720944	Engine problem
<b>Khulna Area Total</b>				<b>2314</b>	<b>1836</b>	<b>35742079</b>	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	761280	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	38	654300	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	179	4305551	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	2041991	
<b>Barisal Area Total</b>				<b>462</b>	<b>423</b>	<b>7763122</b>	
113	Baghabari 71 MW GTTP	PDB	1*71	60	60	1365000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	228104	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	30	121006	
116	Annura 50 MW PP(Sinha)	QRPP	7*7.79	50	6	162210	Engine problem
117	Katakhalai 50 MW PP (Northern)	QRPP	6*8.9	50	42	791565	Engine problem
118	Katakhalai 50 MW Peaking PP	PDB	6*8.7	50	37	166038	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	200	4764845	FGMO
120	Sirajgonj Unit-2 225MW	N					