

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1633000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	100	2779000	Gas shortage
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4536000	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	280	6475336	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	84681	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	348	8697860	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	303	7542000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	350	8800250	Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	74	285120	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3358836	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	48	282456	Low demand
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	101568	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	10	115592	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	426492	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirganj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	7	110400	Low demand
18	Siddhirganj 335 MW CCPP	EGCB	1*217	217	0	1108182	Under maint.
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.92	102	101	682520	
21	Katpuchi 52 MW PP (Sinha)	IPP	7*7.9	51	46	266976	Engine problem
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	35	963720	Engine problem
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	135	1157760	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	867906	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	949446	
26	Bosila 108MW PP(ELC)	IPP	12*8.775+1*3.5	108	72	1340160	Engine problem
27	Summit Power (Madhabdi+Ashulha)	SIPP, REB	3*3.67+4*8.73	80	56	1293540	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	786100	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	805100	
30	Gazipur 52 MW PP	IPP	6*8.9	52	52	1017228	
31	Tongi 90 MW GTPP	IPP	1*108	105	0	0	Gas shortage
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	150	659890	Low demand
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
34	Bramhangaoan 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	150	904320	
37	Gazipur 100 MW PP	RPCL	100 MW	105	88	207996	Engine problem
Dhaka area Total				5693	3088	6011435	
37	Chattoogram TPP-1	PDB	1*210	180	95	2300000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	25	207799	
39	Teknaf 20MW PP (Solartech)Teknaf Solartech Energy			20	0	24435	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	18	684000	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	212	4694514	
42	Sikalbaha 228MW	PDB	1*150+1*175	225	203	4874982	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	100	2407888	
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Reserve
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve
47	Dohazari -Kalash 100 MW Peakin	PDB	6*17	102	66	235191	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	264640	Line O/L
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1560000	
50	Barabakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	518112	
51	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	43	711840	
52	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	65	741120	Low demand
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	27840	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	125	2795127	Transformer overload.
55	Jiodac Power	IPP	3*18.55+1*3.6	54	34	693359	Transformer overload.
56	Kanapuhuli Power Ltd	IPP	1*10	17	17	170817	Transformer overload.
Chattoogram area Total				2166	1255	26030964	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	15	118632	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	80	1923456	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	181	4601000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	330	7796800	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	305	7115500	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	33	684792	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	52	1073760	
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	55	501818	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	908764	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	100	782673	Transformer overload.
65	B Bara (Aggreko)	QRPP	86*1.10	86	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	32480	Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	100	2333858	
68	Chandpur 200MW (Desh energy)	IPP	0	200	182	2086080	Engine problem
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	456408	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	198900	
**	Impoport (Tripura)	Imported power	0	160	174	3608640	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	817100	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	493080	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	489730	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1787	36033671	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	124	2597580	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	416440	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1894080	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12100	
79	Mymensingh 200 MW PP (United)	IPP	200	200	195	1850400	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	105	2191200	Engine problem
Mymensingh Area Total				637	541	8962108	
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	58	1414000	
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	41	945000	
83	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3267965	
84	Shajibazar 330 MW CCPP	PDB	3*110	330	240	5369000	
85	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	47	1104000	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	114408	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	240912	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	66	1550784	FGMO
89	Shajibazar 86MW PP (Shajibaz)	RPP	32*2.90	86	77	1722240	
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	50	45	1007280	
91	Sylhet 150 MW CCPP	PDB	1*142	142	110	2707960	FGMO
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	435000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	44	1010000	Engine problem
94	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	24	546888	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	300	7261000	FGMO
96	Bibiana-III 400 MW CCPP	PDB	285 MW	285	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	240120	
Sylhet Area Total				1834	1303	28936557	
**	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	905	21773818	
98	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	804480	Engine problem
100	Fanjipur 50 MW Peaking PP	PDB	8*6.89	54	28	355680	
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	67	565504	
103	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	300	8261856	Frequency Control
104	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	364500	
105	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
106	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	100	556800	
107	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	90	1277760	Engine problem
108	Madhumati 100 MW PP	IPP	100 MW	105	103	1832544	
Khulna Area Total				2314	1748	35792942	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	953376	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	36	635641	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	178	4293040	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	2165354	
Barisal Area Total				462	421	8647411	
113	Baghabari 71 MW GTTP	PDB	1*71	71	50	1325000	
114	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
115	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	285064	
116	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	14696	Reserve
117	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	6	159810	Engine problem
118	Katakhali 50 MW PP (Northern)	QRPP	6*8.9	50	42	674058	Engine problem
119	Katakhali 50 MW Peaking PP	PDB	6*8.7	50	37	315613	
120	Sirajganj Unit-1 225MW	NWPGCL	1*150+1*75	210	190	4820254	FGMO
121	Sirajganj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	Gas shortage
122	Sirajganj Unit-3 225MW	NWPGCL	1*141	220	193	4863809	FGMO
123	Sirajganj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	370	8685636	Frequency Control
124	Santahar 50 MW Peaking PP	PDB	6*8.7	50	27	228984	
125	Bogra 22 MW PP (GSB)	RPP	6*4	22	22	511200	
126	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	7	160344	Engine problem
127	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	242748	
128	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	332640	
129	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	95	1079252	Engine problem
130	Baghabari 200 MW PP (Paramout	IPP	200 MW	200	0	0	Reserve
131	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2279328	
Rajshahi Area Total				2070	1265	25978536	
131	Barapukuria TPP Unit-1	PDB	1*125	85	70	1645963	
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.
132	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	270	6528500	
133	Rangpur 20 MW GTTP	PDB	1*20	20	0	0	Under maint.
134	Saidpur 20 MW GTTP	PDB	1*20	20	16	152000	
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	90	1552320	Engine problem
136	Sympa Solar Power 8MW	IPP	8 MW	8	0	25150</	