

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1622000	
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	179	1648500	Gas shortage
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	1569000	Gas shortage
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4441500	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	320	6411473	Gas shortage
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur G1PP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	344	8503610	FGMO
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	351	7648000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	370	8599800	Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	7	32640	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3487302	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	0	18384	Reserve
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	34449	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	0	Reserve
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	406728	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	0	Reserve
18	Siddhirgonj 335 MW CCPP	EGCB	1*217	217	300	3046128	
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired
20	Gaiganj 102 MW PP (Digital Po)	IPP	12*8.924	102	74	754272	Low demand
21	Katpochi 52 MW PP (Sinha)	IPP	7*7.9	51	27	389952	Low demand
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	993600	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	135	2232960	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	941866	
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1075729	
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1450560	Engine problem
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	56	1308300	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	736400	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	805000	
30	Gazipur 52 MW PP	IPP	6*8.9	52	34	740280	Engine problem
31	Tongi 90 MW GTTP	IPP	1*105	105	0	0	Gas shortage
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	0	42655	Plant under maint.
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
34	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	100	735840	Low demand
	Gazipur 100 MW PP	RPCL	100 MW	105	70	1688568	Engine problem
Dhaka area Total				5693	3098	61367496	
37	Chattoogram TPP-1	PDB	1*210	180	95	2000000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	16	88715	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy		20	0	30375	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	798240	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	212	4925733	
42	Sikalbaha 228MW	PDB	1*150+1*175	225	204	4878320	
43	Sikalbaha Peaking GT	PDB	1*150	150	100	2404675	FGMO
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+3*11.5	0	0	0	Contract Expired
45	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	22581	Reserve
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve
47	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	108047	
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	253800	Line O/L
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1916160	
	Barabakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	519264	
	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	10	469920	
50	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	51	443520	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	15840	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	124	2800145	Transformer overload.
53	Jadac Power	IPP	3*18.55+1*3.6	54	18	668372	
54	Karnaphuli Power Ltd	IPP	1*10	10	0	22581	Transformer overload.
Chattoogram area Total				2166	1183	25662288	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2155148	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	182	4754000	FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	300	7636900	FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	300	7222500	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	605664	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	52	1234560	Engine problem
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	16	418181	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	30	891160	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	50	376363	Transformer overload.
65	B Bara (Aggreko)	QRPP	86*1.10	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	0	
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	136	2705540	
68	Chandpur 200MW (Desh energy)	IPP	0	200	160	2359200	Engine problem
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	502560	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	174420	
**	Impoort (Tripura)	Imported power	0	160	162	3351360	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	738900	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	320678	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	431008	Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1635	35878142	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	106	2732880	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	4797480	
77	Fariapur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1284480	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	5900	
79	Mymensingh 200 MW PP (United)	IPP	200	200	150	1754400	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2678400	
Mymensingh Area Total				637	486	8935760	
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	60	1424000	
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	41	979200	
83	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	100	3020506	Frequency Control
84	Shajibazar 330 MW CCPP	PDB	3*110	330	243	5463000	FGMO
85	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	47	947400	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	48	1068192	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	229008	
88	Shajibazar GTPP Unit- 8 & 9	PDB	2*35	66	52	1568640	FGMO
89	Shajibazar 86MW PP (Shajibaz)	RPP	32*2.90	86	78	1631040	Engine problem
90	Shajibazar 50MW PP (EPL)	RPP	27*2.0	46	46	959760	
91	Sylhet 150 MW CCPP	PDB	1*142	142	70	2325500	FGMO
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	445000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	45	991960	Engine problem
94	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	16	390216	
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	270	7207700	FGMO
96	Bibiana-III 400 MW CCPP	PDB	285 MW	285	0	0	Under maint.
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	250020	
Sylhet Area Total				1834	1155	28901142	
98	Bheramara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	904	21755636	
99	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired
100	Khulna 115 PP MW (KPCL-2)	IPP	7*17	115	99	558800	Engine problem
101	Fariapur 50 MW Peaking PP	PDB	8*6.89	44	30	220320	
102	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	62	335232	
104	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	350	7710912	Gas shortage
105	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	354000	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
106	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	99	325440	
107	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	90	1152000	Engine problem
	Madhumati 100 MW PP	IPP	100 MW	105	103	1400256	
Khulna Area Total				2314	1777	33810596	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	759936	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	28	572220	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	166	4050745	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	95	1939922	
Barisal Area Total				462	400	7376893	
113	Baghabari 71 MW GTTP	PDB	1*71	71	0	4000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	386696	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	41	125690	
116	Annura 50 MW PP(Sinha)	QRPP	7*7.79	50	6	157460	Engine problem
117	Katakhalai 50 MW PP (Northern)	QRPP	6*8.9	50	8	364030	Engine problem
118	Katakhalai 50 MW Peaking PP	PDB	6*8.7	50	37	263205	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	192	4772291	FGMO
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75				