

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour		Generated	Remarks
					Hour	Generation		
			Unit No. X Capacity	MW	MW	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1628000		
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	178	3439200		
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.	
	Ghorasal TPP Unit-5	PDB	1*210	190	100	2318400	Gas shortage	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	170	4701845	Gas shortage	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage	
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage	
5	Haripur G1PP	SBU, PDB	2*32	40	0	152000	Engine problem	
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	363	8694100	FGMO	
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	320	7503000	Gas shortage	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9894250		
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	74	1505280	Low demand	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3512058	Gas shortage	
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	64	907824	Low demand	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	401686	Low demand	
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	10	550172	Low demand	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	282780		
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Gas shortage	
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage	
	Siddhirganj Desh	QRPP	96*1.2	0	0	0	Contract Expired	
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	7	308160	Low demand	
18	Siddhirganj 335 MW CCPP	EGCB	1*217	217	0	0	Under S/D	
19	Papia (DPA)	QRPP	100*0.5	0	0	0	Contract Expired	
20	Gaganagar 102 MW PP (Digital Po)	IPP	12*8.924	102	50	1318032	Low demand	
21	Katpatti 52 MW PP (Sinha)	IPP	7*7.9	51	45	581280	Engine problem	
22	Karnalaghat 54 MW PP(Banco En)	IPP	3*18	54	53	1292760		
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	140	1850880	Engine problem	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1115473		
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1233005		
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	1481280	Engine problem	
27	Summit Power, (Madhabdi+Ashulha)	SIPP, REB	3*3.67+4*8.73	80	50	1118220	Engine problem	
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	713400		
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	761800		
30	Gazipur 52 MW PP	IPP	6*8.9	52	43	1162804	Engine problem	
31	Tongi 90 MW GTTP	IPP	1*105	105	0	0	Gas shortage	
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	145	802909	Low demand	
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve	
34	Bramhangaan 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve	
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve	
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	62	712800	Low demand	
37	Gazipur 100 MW PP	RPCL	100 MW	105	85	2029800	Engine problem	
<b>Dhaka area Total</b>				<b>5693</b>	<b>2914</b>	<b>6179198</b>		
37	Chattoogram TPP-1	PDB	1*210	180	75	1800000	Gas shortage	
	Chattoogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
38	Raozan 25 MW PP	IPP	3*8.9	25	8	247815	Low demand	
39	Teknaf 20MW PP (Solartech) Teknaf Solartech Energy		20	20	0	67905		
40	Patenga 50MW PP (Baraka)	IPP	6*6.96	50	42	719040	Engine problem	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	175	4157565		
42	Sikalbaha 228MW	PDB	1*150+1*175	225	205	4871250	FGMO	
43	Sikalbaha Peaking GT	PDB	1*150	150	140	2785868		
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+3*11.5	0	0	0	Contract Expired	
45	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Transformer overload.	
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve	
47	Dohazari -Kalash 100 MW Peakin	PDB	6*17	102	67	366122		
48	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	257640	Line O/L	
49	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1701120		
50	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	481728		
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	41	612480		
51	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	70	693120	Low demand	
52	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	0		
53	Anwara 300 MW PP (United)	IPP	300 MW	300	107	2657127	Transformer overload.	
54	Jodac Power	IPP	3*18.55+1*3.6	54	54	1054716	Transformer overload.	
54	Kanapathuli Power Ltd	IPP	110	110	17	276935	Transformer overload.	
<b>Chattoogram area Total</b>				<b>2166</b>	<b>1131</b>	<b>2276731</b>		
55	Ashuganj TPP Unit-3	APSCL	1*150	135	130	2570307	Gas shortage	
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage	
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage	
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	192	4606000	FGMO	
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	335	8225300		
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	315	7398500	FGMO	
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	568672	Engine problem	
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	1142880		
61	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0	Contract Expired	
62	Ashuganj 195MW PP (APSCL-Ur)	IPP	20*9.73+1*16	195	8	485090	Gas shortage	
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	614854	Engine problem	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	70	817963	Transformer overload.	
65	B Bara (Aggreko)	QRPP	86*1.10	86	0	0	Contract Expired	
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	42	164400		
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	100	2226410		
68	Chandpur 200MW (Desh energy)	IPP	0	200	140	2784000	Engine problem	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	497196		
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	186300		
**	Impoport (Tripura)	Imported power	0	160	188	3715200		
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818200		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	617779		
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	379720	Engine problem	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve	
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1768</b>	<b>37836971</b>		
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	151	3134000	Gas shortage	
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	474984		
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	92	1827840		
78	Sarishabari 3 MW Solar Plant	IPP	113	3	0	13500		
79	Mymensingh 200 MW PP (United)	IPP	200	200	200	1987200		
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	107	2484000		
<b>Mymensingh Area Total</b>				<b>637</b>	<b>572</b>	<b>9921524</b>		
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	55	1397000		
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	41	852000		
83	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3229576		
84	Shajibazar 330 MW CCPP	PDB	3*110	330	190	4822000	FGMO	
85	Fenchuganj 51 MW PP (Barakatu)	RPP	19*2.90	51	50	1039800		
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	48	1111608		
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	111456		
88	Shajibazar G1PP Unit- 8 & 9	PDB	2*35	66	65	1543104	FGMO	
89	Shajibazar 85MW PP (Shajibaz)	RPP	32*2.90	86	82	1569360	Engine problem	
90	Shajibazar 65MW PP (EPL)	RPP	27*2.0	43	0	924480		
91	Sylhet 150 MW CCPP	PDB	1*142	142	119	2666850	FGMO	
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	431000		
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	43	851860	Engine problem	
94	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	24	569464		
95	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	315	6753772	FGMO	
96	Bibiyan-III 400 MW CCPP	PDB	285 MW	285	414	5474000		
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	207540		
<b>Sylhet Area Total</b>				<b>1834</b>	<b>1687</b>	<b>33574870</b>		
98	Bheramara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve	
**	Bheramara (HVDC)	Imported power	2*500	1000	910	21595636		
	Khulna 115 MW PP (KPCL-1 & 2)	IPP	19*6.5	0	0	0	Contract Expired	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1069440		
100	Fanjipur 50 MW Peaking PP	PDB	8*6.89	54	28	197280		
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve	
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	55	539264		
103	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	285	6750432	Line O/L, ST U/M.	
104	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	501750		
	Khulna (Aggreko) 55MW	QRPP	7*10.85	0	0	0	Contract Expired	
105	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	80	621120	Low demand	
106	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	90	1350720	Engine problem	
107	Madhumati 100 MW PP	IPP	100 MW	105	86	1572768	Engine problem	
<b>Khulna Area Total</b>				<b>2314</b>	<b>1689</b>	<b>34198410</b>		
108	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	16	290496	Low demand	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve	
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	38	661918		
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	171	4315971		
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	97	1839130		
<b>Barisal Area Total</b>				<b>462</b>	<b>322</b>	<b>7107515</b>		
113	Baghabari 71 MW GTTP	PDB	1*71	71	55	1210000	Gas shortage	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.	
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	379952		
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	35	164182		
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	18	264420	Engine problem	
117	Katakhalai 50 MW PP (Northern)	QRPP	6*8.9	50	42	759286	Engine problem	
118	Katakhalai 50 MW Peaking PP	PDB	6*8.7	50	45	553000		
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	177	4530273	FGMO	
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	176	4217445	FGMO	
121	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	0	0	Under maint.	
122	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	289	6272727	ST-Under maint.	
123	Santahar 50 MW Peaking PP	PDB	6*8.7	50	27	250518		
124	Bogra 22 MW PP (SBB)	RPP	6*4	22	22	457200		
125	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	0	252864	Machine tripped at 20:27.	
126	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	230490		
127	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1130400		
128	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	79	975848		
129	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve	
130	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2495232		
<b>Rajshahi Area Total</b>				<b>2070</b>	<b>1191</b>	<b>24143837</b>		
131	Barapukuria TPP Unit-1	PDB	1*125	85	71	1645964		
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.	
132	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	260	6516000		
133	Rangpur 20 MW GTTP	PDB	1*20	20	16	95000		
134	Saidpur 20 MW GTTP	PDB	1*20	20	0	0	Reserve	
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	96	1875840	Engine problem	