

Date :		21-Sep-19				Page 2		
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
			Unit No. X Capacity	MW	MW	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	73	1588000		
	Ghorasal Repowered CAPP Unit-3	PDB	1*210	170	178	4587300		
	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	0	0	Under maint.	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	75600	Under maint.	
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	251	4684145	Gas shortage	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	3*43.35	78	0	0	Gas shortage	
4	Ghorasal 108MW PP (Regent)	IPP	2*32	108	0	0	Gas shortage	
5	Haripur GTPP	SBU_PDB	2*32	40	20	321000	Engine problem	
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	349	8621640	FGMO	
7	Haripur 360MW CAPP(HPL)	IPP	1*235+1*125	360	352	7955000	Gas shortage	
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	450	9694000		
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	100	1234560		
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	150	3532131	Gas shortage	
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	80	382800	Engine problem	
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	34891		
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	88	357804	Engine problem	
14	Narsingdi 22 MW PP (Doreen)	SIPP_REB	8*2.90	22	22	459180		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage	
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	67	836000	Gas shortage	
17	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired	
18	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	50	196800	Low demand	
18	Siddhirgonj 335 MW CAPP	EGCB	1*217	217	0	0	Under S/D	
	Paglia (DPA )	QRPP	100*0.5	0	0	0	Contract Expired	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	101	1364400		
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	46	614016	Engine problem	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	1164960		
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	120	2040480	Engine problem	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1117239		
24	Nabaganj 55 MW PP (Southern powe	IPP	3*19.3	55	55	1000603		
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	66	1600320	Engine problem	
26	Summit Power,(Madhabdi+Ashulia)	SIPP_REB	3*3.67+4*8.73	80	50	1175100	Engine problem	
27	Maona 33 MW PP(Summit)	SIPP_REB	4*8.73	33	33	728200		
28	Rupganj 33 MW PP(Summit)	SIPP_REB	4*8.73	33	33	629900		
29	Saipur 52 MW PP	IPP	6*8.9	52	52	1017108		
30	Tongi 80 MW GTPP	PDB	0	1105	0	0	Gas shortage	
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	0	30100	Gas shortage	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve	
33	Bramhanganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve	
34	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1198000		
36	Gazipur 100 MW PP	RPCL	100 MW	105	103	2174256		
<b>Dhaka area Total</b>				<b>5693</b>	<b>3201</b>	<b>60929613</b>		
37	Chattogram TPP-1	PDB	1*210	180	75	1800000	Gas shortage	
38	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
39	Raozan 25 MW PP	IPP	3*8.9	25	25	209016		
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	98280		
40	Patanga 50MW PP (Baraka)	IPP	8*6.98	50	50	799680		
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	182	4232065		
42	Sikalbaha 225MW	PDB	1*150+1*175	225	206	4846634	FGMO	
43	Sikalbaha Peaking GT	PDB	1*150	150	120	2628916		
44	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired	
44	Sikalbaha 105 MW PP (Baraka Sikalba	IPP	105 MW	105	17	108726	Transformer overload.	
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve	
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	102	594957		
47	Juidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	10	256080	Line O/L	
48	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1792320		
49	Barakunda 22 MW PP (Regent)	SIPP_PDB	8*2.90	22	21	506640		
	* Malancha, Ctg. EPZ (Unlited)		5*8.73+3*9.34	0	27	539040		
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	72	1027200	Low demand	
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	0		
52	Anwara 300 MW PP (Unlited)	IPP	300 MW	300	107	2536690	Transformer overload.	
53	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1034861	Transformer overload.	
54	Karnaphuli Power Ltd.	IPP	110	110	17	438252	Transformer overload.	
<b>Chattogram area Total</b>				<b>2166</b>	<b>1185</b>	<b>23449357</b>		
55	Ashuganj TPP Unit- 3	APSCl	1*150	135	110	3064680	Gas shortage	
	Ashuganj TPP Unit- 4	APSCl	1*150	129	0	0	Gas shortage	
	Ashuganj TPP Unit- 5	APSCl	1*150	134	0	0	Gas shortage	
56	Ashuganj 225 MW CAPP	APSCl	1*142+1*75	221	218	4605000	FGMO	
57	Ashuganj 450 MW CAPP(North)	APSCl	1*360	360	320	7980900	FGMO	
58	Ashuganj 450 MW CAPP(South)	APSCl	1*360	360	360	8208500	FGMO	
59	Ashuganj 50 MW PP	APSCl	14*3.968	45	26	588168	Engine problem	
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	1173600		
61	Ashuganj 53MW PP (Unlited)	QRPP	14*4	53	0	0	Contract Expired	
62	Ashuganj 195MW PP (APSCl-Unlited)	IPP	20*9.73+1*16	195	8	217454	Gas shortage	
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	786270	Engine problem	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	60	858109	Transformer overload.	
65	B.Barua (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired	
66	Tilas 50 MW Peaking PP	PDB	6*8.92	52	42	92400		
67	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	100	1968870		
68	Chandpur 200MW (Desh energy)	IPP	0	200	160	2510400	Engine problem	
69	Feni 22MW PP (Doreen)	SIPP_PDB	8*2.90	22	21	484668		
70	Feni 11 MW PP (Doreen)	SIPP_REB	4*2.90	11	11	237960		
**	Impoort (Tripura)	Imported power	0	160	190	3577920		
71	Jangalia 33MW PP (Summit)	SIPP_PDB	4*8.73	33	33	818500		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	443947		
73	Cumilla 25 MW PP (Summit)	SIPP_PDB	3*3.67+2*6.97	25	20	357710	Engine problem	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve	
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1816</b>	<b>37975036</b>		
75	RPCL 210MW CAPP	IPP	4*35+1*70	202	149	3523120	Gas shortage	
76	Tangali 22 MW PP (Doreen)	SIPP_PDB	8*2.90	22	22	403612		
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	91	2099520		
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13750		
79	Mymensingh 200 MW PP (Unlited)	IPP	200	200	196	2272800		
80	Jamalpur 115 MW PP (Unlited)	IPP	115 MW	115	115	2755200		
<b>Mymensingh Area Total</b>				<b>637</b>	<b>573</b>	<b>11680602</b>		
81	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	60	1428000		
82	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	40	969000		
83	Kushiana 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3075644		
84	Shahbazar 330 MW CAPP	PDB	3*110	330	192	4234000	FGMO	
85	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	1039200		
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	1108800		
87	Hobiganj 11MW PP Confidence-E	SIPP_REB	4*2.90	11	8	164064		
88	Shahjibazar GTPP Unit- 6 & 9	PDB	2*35	66	61	1534752	FGMO	
89	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	82	1867200	Engine problem	
90	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	43	935640		
91	Syhet 150 MW CAPP	PDB	1*142	142	117	2378660	FGMO	
92	Syhet 20 MW GTPP	PDB	1*20	20	17	433000		
93	Syhet 50MW PP (EPL)	RPP	27*2	50	43	948520	Engine problem	
94	Shahjahanulla 25 MW PP	SIPP_REB	3*9.34	25	24	550848		
95	Bibiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	280	7175700	FGMO	
96	Bibiana-III 400 MW CAPP	PDB	285 MW	285	425	10156000		
97	Syhet 10MW PP (Desh)	RPP	6*1.95	10	10	219600		
<b>Syhet Area Total</b>				<b>1834</b>	<b>1664</b>	<b>38216628</b>		
98	Bheramara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve	
**	Bheramara (HVDC )	Imported power	2*500	1000	918	21925091		
99	Khulina 115 MW PP (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired	
99	Khulina 115 PP MW (KPCL-2)	QRPP	7*17	115	115	1301760		
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	35	336480		
101	Khulina 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Reserve	
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	62	548992		
103	Bheramara 360 MW CAPP	NWPGCL	1*278+1*132	410	250	6313248	Line O/L, ST U/M.	
104	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	373875		
104	Khulina (Aggreco) 55MW	QRPP	7*7.05	0	0	0	Contract Expired	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	720000		
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	70	1310880	Engine problem	
107	Madhumati 100 MW PP	IPP	100 MW	105	85	1751064	Engine problem	
<b>Khulina Area Total</b>				<b>2314</b>	<b>1675</b>	<b>34589430</b>		
108	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	48	380736	Low demand	
109	Barisal GT PP Unit-1&2	PDB	2*20	30	0	0	Reserve	
110	Bhda 33 MW PP (Venture)	RPP	1*34.50	33	37	664224		
111	Bhda 225 MW CAPP	PDB	2*63+1*68	194	182	4334520		
112	Bhda 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	2175859		
<b>Barisal Area Total</b>				<b>462</b>	<b>363</b>	<b>7553328</b>		
113	Baghabari 71 MW GTPP	PDB	1*71	71	55	1080000	Gas shortage	
114	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Under shut down.	
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	329432		
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	37	118323		
116	Annura 50 MW PP(Sinha)	QRPP	7*7.79	50	18	273170	Engine problem	
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	50	1138305		
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	46	1035600		
119	Siragongj Unit-1 225MW	NWPGCL	1*150+1*75	210	163	4509155	FGMO	
120	Siragongj Unit-2 225MW	NWPGCL	1*150+1*75	220	166	4406645	FGMO	
121	Siragongj Unit-3 225MW	NWPGCL	1*141	220	0	0	Under maint.	
122	Siragongj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	215	6042727	ST-Under maint.	
123	Santahar 50 MW Peaking PP	PDB	6*8.7	50	27	223601		
124	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	498000		
125	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	10	15	320184		
126	Ullapara 11 MW PP (Summit)	SIPP_REB	4*2.90	11	11	245232		
127	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1106400		
128	Chapainawabganj 100 MW Peaking PP	PDB	12*8.924	104	85	1022760		
129	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve	
130	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2540640		
<b>Rajshahi Area Total</b>				<b>2070</b>	<b>1125</b>	<b>24890174</b>		
131	Barapukuria TPP Unit-1	PDB	1*125	85	0	0	Under maint.	
132	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.	
132	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	260	6384900		
133	Rangpur 20 MW GTPP	PDB	1*20	20	16	101000		
134	Saidpur 20 MW GTPP	PDB	1*20	20	0	0	Reserve	
135	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	113	1863360		
136	Sympa Solar Power 8MW	IPP	8 MW	8	0	29884		
<b>Rangpur Area</b>								