

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	38	852000	
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	94	2908200	Gas shortage
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	QRPP	1*243+1*122	365	350	7470682	
	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Engine problem
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	352	7768440	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	284	6292000	Frequency control
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	380	8360125	Frequency control
9	Meghnaghat 100 MW (IEL)	QRPP	1*210	100	22	49820	Low demand
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	120	3189556	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	35	75840	Low demand
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	417428	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	46	0	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	423792	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
	Siddhirgonj Desh	QRPP	96*1.2	0	0	0	Contract Expired
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	7	12480	Low demand
18	Siddhirgonj 335 MW CCGP	EGCB	1*217	217	0	0	Under maint.
	Pagla (DPA )	QRPP	100*0.5	0	0	0	Contract Expired
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	80	1011744	Low demand
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	12	316704	Low demand
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	912960	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	100	474720	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	310880	
24	Natabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	980350	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	70	968640	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	56	1070820	
27	Masna 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	774880	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	636700	
29	Gazipur 52 MW PP	IPP	6*8.9	52	34	653904	Engine problem
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	64	434073	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1188000	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2105976	
<b>Dhaka area Total</b>				<b>5693</b>	<b>2661</b>	<b>49666734</b>	
37	Chattoogram TPP-1	PDB	1*210	180	75	1800000	Gas shortage
	Chattoogram TPP-2	PDB	1*210	180	0	0	Gas shortage
38	Racozan 25 MW PP	IPP	3*8.9	25	25	163038	
	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	120420	
40	Patanga 50MW PP (Baraka)	IPP	8*6.98	50	46	648480	
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	203	4840560	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4891529	FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	130	2874090	
	Sikalbaha 51 MW PP(Energis)	RPP	4*12.5+2*11.9+1*3+1*1.5	0	0	0	Contract Expired
44	Sikalbaha 105 MW PP (Baraka Sikalba)	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	169219	
47	Julidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	10	79320	Transformer overload.
48	Julidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1215380	
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	225024	
**	Malancha, Ctg. EPZ (Unlted)		5*8.73+3*9.34	0	20	484320	
50	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	78	541440	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	0	
52	Arwara 300 MW PP (Unlted)	IPP	300 MW	300	125	2223054	Low demand
53	Jodiac Power	IPP	3*18.55+1*3.6	54	17	433502	Low demand
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Low demand
<b>Chattoogram area Total</b>				<b>2166</b>	<b>1118</b>	<b>20709356</b>	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	80	2033654	Gas shortage
56	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	0	0	Under maint.
57	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	275	6976000	FGMO
58	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	270	6712500	FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	620856	Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1307520	
61	Ashuganj 53MW PP (Unlted)	QRPP	14*4	53	0	0	Contract Expired
62	Ashuganj 195MW PP (APSCL-Unlted)	IPP	20*9.73+1*16	195	16	434909	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	15	408634	Transformer overload.
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	5	66909	Transformer overload.
65	B.Barua (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	8	71576	Reserve
67	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	95	2342920	
68	Chandpur 200MW (Desh energy)	IPP	0	200	121	1706400	Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	469980	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	167040	
**	Imoport (Tripura)	Imported power	0	160	170	3236160	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818500	
72	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	20	74280	Low demand
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	464100	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
<b>Cumilla Area Total</b>				<b>2891</b>	<b>1240</b>	<b>27911938</b>	
75	RPCL 210MW CCGP	IPP	4*35+1*70	202	163	3918080	Gas shortage
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	505080	
77	Jamailpur 95 MW PP(Powerpac)	IPP	12*8.924	95	78	1050000	
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	5400	
79	Mymensingh 200 MW PP (Unlted)	IPP	200	200	84	1070400	Low demand
80	Jamailpur 115 MW PP (Unlted)	IPP	115 MW	115	115	2436000	
<b>Mymensingh Area Total</b>				<b>637</b>	<b>460</b>	<b>8999960</b>	
81	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	59	1206000	
82	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	30	720000	
83	Kushiana 163 MW CCGP (KP)	IPP	1*109+1*54	163	100	3006956	Frequency control
84	Shahbazar 330 MW CCGP	PDB	3*110	330	208	3514000	ST under S/D
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	39	619800	
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	804312	
87	Hobiganj 11MW PP Cofidence-E	SIPP, REB	4*2.90	11	11	162720	Engine problem
88	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1465632	FGMO
89	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	81	1118400	
90	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	47	816840	
91	Syhet 150 MW CCGP	PDB	1*142	142	110	2263170	FGMO
92	Syhet 20 MW GTTP	PDB	1*20	20	18	444000	
93	Syhet 50MW PP (EPL)	RPP	27*2	50	46	798940	
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	566856	
95	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	280	7220080	FGMO
96	Bibiana-III 400 MW CCGP	PDB	285 MW	285	429	10230000	
97	Syhet 10MW PP (Desh)	RPP	6*1.95	10	10	251460	
<b>Syhet Area Total</b>				<b>1834</b>	<b>1608</b>	<b>35199686</b>	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
**	<b>Bheramara (HVDC )</b>	Imported power	2*500	1000	914	21906909	
	Khulna 115 MW PP (KPCL-1 & 3)	IPP	19*6.5	0	0	0	Contract Expired
99	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	115	470400	
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	45	328800	
101	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	78	444800	
103	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	280	6950352	Frequency control
104	Neopara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	43	246750	
	Khulna (Aggreco) 55MW	QRPP	7*10.85	0	0	0	Contract Expired
105	Neopara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	17280	Reserve
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	72	605790	Low demand
107	Madhumati 100 MW PP	IPP	100 MW	105	85	2005632	Engine problem
<b>Khulna Area Total</b>				<b>2314</b>	<b>1629</b>	<b>32922693</b>	
108	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	64	328320	Low demand
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	32	610032	
111	Bhola 225 MW CCGP	PDB	2*63+1*68	194	152	3636106	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	91	1169579	
<b>Barisal Area Total</b>				<b>462</b>	<b>339</b>	<b>5744037</b>	
113	Baghabari 71 MW GTTP	PDB	1*71	71	60	105000	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	195241	
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	36	52063	
116	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	18	409620	Engine problem
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	50	209479	
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	38	72928	
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	179	4020645	FGMO
120	Sirajgonj Unit-2 22						