

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	756000	#1 under maint.
	Ghorasal Repowered CCGP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	200	4631000	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	QRPP	1*243+1*122	365	370	8566782	
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	2*40	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	108	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*2	40	0	0	Gas shortage
6	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	360	8646660	FGMO
7	Haripur 360MW CCGP(HPL)	IPP	1*235+1*125	360	350	7842000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	330	8645000	Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	100	428160	
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	230	6048582	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	64	1484856	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	665761	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	50	157312	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	461052	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Gas shortage
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	990720	
18	Siddhirgonj 335 MW CCGP	EGCB	1*217+118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	101	398880	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	46	174762	Engine problem
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	53	859680	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	854400	
23	Maniganj 55 MW PP (Northern)	IPP	3*19.3	55	55	390045	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	379159	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	54	379200	Engine problem
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	53	1224600	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	781200	
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	818600	
29	Saipur 52 MW PP	IPP	6*8.9	52	34	114120	Engine problem
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	230	943418	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve
33	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve
34	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1609920	
36	Gazipur 100 MW PP	RPCL	100 MW	105	87	494604	Engine problem
Dhaka area Total				5811	3398	58746383	
37	Chattogram TPP-1	PDB	1*210	180	105	2500000	Gas shortage
38	Chattogram TPP-2	PDB	1*210	180	90	2400000	Gas shortage
39	Razcan 25 MW PP	IPP	3*8.9	25	25	176020	
40	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	138240	
41	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	454080	
42	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	82	1993627	Low water level
43	Sikalbaha 225MW	PDB	1*150+1*175	225	215	4872048	
44	Sikalbaha Peaking GT	PDB	1*150	150	104	2858958	FGMO
45	Sikalbaha 105 MW PP (Baraka Sikalba)	IPP	105 MW	105	0	0	Transformer & Line overload
46	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D.
47	Dohazari-Kalaish 100 MW Peaking	PDB	6*17	102	85	548092	
48	Juidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	100	749880	
49	Juidah 100 MW Unit-3 (Acom)	IPP	0	100	100	1404480	
50	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	451248	
51	* Malancha, Ctg. EPZ (Unitted)		5*8.73+3*9.34	0	19	447840	
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	96	1665600	Engine problem
53	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	32520	
54	Anwara 300 MW PP (Unitted)	IPP	300 MW	300	160	1758873	Transformer & Line overload
55	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	Reserve
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
Chattogram area Total				2166	1250	22451506	
57	Ashuganj TPP Unit- 3	APSCCL	1*150	135	125	2787852	Gas shortage
58	Ashuganj TPP Unit- 4	APSCCL	1*150	129	0	0	Gas shortage
59	Ashuganj TPP Unit- 5	APSCCL	1*150	134	0	0	Gas shortage
60	Ashuganj 225 MW CCGP	APSCCL	1*142+1*75	221	197	4580000	FGMO
61	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	295	8130000	FGMO
62	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	295	7539500	FGMO
63	Ashuganj 50 MW PP	APSCCL	14*3.968	45	23	535896	Engine problem
64	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	1222560	
65	Ashuganj 53MW PP (Unitted)	QRPP	14*4	53	0	0	Contract Expired
66	Ashuganj 195MW PP (APSCCL-Unitted)	IPP	20*9.73+1*16	195	55	1154181	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	578112	Engine problem
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Reserve
69	B. Baria (Aggreko) 85MW	QRPP	86*1.10	85	0	0	Contract Expired
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	25	54288	Low demand
71	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	127	3148680	
72	Chandpur 200MW (Desh energy)	IPP	0	200	200	2019840	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	496980	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	186840	Engine problem
75	** Impoort (Tripura)	Imported power	0	160	180	3586560	
76	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	600500	
77	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	302160	
78	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	470090	Engine problem
79	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve
Cumilla Area Total				2891	1742	37394039	
80	RPCL 210MW CCGP	IPP	4*35+1*70	202	131	3771400	Gas shortage
81	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	483012	
82	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	91	1913280	
83	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13550	
84	Mymensingh 200 MW PP (Unitted)	IPP	200	200	150	964800	High Voltage
85	Jamalpur 115 MW PP (Unitted)	IPP	115 MW	115	115	1240800	
Mymensingh Area Total				637	509	8386842	
86	Fenchuganj CCGP Phase-1	PDB	2*32+1*33	67	60	1428000	
87	Fenchuganj CCGP Phase-2	PDB	2*35+1*35	90	60	1448880	
88	Kushaura 163 MW CCGP (KP)	IPP	1*109+1*54	163	130	3145547	Frequency control
89	Shahbazar 330 MW CCGP	PDB	3*110	330	157	3536000	GT-1 under S/D
90	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	40	705000	
91	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	48	980496	
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	252960	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	65	1553472	FGMO
94	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	75	1351680	
95	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	40	790920	Engine problem
96	Syhet 150 MW CCGP	PDB	1*142	142	81	2262610	
97	Syhet 20 MW GTTP	PDB	1*20	20	17	439000	
98	Syhet 50MW PP (EPL)	RPP	27*2	50	42	857700	Engine problem
99	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	424296	
100	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	318	7458750	FGMO
101	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.
102	Syhet 10MW PP (Desh)	RPP	6*1.95	10	10	195300	
Syhet Area Total				1949	1178	26822631	
103	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve
104	** Bheramara (HVDC)	Imported power	2*500	1000	927	22240727	
105	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	115	685440	
106	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	37	185280	
107	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve
108	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	20	133888	Low demand
109	Bheramara 360 MW CCGP	NWPGCL	1*278+1*132	410	375	8736192	FGMO
110	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	40	270375	
111	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve
112	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	1002720	
113	Madhumati 100 MW PP	IPP	100 MW	105	102	864416	
Khulna Area Total				2314	1721	33919038	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1111680	
115	Barisal GT PP Unit-1&2	PDB	2*20	30	0	0	Reserve
116	Bhida 33 MW PP (Venture)	RPP	1*34.50	33	34	601736	
117	Bhida 225 MW CCGP	PDB	2*63+1*68	194	173	4213315	FGMO
118	Bhida 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	2075864	
Barisal Area Total				462	413	8002595	
119	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
120	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Under shut down.
121	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	260168	
122	Bera 70 MW Peaking PP	PDB	9*8.29	71	45	149651	
123	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	50	50	401230	
124	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	50	819665	
125	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	36468	Reserve
126	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	171	3863627	FGMO
127	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	841300	Gas shortage
128	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	175	4782700	FGMO
129	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	335	9783781	FGMO
130	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	42245	Reserve
131	Bogra 22 MW PP (GGB)	RPP	6				