

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|------------------------------|----------------------------------|-------------------------|---------------------|------------------|----------------------|------------------|-----------------------------|
| | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*55 | 85 | 35 | 770000 | #1 under maint. |
| | Ghorasal Repowered CCPP Unit-3 | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CCPP Unit-4 | PDB | 1*210 | 180 | 200 | 4696000 | |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 0 | 0 | Under maint. |
| 2 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 350 | 8562891 | |
| 3 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 0 | 0 | Gas shortage |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 0 | 0 | Gas shortage |
| 5 | Harpur GTPP | SBU, PDB | 2*32 | 40 | 0 | 0 | Gas shortage |
| 6 | Harpur 412 MW CCPP | EGCB | 1*273+1*139 | 412 | 345 | 8722880 | FGMO |
| 7 | Harpur 360MW CCPP(HPL) | IPP | 1*236+1*125 | 360 | 351 | 8037200 | |
| 8 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 380 | 9882250 | Gas shortage |
| 9 | Meghnaghat 100 MW (IEL) | QRPP | 12*8.9 | 100 | 100 | 398400 | |
| 10 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 305 | 230 | 5888000 | Gas shortage |
| 11 | Madanganj 102 PP(Summit) | QRPP | 6*17 | 100 | 97 | 1620792 | Engine problem |
| 12 | Madanganj-55 MW PP(Summit) | (IPP) | 3*17.08+1*11.3 | 55 | 55 | 874896 | |
| 13 | Keraniganj 100 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 50 | 174370 | Low demand |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 365148 | |
| 15 | 210 MW Siddhirganj TPP | PDB | 1*210 | 115 | 0 | 0 | Gas shortage |
| 16 | Siddhirganj 2*120 MW GTPP | EGCB | 2*105 | 210 | 0 | 0 | Gas shortage |
| 17 | Siddhirganj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 100 | 90 | 4512000 | Engine problem |
| 18 | Siddhirganj 335 MW CCPP | EGCB | 1*217+1*118 | 335 | 0 | 0 | Gas shortage |
| 19 | Gagnagar 102 MW PP (Digital Po | IPP | 12*8.924 | 102 | 101 | 557280 | |
| 20 | Kapotti 52 MW PP (Sinha) | IPP | 7*7.9 | 52 | 51 | 166224 | Low demand |
| 21 | Karnalaghat 54 MW PP(Banco En | IPP | 3*18 | 54 | 53 | 650880 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 149 | 827520 | |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 803256 | |
| 24 | Nababaganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 55 | 708490 | |
| 25 | Bosila 108MW PP(CLC) | IPP | 12*8.775+1*3.5 | 108 | 69 | 1046400 | Engine problem |
| 26 | Summit Power,(Madhabadi+Ashuldi | SIPP,REB | 3*3.67+4*8.73 | 80 | 56 | 1247640 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | SIPP,REB | 4*8.73 | 33 | 33 | 793100 | |
| 28 | Rupganj 33 MW PP(Summit) | SIPP,REB | 4*8.73 | 33 | 33 | 823100 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 52 | 182580 | |
| 30 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | Gas shortage |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 300 | 1124072 | |
| 32 | Keraniganj 300 MW PP (AQR) | IPP | 25*11.4 | 300 | 0 | 0 | Reserve |
| 33 | Bramanganj 100 MW PP (Aggr | IPP | 1*100 | 100 | 0 | 0 | Reserve |
| 34 | Aurashahi 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | Reserve |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 149 | 3052800 | |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 87 | 1066176 | Engine problem |
| Dhaka area Total | | | | 5811 | 3521 | 63343345 | |
| 37 | Chattogram TPP-1 | PDB | 1*210 | 180 | 100 | 2400000 | Gas shortage |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage |
| 38 | Raozan 25 MW PP | IPP | 3*8.9 | 25 | 25 | 322277 | |
| 39 | Teknaf 20MW PP (Solartech) | Teknaf Solartech Energy | 20 | 20 | 0 | 122580 | |
| 40 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 50 | 789120 | |
| 41 | Kaptai Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 85 | 1844744 | Low water level |
| 42 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 205 | 4928202 | |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 134 | 3643362 | FGMO |
| 44 | Sikalbaha 105 MW PP (Baraka St | IPP | 105 MW | 105 | 0 | 0 | Reserve |
| 45 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | Under S/D. |
| 46 | Dohazari -Kalaish 100 MW Peakin | PDB | 6*17 | 102 | 102 | 682071 | |
| 47 | Juldah 100 MW Unit-1 (Acorn) | QRPP | 8*13.45 | 100 | 30 | 657000 | Low demand |
| 48 | Juldah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 100 | 1395840 | |
| 49 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 19 | 453552 | |
| * | Malancha, Ctg. EPZ (United) | | 5*8.73+3*9.34 | 0 | 8 | 458400 | |
| 50 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 97 | 1645440 | Engine problem |
| 51 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 27960 | |
| 52 | Anwara 300 MW PP (United) | IPP | 300 MW | 300 | 161 | 3176509 | Transformer & Line overload |
| 53 | Jodiak Power | IPP | 3*18.55+1*3.6 | 54 | 0 | 0 | Transformer & Line overload |
| 54 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | Transformer & Line overload |
| Chattogram area Total | | | | 2166 | 1116 | 22547057 | |
| 55 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 135 | 0 | 0 | Gas shortage |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 100 | 2394590 | Gas shortage |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 0 | 0 | Gas shortage |
| 56 | Ashuganj 225 MW CCPP | APSCL | 1*142+1*75 | 221 | 179 | 4643000 | FGMO |
| 57 | Ashuganj 450 MW CCPP(North) | APSCL | 1*360 | 360 | 285 | 8296500 | FGMO |
| 58 | Ashuganj 450 MW CCPP(South) | APSCL | 1*360 | 360 | 275 | 7335000 | FGMO |
| 59 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 30 | 636120 | Engine problem |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 54 | 1149120 | |
| | Ashuganj 53MW PP (United) | QRPP | 14*4 | 53 | 0 | 0 | Contract Expired |
| 62 | Ashuganj 195MW PP (APSCL-Ur | IPP | 20*9.73+1*16 | 195 | 63 | 1739636 | Gas shortage |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 35 | 750468 | Engine problem |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 0 | 35127 | Transformer & Line overload |
| | B. Baria (Aggreko) 85MW | QRPP | 8*6.10 | 85 | 0 | 0 | Contract Expired |
| 66 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 0 | 36824 | Reserve |
| 67 | Chandpur 150 MW CCPP | PDB | 1*106+1*57 | 163 | 124 | 3011880 | |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 200 | 3206880 | |
| 69 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 22 | 485712 | |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 8 | 188820 | Engine problem |
| ** | Impoort (Tripura) | | 0 | 160 | 176 | 3537600 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 33 | 771100 | |
| 72 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6*8.92 | 52 | 52 | 187320 | |
| 73 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 21 | 461120 | Engine problem |
| 74 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 0 | 0 | Reserve |
| Cumilla Area Total | | | | 2891 | 1657 | 38866397 | |
| 75 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 104 | 2863720 | Gas shortage |
| 76 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 22 | 514584 | |
| 77 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 95 | 2024640 | |
| 78 | Sarisahabi 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 11550 | |
| 79 | Mymensingh 200 MW PP (United | IPP | 200 | 200 | 170 | 892800 | High Voltage |
| 80 | Jamalpur 115 MW PP (United) | IPP | 115 MW | 115 | 115 | 1356500 | |
| Mymensingh Area Total | | | | 637 | 506 | 7663294 | |
| 81 | Fenchugonj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 59 | 1426000 | |
| 82 | Fenchugonj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 73 | 1759200 | |
| 83 | Kushiatra 163 MW CCPP (KP) | IPP | 1*109+1*54 | 163 | 100 | 3222990 | Low demand |
| 84 | Shajibazar 330 MW CCPP | PDB | 3*110 | 330 | 100 | 2310000 | GT-1 under S/D |
| 85 | Fenchugonj 51 MW PP (Barakati) | RPP | 19*2.90 | 51 | 44 | 876600 | |
| 86 | Fenchugonj 44MW (Energyprima | RPP | 12*3.3+5*2 | 44 | 49 | 1082304 | |
| 87 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 11 | 260928 | |
| 88 | Shajibazar GTTP Unit- 8 & 9 | PDB | 2*35 | 66 | 66 | 1530388 | FGMO |
| 89 | Shajibazar 86MW PP (Shajibaz | RPP | 32*2.90 | 86 | 75 | 1608000 | |
| 90 | Shajibazar 50MW PP (EPL) | RPP | 27*2.0 | 50 | 40 | 874080 | Engine problem |
| 91 | Sylhet 150 MW CCPP | PDB | 1*142 | 142 | 0 | 859040 | Under shut down. |
| 92 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 17 | 440000 | |
| 93 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 28 | 759600 | Engine problem |
| 94 | Shajibazhanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 24 | 571848 | |
| 95 | Bibiana-II 341 MW CCPP (Summit) | IPP | 1*222+1*119 | 341 | 295 | 7406000 | FGMO |
| 96 | Bibiyana-III 400 MW CCPP | PDB | 400 MW | 400 | 0 | 0 | Under maint. |
| 97 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 241920 | |
| Sylhet Area Total | | | | 1949 | 991 | 25223318 | |
| 98 | Bheramara GTTP Unit-1,2 & 3 | PDB | 3*20 | 46 | 0 | 0 | Reserve |
| ** | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 924 | 22269009 | |
| 99 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 115 | 116 | 606720 | |
| 100 | Faridpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 41 | 136800 | |
| 101 | Khulna 225 MW CCPP | NWPGCL | 1*150+1*75 | 230 | 0 | 0 | Reserve |
| 102 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 55 | 146560 | |
| 103 | Bheramara 360 MW CCPP | NWPGCL | 1*278+1*132 | 410 | 315 | 7314512 | FGMO |
| 104 | Noapara 40 MW PP (Karnajahan A | QRPP | 5*8.5 | 40 | 40 | 285000 | |
| 105 | Noapara 100 MW PP (Bangla Tra | IPP | 70*1.4 | 100 | 0 | 27840 | Reserve |
| 106 | Rupsha 105 MW PP (Orion rupsh | IPP | 6*18.445 | 105 | 105 | 1102560 | |
| 107 | Madhumati 100 MW PP | IPP | 100 MW | 105 | 86 | 489024 | Low demand |
| Khulna Area Total | | | | 2314 | 1682 | 32376325 | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 110 | 1637088 | |
| 109 | Barisal GT PP Unit-1& 2 | PDB | 2*20 | 30 | 0 | 0 | Reserve |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 31 | 578873 | |
| 111 | Bhola 225 MW CCPP | PDB | 2*63+1*68 | 194 | 173 | 4187550 | FGMO |
| 112 | Bhola 95 MW PP (Aggreko) | QRPP | 9*6.10 | 95 | 97 | 2134693 | |
| Barisal Area Total | | | | 462 | 411 | 8538204 | |
| 113 | Baghabari 71 MW GTPP | PDB | 1*71 | 71 | 0 | 0 | Gas shortage |
| | Baghabari 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | Under shut down. |
| 114 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 50 | 209845 | |
| 115 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 46 | 108158 | |
| 116 | Annura 50 MW PP(Sinha) | QRPP | 7*7.79 | 50 | 50 | 219320 | |
| 117 | Katakhal 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 42 | 455497 | Engine problem |
| 118 | Katakhal 50 MW Peaking PP | PDB | 6*8.7 | 50 | 0 | 51215 | Reserve |
| 119 | Sirajgonj Unit-1 225MW | NWPGCL | 1*150+1*75 | 210 | 155 | 4642473 | FGMO |
| 120 | Sirajgonj Unit-2 225MW | NWPGCL | 1*150+1*75 | 220 | 0 | 0 | Gas shortage |
| 121 | Sirajgonj Unit-3 225MW | NWPGCL | 1*141 | 220 | 176 | 4741836 | FGMO |
| 122 | Sirajgonj 400 MW CCPP Unit-4 | SNWPGCL | 1*282+1*132 | 414 | 395 | 9747818 | FGMO |
| 123 | Santahar 50 MW Peaking PP | PDB | 6*8.7 | 50 | 35 | 61260 | |
| 124 | Bogra 22 MW PP (GBB) | RPP | 6*4 | 22 | 22 | 507600 | |
| 125 | Bogura 20 MW PP (Energyprima) | RPP | 5*3.3+5*2 | 10 | 10 | 242496 | |
| 126 | Ullapara 11 MW PP (Summit) | SIPP, REB | 4*2.90 | 11 | 11 | 240300 | |
| 127 | Natore 52 MW PP (Rajlanka) | IPP | 6*8.92 | 52 | 43 | 530880 | |
| 128 | Chapanawabaganj 100 MW Peakin | PDB | 12*8.924 | 104 | 85 | 214760 | Low demand |
| 129 | Baghabari 200 MW PP (Paramou | IPP | 200 MW | 200 | 0 | 0 | Reserve |
| 130 | Bagura 113 MW PP (Confidence) | IPP | 113 MW | 113 | 113 | 707520 | |
| Rajshahi Area Total | | | | 2070 | 1233 | 22680978 | |
| 131 | Barapukuria TPP Unit-1 | PDB | 1*125 | 85 | 0 | 0 | Under maint. |
| | Barapukuria TPP Unit-2 | PDB | 1*125 | 85 | 66 | 1635927 | |
| 132 | Barapukuria 275 MW TPP Unit-3 | PDB | 1*275 | 274 | 280 | 6775900 | |
| 133 | Rangpur 20 MW GTPP | PDB | 1*20 | 20 | 0 | 0 | Reserve |
| 134 | Saidpur 20 MW GTPP | PDB | 1*20 | 20 | 16 | 76000 | |
| 135 | Rangpur 113 MW PP (Confidence | IPP | 113 MW | 113 | 107 | 935040 | |
| 136 | Sympa Solar Power 8MW | IPP | 8 MW | 8 | 0 | 31079 | |
| | Confidence Power Bogura Unit-1 | IPP | 6*18.55 | 113 | 0 | 99840 | |
| Rangpur Area Total | | | | 718 | 469 | 9553786 | |
| Total | | | | 19018 | 11586 | 230792704 | |
| Eastern Grid Total | | | | 13454 | 7791 | 157643411 | |
| Western Grid Total | | | | 5564 | 3795 | 73149293 | |
| National Grid Total | | | | 19018 | 11586 | 230792704 | |