

Till now the maximum generation is :- **12893 MW** **21:00 Hrs** on **29-May-19** Reporting Date : 7-Nov-19

The Summary of Yesterday's	6-Nov-19	Generation & Demand	12:00	Today's Actual Min Gen. & Probable Gen. & Demand	5:00
Day Peak Generation	8359.9 MW		12:00	Min. Gen. at	6459 MW
Evening Peak Generation	9976.0 MW		19:00	Available Max Generation	14595 MW
E.P. Demand (at gen end)	9976.0 MW		19:00	Max Demand (Evening)	10200 MW
Maximum Generation	9976.0 MW		19:00	Reserve(Generation end)	4395 MW
Total Gen. (MKWH)	195.8	System Load Factor	81.76%	Load Shed	0 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum	60 MW	at	19:00	Energy	MKWHR.
Import from West grid to East grid :- Maximum	-	MW	at	-	- MKWHR.
Water Level of Kaptai Lake at 6:00 A M on	7-Nov-19				
Actual :	101.44	Ft.(MSL) ,	Rule curve :	108.40	Ft.(MSL)

Gas Consumed :	Total =	1141.18	MMCFD.	Oil Consumed (PDB) :	
				HSD :	Liter
				FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk134,831,125			
	Coal :	Tk27,977,236	Oil :	Tk211,673,521	Total : Tk374,481,882

Load Shedding & Other Information

Area	Yesterday		Today		Rates of Shedding (On Estimated Demand)
	MW	Estimated Demand (S/S end)	MW	Estimated Shedding (S/S end)	
Dhaka	0	0:00	3593	0	0%
Chittagong Area	0	0:00	1219	0	0%
Khulna Area	0	0:00	1092	0	0%
Rajshahi Area	0	0:00	987	0	0%
Mymensingh Area	0	0:00	892	0	0%
Sylhet Area	0	0:00	720	0	0%
Barisal Area	0	0:00	406	0	0%
Rangpur Area	0	0:00	185	0	0%
Total	0	0:00	9648	0	0%

Information of the Generating Units under shut down.

Planned Shut-Down

Forced Shut-Down

- 1) Barapukuria ST: Unit-1.
- 2) Sylhet-150 MW.
- 3) Ghorasal Unit-1,3 & 5
- 4) Raozan #2
- 5) Ashuganj unit-4 & 5
- 6) Chandpur CAPP ST
- 7) Sylhet 150 MW
- 8) Fenchuganj # 03 & 04

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Comments on Power Interruption	
a) Hathazari-Baroihat 132 kV Ckt-1 was under shut down from 08:40 to 16:12 for A/M.		
b) Aminbazar-Mirpur 132 kV Ckt-2 was under shut down from 09:02 to 17:38 for A/M.		
c) Sikalbaha-TK Chemical 132 kV Ckt was under shut down from 08:05 to 14:45 for A/M.		
d) Mymensingh-Kishorganj 132 kV Ckt-1 was under shut down from 09:41 to 16:36 for A/M.		
e) Jamalpur UMPL-Sherpur 132 kV Ckt-1 was under shut down from 08:18 to 16:32 for A/M.		
f) Dhamrai-Kalikoair 132 kV Ckt-1 was shut down at 09:35 for A/M.		
g) Shazibazar 132/33 kV T-2 transformer was under shut down from 09:02 to 13:50 for A/M.		
h) Meghnaghat-Haripur 230 kV Ckt-1 was under shut down from 08:37 to 14:52 for A/M.		
i) Haripur-Bhulta 230 kV Ckt-2 was under shut down from 09:30 to 17:14 for A/M.		
j) Hathazari 230/132 kV T-3 transformer was under shut down from 09:29 to 16:15 for C/M.		
k) Polashbari-Rangpur Confidence 132 kV Ckt-1 was under shut down from 09:10 to 16:45 for A/M.		
l) Polashbari-Thakurgaon 132 kV Ckt-1 was under shut down from 08:34 to 17:22 for A/M.		
m) Naogaon-Bogura 132 kV Ckt-1 was under shut down from 09:25 to 16:08 for A/M.		
n) Khulna (c) 132/33 kV T-3 transformer was under shut down from 08:06 to 16:11 for A/M.		
o) Gopalganj 132/33 kV T-2 transformer was under shut down from 08:18 to 15:25 for A/M.		
p) Barisal 230 kV bus bar-2 was under shut down from 08:18 to 15:48 for A/M.		
q) Barisal(n)-Madaripur 132 kV Ckt-1 was shut down at 10:09 for D/W.		
r) Bogura-Mohasthanagarh 132 kV Ckt-1 was close at 10:48.		
s) Bibiyana(s) 400 kV QA-3 CB of Dia-6 was shut down at 11:18 for Protection test.		
t) Haripu 412 MW was shut down at 11:18 for filter change.		
u) Siddhirganj 335 GT-2 was synchronized at 11:37.		
v) Ashuganj 225 MW ST tripped at 12:32.		
w) Sonargaon 132/33 kV T-2 transformer was under shut down from 13:40 to 15:42 for fault of 33 kV PBS feeder.	About 30 MW power interruption occurred under Sonargaon S/S area from 13:40 to 15:42.	
x) Sirajganj unit-2 GT was synchronized at 17:29.		
y) Chandpur 150 MW CAPP tripped at 06:25(07/11/2019) for problem eith GBC.		
z) Cumilla(n)-Meghnaghat 230 kV Ckt-1 was shut down at 07:54(07/11/2019).		
aa) Dhamrai-Kalikoair 132 kV Ckt-1 was shut down at 07:03(07/11/2019) for C/M.		
Sub Divisional Engineer	Executive Engineer	Superintendent Engineer
Network Operation Division	Network Operation Division	Load Despatch Circle