

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW		MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	35	795000		#2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	169400		Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0		Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0		Gas shortage.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	250	6110245		
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0		Gas shortage.
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0		Gas shortage.
5	Haripur GTPP	SBU, PDB	2*32	40	0	0		Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	379	8760320		FGMO
7	Haripur 365MW CCPP(HPL)	IPP	1*236+1*125	360	362	7471000		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	420	8738500		
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	0	0		Reserve
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3267840		Gas shortage.
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	0	0		Reserve
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	15	123431		Low demand
13	Keranganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	0		Reserve
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	106092		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0		Gas shortage.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	97	806000		Gas shortage.
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	0	0		Reserve
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	0	0		Under maint.
19	Gaganraj 102 MW PP (Digital Po	IPP	12*8.924	102	7	70416		Low demand
20	Kaptai 52 MW PP (Sinha)	IPP	7*7.9	51	46	399168		
21	Kamalshah 54 MW PP(Banco En	IPP	3*18	54	0	0		Reserve
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	0		Reserve
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	0	46130		Reserve
24	Nababaganj 55 MW PP (Southern)	IPP	3*19.3	55	17	51174		Low demand
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	72	214080		
26	Summit Power, (Madhabdi+Ashuldi)	SIPP,REB	3*3.67+4*8.73	80	30	1174420		Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	797800		
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	723000		
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	370176		
30	Tongi 80 MW GTPP	PDB	1* 105	105	0	0		Gas shortage.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	95	278500		Low demand
32	Keranganj 300 MW PP (APR)	IPP	25*11.4	300	0	0		Reserve
33	Bramhanganj 100 MW PP (Aggr	IPP	1*100	100	0	0		Reserve
34	Aurshahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0		Reserve
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	0	0		Reserve
36	Gazipur 100 MW PP	RPCL	100 MW	105	52	506388		Low demand
<b>Dhaka area Total</b>				<b>5811</b>	<b>2160</b>	<b>4097989</b>		
37	Chattogram TPP-1	PDB	1*210	180	0	0		Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	120	2900000		Gas shortage.
38	Raozan 25 MW PP	IPP	3*8.9	25	0	0		Reserve
39	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energy	20	20	0	119340		
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	6	35040		Low demand
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	88	2127389		Low water level
42	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4725388		FGMO
43	Sikalbaha Peaking GT	PDB	1*150	150	145	2707368		FGMO
44	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	92	653199		
45	Hattazari 100 MW Peaking PP	PDB	11*8.9	98	0	0		Reserve
46	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	0	0		Low demand
47	Julidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	406680		Reserve
48	Julidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	0	0		Reserve
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	439200		
*	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0	9	297120		
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	10	53760		Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	28080		
52	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0		Reserve
53	Jodiak Power	IPP	3*18.55+1*3.6	54	0	0		Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0		Reserve
<b>Chattogram area Total</b>				<b>2166</b>	<b>793</b>	<b>14492564</b>		
55	Ashuganj TPP Unit-3	APSCL	1*150	135	100	2135376		Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0		Gas shortage.
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0		Gas shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	217	203	4814000		FGMO
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	340	7232100		FGMO
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	315	7054000		FGMO
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	37	667368		Engine problem
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	808800		
	Ashuganj 53MW PP (United)	QRPP	14*4	53	0	0		Contract Expired
62	Ashuganj 195MW PP (APSCL-Ur	IPP	20*9.73+1*16	195	36	401454		Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	25	333268		Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	10	50181		Reserve
	B.Barua (Aggreko) 85MW	QRPP	8*6*1.10	85	0	0		Contract Expired
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0		Reserve
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	88	1948940		
68	Chandpur 200MW (Desh energy)	IPP	0	200	52	163880		Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	203120		
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	67320		
**	Impoort (Tripura)		0	160	124	2341440		
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	237500		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	0		Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	10	348600		Engine problem
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0		Reserve
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0		On test
<b>Cumilla Area Total</b>				<b>3005</b>	<b>1456</b>	<b>28707147</b>		
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	153	3182840		Gas shortage.
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	318492		
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	0	0		Reserve
78	Sarisahabi 3 MW Solar Plant	IPP	1*3	3	0	10500		
79	Mymensingh 200 MW PP (United	IPP	200	200	195	1408000		
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	0	0		Reserve
<b>Mymensingh Area Total</b>				<b>637</b>	<b>370</b>	<b>4920322</b>		
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	59	1123000		
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	58	1105832		
83	Kushiyara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3205113		
84	Shahjibazar 330 MW CCPP	PDB	3*110	330	90	3799000		GT-1 tripped at 15:33
85	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	50	380400		
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	766512		
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	63960		
88	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1236576		FGMO
89	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	79	612480		
90	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	0	0		Contact expired
91	Sylhet 150 MW CCPP	PDB	1*142	142	0	0		Under shut down.
92	Sylhet 20 MW GTTP	PDB	1*20	20	18	136900		
93	Sylhet 58MW PP (EPL)	RPP	27*2	50	40	463920		Engine problem
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	146664		
95	Bibiyana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	315	7498500		FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	364	9107000		
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	124740		
<b>Sylhet Area Total</b>				<b>1949</b>	<b>1398</b>	<b>29769697</b>		
98	Bheramara GTTP Unit-1,2 & 3	PDB	3*20	46	0	0		Reserve
**	Bheramara (HVDC)	Imported power	2*500	1000	686	11521454		
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	0	0		Reserve
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	6	7680		Low demand
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0		Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0		Reserve
103	Bheramara 360 MW CCPP	NWPGCL	1*278+1*132	410	310	8059104		Low demand
104	Noapara 40 MW PP (Konejahan A	QRPP	5*8.5	40	0	0		Reserve
105	Noapara 100 MW PP (Bangla Trd	IPP	70*1.4	100	0	0		Reserve
106	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	53	455520		Low demand
107	Madhumati 100 MW PP	IPP	100 MW	105	17	53712		Low demand
<b>Khulna Area Total</b>				<b>2314</b>	<b>1072</b>	<b>20097470</b>		
108	Barisal 110 MW PP (Summit )	IPP	7*17.076	110	32	316800		Low demand
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0		Reserve
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	424200		Engine problem
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	183	4055968		
112	Bhola 95 MW PP (Aggreko)	QRPP	9*6*1.10	95	0	0		Line over load
<b>Barisal Area Total</b>				<b>462</b>	<b>241</b>	<b>4796968</b>		
113	Baghabari 71 MW GTTP	PDB	1*71	71	50	415000		Gas shortage.
	Baghabari 100 MW GTTP	PDB	1*100	100	0	489000		Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0		Reserve
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0		Reserve
116	Annura 50 MW PP(Sinha)	QRPP	7*7.9	50	50	327280		
117	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0		Reserve</