



Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9584667, 9551095

Month January, 2020		Day : Monday				Date : 06.01.20							
Probable Maximum Demand :		8500 MW		Yesterday = 95.74 ft		Today = 95.74 ft		Probable Maximum Generation : 14820 MW		Rule Curve = 102.24 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.01.20 (Yesterday)		06.01.20 (Today)		05.01.20 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	34	34	35	35		51	Unit-1 Under Maint.	20.01.20
	b) Ghorasal Repowered CCP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0			On Test	
	c) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	100	160	180	180				
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
2	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	294	280	360	360				
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	74	64	0	0				
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	2 x 32	64	40	0	0	0	0	40		Gas Shortage	
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	368	278	360	360				
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	330	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Gas Shortage	
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	364	275	360	360				
11	Siddhirganj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	347	270	335	335				
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	100	100				
14	Meghnaghat CCP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0				
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	100	87	87				
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	0	100	100				
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	102	102	102				
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22				
21	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	57	57	57				
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
23	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52				
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	17	100	100				
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149				
27	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	47	50	50				
28	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	53	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	200	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	100	149				
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300				
32	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100				
33	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100				
34	Nabaganj 55 MW PP (Southern pc)	HFO (IPP)	3x19.3	55	55	0	0	55	55				
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55				
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	72	72				
Dhaka Zone Total				6047	5811	1957	2194	3656	4305	660	51		
37	Karnaphuli Hydro PP Unit-1,2,3,4	Hydro (PDB)	2x40, 3x50	230	230	43	46	44	47	184		Low Water Level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	115	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under Maint.	08.01.20
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1.617	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
41	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	5.59	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	34	50	50				
43	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	50	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	144	104	130	150				
45	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	218	203	210	215				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	158	230	300				
47	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	0	60	100	100				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	80	100				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	16	21	21				
**	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	32	10	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	50	100				
53	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	50	110				
Chattogram Zone Total				2226	2166	533,207	818	1394	1612	184	180		
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	125	125	55		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	40	40	40				
57	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+1'75	221	221	202	185	225	225				
58	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	350	270	360	360				
59	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	350	260	360	360				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0				
61	Ashuganj 195MW PP (APSCL)	Gas (IPP)	20'9.73+1'116	195	195	112	112	150	180				
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	100	150				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
65	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	88	87	50	90				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	150	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	50				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	14	14	14				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+40x1.515+15x1.05	200	200	0	0	0	200				
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	114				
74	Chowmuhani 113 MW Impport (Tripura)	HFO (IPP)	12'9.78+2'3.1	113	113	0	57	0	0				
**	India			160	160	87	106	87	107				
Cumilla Zone Total				3040	2980	1381	1317	1770	2374	318	0		
75	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	146	109	170	170				
76	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
77	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	94	95	95				
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	0	100	115				
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	4	100	200				
80	Sarishabani 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	0.6	0	1.6	0				
Mymensingh Zone Total				645	637	168.6	229	488.6	602	0	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.01.20 (Yesterday)		06.01.20 (Today)		05.01.20 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
81	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	30	30				
82	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	50	62	60	60				
83	Fenchugonj 51 MW PP (Barakatull)	Gas (RPP)	19x2.90	51	51	0	53	51	51				
84	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	50	44	44				
85	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	100	163	163				
86	Hobiganj 11MW PP Confidence-E	Gas (SI,PP, REB)	4x2.90	11	11	0	3	11	11				
87	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	45	69	66	66				
88	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	123	127	160	160				
89	Shahjibazar 86MW PP (Shahjibaza)	Gas (RPP)	32x2.90	86	86	5	79	75	75				
90	Sylhet 150 MW CCPP	Gas (PDB)	1x142	142	142	0	0	0	0	142	Under Overhauling	31.01.20	
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	17	17	17				
92	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
93	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	9	10	10				
94	Shahjahanulla 25 MW PP	Gas (CI,PP, REB)	3x9.34	25	25	0	24	24	24				
95	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	341	341				
96	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	442	225	230	230				
Sylhet Zone Total				1944	1899	1095	1128	1282	1282	0	142		
97	Bheramara GTPP Unit-1,2 & 3	HSD (PDB)	3 x 20	60	46	0	0	0	40				
98	Bheramara 410 MW CCPP	Gas (NWP,GCCL)	1 x 278+1 x 132	410	410	78	250	288	288				
99	Fairdur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35				
100	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	30	70				
101	Khulna 225 MW CCPP	HSD (NWP,GCCL)	1 x 150+1x75	230	230	0	0	0	200				
102	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	0	115	0	115				
103	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	80	100				
104	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	33	38	40	40				
105	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	50	105				
106	Madhumati 100 MW PP	HFO (NWP,GCCL)	6x18.415	105	105	0	80	33	100				
**	Bheramara (HVDC)	India		1000	1000	312	653	316	661				
Khulna Zone Total				2328	2314	423	1136	837	1754	0	0		
107	Barisal GT PP Unit-1&2	HSD (PDB)	2 x 20	40	30	0	0	0	30				
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	44	70	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	9	20	25	25				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	60	0	175	190				
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	56	77	95	95				
Barishal Zone Total				472	462	125	141	365	450	0	0		
112	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	70	70	70	70	1	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
113	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
114	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
115	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	45				
116	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	25	50	50				
117	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	0	80	100				
118	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
119	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	40	40				
120	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38				
121	Sirajgonj 225MW CCPP Unit-1	Gas (NWP,GCCL)	1x150+1x75	210	210	214	182	210	210				
122	Sirajgonj 225MW CCPP Unit-2	Gas (NWP,GCCL)	1x150 + 1x75	220	220	177	155	220	220	220	Gas Shortage		
123	Sirajgonj 225MW CCPP Unit-3	Gas (NWP,GCCL)	1x141+1x79	220	220	0	37	220	220		was under maint.		
124	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	437	386	400	430				
125	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	22	22				
126	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	11	14	10	10				
127	Ullapara 11 MW PP (Summit)	Gas (SI,PP, REB)	4x2.90	11	11	10	11	11	11				
128	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
129	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	108	113	113				
130	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	0	0	113				
Rajshahi Zone Total				2193	2183	919	988	1738	2034	321	0		
131	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Maintenance	10.01.20	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Shutdown for Low Demand		
132	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	200	260	260				
133	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
134	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	0	70	113	113				
135	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
136	Majpara, Tatula 8 MW Solar PP (Sympa)	Solar (IPP)	1 x 8	8	8	2.9	0	8	0				
Rangpur Zone Total				685	605	163	270	381	407	0	170		
Sub-total: Plants in operation				19580	19057	6764.7	8221	11912	14820	1483	543		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6402	7518	11273	14025				
(B) Contract expired power plants													
137	Shahjibazar 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0		Contract expired		
Sub-Total: Plants under long term maintenance				50	50	0	0	0	0				
Gross Total				19630	19107	6764.7	8221	11912	14820	1483	543		
(C) Actual data of 05.01.20 (Yesterday) Sunday :													
01.	Max. Demand (Generation end)	:	8221.00	MW, at =	20:00 hrs P	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand (Sub-station end)	:	7518.00	MW, at =	20:00 hrs P	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	8221.00	MW, at =	20:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	5007.00	MW, at =	5:00 hrs	Dhaka	2803	2803	0	Mymensingh	629	629	0
05.	Day-peak Generation (Generation end)	:	6764.71	MW, at =	12:00 hrs	Chattogram	839	839	0	Sylhet	307	307	0
06.	Evening-peak Generation (Generation end)	:	8221.00	MW, at =	20:00 hrs	Khulna	921	921	0	Barishal	194	194	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	20:00 hrs P	Rajshahi	921	921	0	Rangpur	194	194	0
08.	Actual Minimum Generation up to 8:00 hrs.	:	5117.00	MW, at =	5:00 hrs am	Cumilla	710	710	0				
09.	Generation shortfall at evening peak due to :	:								Total	7518	7518	0
	a) Gas limitation	:	1299	MW		13.	Fuel cost :	(a) Gas = 125557283 Taka	(c) Coal = 16907242 Taka				
	d) Coal supply Limitation	:	0	MW			(b) Oil = 64693023 Taka	Total = 142464525 Taka					
	b) Low water level in Kaptai lake	:	184	MW									
	c) Plants under shut down/ maintenance	:	543	MW									
10.	Total Energy (Generation + India Import)	:	158.61	MKWh		14.	Maximum Temperature in Dhaka was :	22.8° C					
	By Gas = 136.096 MKWh			By Oil = 7.273 MKWh		15.	Export through East-West interconnections :						
	By Coal = 4.134 MKWh			By Hydro = 1.061 MKWh			At evening peak-hour	:	-136	MW, at	20:00 hrs PM		
	By Solar= 0.096 MKWh						Maximum	:	-480	MW, at	7:00 hrs		
11.	Total Gas Supplied	:	1089.30	MMCFD			Energy	:	3.363	MKWh			
(D) Forecast of 06.01.20 (Today) Monday :													
01.	Maximum Demand	:	8500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14820	MW	(Generation end)	05.	Total Generation	:	163.99	MKWh			
03.	Maximum Shortage	:	-6320	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	22.6° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(MONIRUZAMAN)
Deputy Secretary, Generation