

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy		Remarks
						Generated	MW	
			Unit No. X Capacity	MW	Generation	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	72	1670000		
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.	
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	220	4063000		
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	380	9011582		
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage.	
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage.	
5	Haripur GTPP	SBU, PDB	2*32	40	0	0	Under maint.	
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	362	8467460	FGMO	
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	257	7422000	Gas shortage.	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9410000		
9	Meghnaghat 100 MW (EL)	QRPP	12*8.9	100	100	1775040		
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage.	
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	98	962352		
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	524149		
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	10	42228	Low demand	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	503928		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.	
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage.	
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	88	1087680	Engine problem	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	203	5077148	STG under maint.	
19	Gaganpur 102 MW PP (Digital Po	IPP	12*8.924	102	102	1694592		
20	Kaptai 52 MW PP (Sinha)	IPP	7*7.9	52	47	693590		
21	Kamalshahi 54 MW PP(Banco En	IPP	3*18	54	53	1020960		
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	0	Reserve	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	710822	Low demand	
24	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	0	0	Reserve	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Reserve	
26	Summit Power,(Madhabdi+Ashuldi)	SIPP,REB	3*3.67+4*8.73	80	49	1175820	Engine problem	
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	20	598800	Engine problem	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	837600		
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0	Reserve	
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Gas shortage.	
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	145	328690	Low demand	
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve	
33	Bramhanganj 100 MW PP (Aggr	IPP	1*100	100	0	0	Reserve	
34	Aurshahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve	
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	17	50400	Low demand	
36	Gazipur 100 MW PP	RPCL	100 MW	105	17	174156	Low demand	
Dhaka area Total				5811	2835	57301767		
37	Chattogram TPP-1	PDB	1*210	180	0	8000	Gas shortage.	
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage.	
38	Raozan 25 MW PP	IPP	3*8.9	25	0	0	Reserve	
39	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energy	20	20	0	80055		
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	886560		
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	32	675540	Low water level	
42	Sikalbaha 225MW	PDB	1*150+1*175	225	141	335935	DP high	
43	Sikalbaha Peaking GT	PDB	1*150	150	140	292746	FGMO	
44	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	34	627272	Low demand	
45	Hatibazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under maint.	
46	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	0	0	Reserve	
47	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	50	101400	Low demand	
48	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	1431360	Engine problem	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	418080		
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	11	591840		
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	97	462720	Engine problem	
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	8760		
52	Anwara 300 MW PP (United)	IPP	300 MW	300	260	4543964	Transformer over load	
53	Jodiak Power	IPP	3*18.55+1*3.6	54	0	0	Reserve	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve	
Chattogram area Total				2166	924	16183632		
55	Ashuganj TPP Unit-3	APSCl	1*150	135	0	0	Gas shortage.	
	Ashuganj TPP Unit-4	APSCl	1*150	129	0	0	Machine problem	
	Ashuganj TPP Unit-5	APSCl	1*150	134	135	2564608		
56	Ashuganj 225 MW CCPP	APSCl	1*142+1*75	221	185	4435000	FGMO	
57	Ashuganj 450 MW CCPP(North)	APSCl	1*360	360	300	7710500	FGMO	
58	Ashuganj 450 MW CCPP(South)	APSCl	1*360	360	310	7559000	FGMO	
59	Ashuganj 50 MW PP	APSCl	14*3.968	45	43	924192		
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	132960	Gas shortage.	
62	Ashuganj 195MW PP (APSCl-Ur	IPP	20*9.73+1*16	195	8	702545	Gas shortage.	
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1250648		
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	1154181		
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve	
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	83	1612490	ST under maint.	
68	Chandpur 200MW (Desh energy)	IPP	0	200	34	130560	Low demand	
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	466380		
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	254980		
**	Impoort (Tripura)	Imported power	0	160	112	2136960		
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	799100		
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	0	Reserve	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	444000		
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve	
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	441180		
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	0	Reserve	
Cumilla Area Total				2980	1613	32719184		
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	103	2459200	Gas shortage.	
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	532008		
77	Jamulpur 95 MW PP(Powerpac)	IPP	12*8.924	95	95	1713600		
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	5900		
79	Mymensingh 200 MW PP (United)	IPP	200	200	36	242400	Low demand	
80	Jamulpur 115 MW PP (United)	IPP	115 MW	115	115	1712400		
Mymensingh Area Total				637	371	6665508		
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	60	1329000		
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	0	181440	Under maint.	
83	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Under maint.	
84	Shahjibazar 330 MW CCPP	PDB	3*110	330	146	3439000	FGMO & GT-1 Under S/D.	
85	Fenchuganj 51 MW PP (Barakata)	RPP	19*2.90	51	53	1255200		
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	50	1192968		
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	250080		
88	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	65	1578528	FGMO	
89	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	76	1807680	Engine problem	
90	Shahjibazar 50MW PP (EPL)	RPP	27*2.0	50	0	0	Contact expired	
91	Sylhet 150 MW CCPP	PDB	1*142	142	99	571300	Machine problem	
92	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	Under maint.	
93	Sylhet 50MW PP (EPL)	RPP	2*7.2	50	0	0	Contract Expired	
94	Shahjibazar 25 MW PP	SIPP, REB	3*9.34	25	24	486684		
95	Bibiyana-II 341 MW CCPP (Summi	IPP	1*222+1*119	341	320	7571500	FGMO	
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	144	3484000	Machine problem	
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	241380		
Sylhet Area Total				1949	1058	23388760		
98	Bheramara GTPP Unit-1,2 & 3	PDB	3*20	46	0	0	Reserve	
**	Bheramara (HVDC)	Imported power	2*500	1000	737	8130181		
99	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	115	1629120		
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve	
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve	
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve	
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	30	4218912	ST Synchronized process.	
104	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	33	48375	Engine problem	
105	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	0	0	Reserve	
106	Rupsha 105 MW PP (Ghiron rupsh	IPP	6*18.445	105	0	0	Reserve	
107	Madhumati 100 MW PP	IPP	100 MW	105	67	316176	Low demand	
Khulna Area Total				2314	982	14327264		
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	64	371520	Line overload	
109	Barisal GT PP Unit-1& 2	PDB	2*20	30	0	0	Reserve	
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	20	359800	Engine problem	
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	90	2192268	ST Under S/D.	
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	36	888060	Gas shortage.	
	Payra 1320 MW	NWPGCL	0	0	0	0	On test	
Barisal Area Total				462	210	3811648		
113	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage.	
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.	
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	43	94005		
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve	
116	Ammura 50 MW PP(Sinha)	QRPP	7*7.79	50	40	568810	Engine problem	