

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2'55	85	12	520000	Unit-1 Under maint.
	Ghorasal Repowered CAPP Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	130	3032000	
	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
2	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	320	7614991	Gas shortage.
3	Ghorasal 78.5 MW PPI(MAX)	QRPP	2'40	78	0	0	Gas shortage.
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	12	318863	Gas shortage.
5	Haripur GTPP	SBU, PDB	2'32	40	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	336	8429236	FGMO
7	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	320	7827000	Frequency Contro
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	350	8439250	Frequency Contro
9	Meghnaghat 100 MW (IEL)	QRPP	12'8.9	100	100	521280	
10	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	140	3385600	Gas shortage.
11	Madaniganj 102 PP(Summit)	QRPP	6'11	100	79	1423248	
12	Madaniganj 55 MW PPI(Summit)	(IPP)	3'17.08+1'11.3	55	15	80244	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	10	18505	Low demand
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	431496	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage.
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	781988	
18	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	0	0	Under maint.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	923040	
20	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	51	6	59808	Low demand
21	Kamalaghat 54 MW PPI(Banco Energy)	IPP	3'18	54	53	686760	
22	Kodda 150MW PP	IPP	8'17.06	149	0	19200	Reserve
23	Manikganj 55 MW PP (Northern)	BPDB-RPCL	3'19.3	55	55	403858	Reserve
24	Nabaganj 55 MW PP (Southern pow)	IPP	3'19.3	55	0	0	Reserve
25	Bosila 108MW PPI(CLC)	IPP	12'8.775+1'3.5	108	0	0	Reserve
26	Summit Power, (Madhabadi+Ashulia)	SIPP, REB	3'3.67+8'6.73	80	47	1130280	Engine problem
27	Maona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	837300	
28	Rupsha 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	32	830100	Low demand
29	Gazipur 52 MW PP	IPP	6'8.9	52	18	248292	Low demand
30	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Gas shortage.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	250	1743818	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve
33	Bramhanaganj 100 MW PP (Agrako)	IPP	100	100	0	0	Reserve
34	Aurahi 100MW PP (Agrako)	IPP	0.85'2340.95'91	100	0	0	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	0	0	Reserve
36	Gazipur 100 MW PP	RPCL	100 MW	105	88	1382664	Engine problem
Dhaka area Total				5811	2629	51078921	
37	Chattoogram TPP-1	PDB	1'210	180	100	2400000	Gas shortage.
	Chattoogram TPP-2	PDB	1'210	180	0	0	Gas shortage.
38	Raczer 25 MW PP	IPP	3'9.9	25	8	17680	Low demand
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	115830	
40	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	50	684000	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	75	1781687	Low water level
42	Sikalaha 225MW	PDB	1'150+1'175	225	203	4875024	
43	Sikalaha Peaking GT	PDB	1'150	150	139	3096176	FGMO
44	Sikalaha 105 MW PP (Baraka Sikab)	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	102	554918	
47	Jukdah 100 MW Unit-1 (Accorn)	QRPP	8'13.45	100	0	0	Reserve
48	Jukdah 100 MW PP Unit-3 (Accorn)	IPP	0	100	100	494400	
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'7.30	22	22	830132	
	Malancha, Ctg, EPZ (United)		5'8.73+3'9.34	0	27	409920	
50	Chattoogram 108 MW PP (ECPV)	IPP	16'7	108	50	77760	Low demand
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29399	
52	Anwara 300 MW PP (Unite)	IPP	300 MW	300	213	3081164	Transformer overload
53	Jodioc Power	IPP	3'18.55+1'3.6	54	0	0	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Jukdah unit-2	IPP	0	0	0	0	On test
Chattogram area Total				2166	1089	18121070	
55	Ashuganj TPP Unit- 3	APSCL	1'150	135	100	2501158	Gas shortage.
	Ashuganj TPP Unit- 4	APSCL	1'150	129	100	2424275	
	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CAPP	APSCL	1'142+1'175	221	180	4294000	FGMO
57	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	315	7884500	FGMO
58	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	0	0	Under maint.
59	Ashuganj 50 MW PP	APSCL	14'3.968	45	46	1009800	
60	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	5	136800	Gas shortage.
62	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'116	195	26	434909	
63	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	25	964876	Engine problem
64	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	58	2107763	Low demand
66	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Reserve
67	Chandour 150 MW CAPP	PDB	1'106+1'57	163	0	0	Under S/D
68	Chandour 200MW (Dash eneray)	IPP	0	200	0	120000	Reserve
69	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	481392	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	150120	
**	Import (Tijaura)	Imported power	0	160	128	2881840	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	812200	
72	Jangalia 52 MW PP (Laksharavi)	IPP	6'8.92	52	0	10003	Reserve
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	22	521850	
74	Daukandi 200 MW PP (B. Trac)	IPP	154'1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	0	Reserve
	Chamuhani 113 MW	IPP	12'9.78+2'3.1	113	113	507360	
Cumilla Area Total				2980	1171	24955846	
75	RPCL 210MW CAPP	IPP	4'35+1'70	202	196	4755040	
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	510372	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	42	463680	Low demand
78	Sarsahabari 3 MW Solar Plant	IPP	1'3	3	0	15000	
79	Mymensingh 200 MW PP (Unite)	IPP	200	200	173	3235600	
80	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	8	22800	Low demand
Mymensingh Area Total				637	441	8292492	
81	Fenchuganj CAPP Phase-1	PDB	2'32+1'33	70	41	983000	
82	Fenchuganj CAPP Phase-2	PDB	2'35+1'35	90	43	687680	Frequency Contro
83	Kushara 163 MW CAPP (KP)	IPP	1'109+1'54	163	130	3289418	Frequency Contro
84	Shahbazar 330 MW CAPP	PDB	3'110	330	275	6664000	FGMO
85	Fenchuganj 51 MW PP (Barakatalah)	RPP	19'2.90	51	49	932000	
86	Fenchuganj 44MW (Energyprima)	RPP	12'3.3+5'2	44	47	916560	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	245856	
88	Shahbazar GTTP Unit- 8 & 9	PDB	2'35	66	62	1459680	FGMO
89	Shahbazar 88MW PP (Shahbazar)	RPP	32'2.90	88	78	1573440	Engine problem
90	Shahbazar 50MW PP (EPL)	RPP	27'2.0	50	0	0	Contact expired
91	Sylhet 150 MW CAPP	PDB	1'142	142	235	4849030	
92	Sylhet 20 MW GTTP	PDB	1'20	20	19	453000	
93	Sylhet 50MW PP (EPL)	RPP	27'2	50	0	0	Contact Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	545944	
95	Bibara-II 341 MW CAPP (Summit)	IPP	1'22+1'119	341	300	7347000	FGMO
96	Bibara-II 400 MW CAPP	PDB	400 MW	400	0	0	Under maint.
97	Sylhet 10MW PP (Dash)	RPP	6'1.95	10	9	187440	
Sylhet Area Total				1949	1322	30075348	
98	Bheramara GTTP Unit-1,2 & 3	PDB	3'20	46	0	0	Reserve
**	Bheramara (HVDC)	Imported power	2'500	1000	942	17850181	
99	Khulna 115 MW PP (KPCL-2)	QRPP	1'17	115	0	239400	Reserve
100	Fariapur 50 MW Peaking PP	PDB	8'6.99	54	0	0	Reserve
101	Khulna 225 MW CAPP	NWPGCL	1'150+1'175	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve
103	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	250	7412832	Gas shortage.
104	Noapara 40 MW PP (Khanishan Ali)	QRPP	5'8.5	40	40	546750	
105	Noapara 100 MW PP (Banjila Trac)	IPP	70'1.4	100	100	120000	Low demand
106	Rupsha 105 MW PP (Ton rupsha)	IPP	6'18.445	105	105	1048800	
107	Mashumati 100 MW PP	IPP	100 MW	105	0	0	Reserve
Khulna Area Total				2314	1407	27015683	
108	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	
109	Barisal GT PP Unit-1& 2	PDB	2'20	30	0	0	Reserve
110	Bhola 33 MW PP (venture)	RPP	1'34.50	33	22	389200	Engine problem
111	Bhola 225 MW CAPP	PDB	2'63+1'68	194	149	3713137	
112	Bhola 95 MW PP (Agrako)	QRPP	95'1.10	95	0	0	
	Pavra 1320 MW	NWPGCL	0	0	402	7598200	On test
Barisal Area Total				462	573	11700537	
113	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	0	0	Reserve
115	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve
116	Amnara 50 MW PPI(Sinha)	QRPP	7'7.79	50	0	0	Fuel problem
117	Katakhali 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Reserve
118	Katakhali 50 MW Peaking PP	PDB	6'8.7	50	43	295049	
119	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	180	4206845	FGMO
120	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	160	4044945	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	2'144.15	220	0	0	Gas shortage.
122	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1'282+1'132	414	370	9064509	FGMO
123	Santahar 50 MW Peaking PP	PDB	6'8.7	50	0	0	Reserve
124	Bogra 22 MW PP (GBB)	RPP					