

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
				MW	MW	MW	
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2'55	85	0	0	Unit-1 & 2 Under maint.
	Ghorasal Repowered CCGP Unit-3	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CCGP Unit-4	PDB	1'210	180	220	3930000	
	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
3	Ghorashah 78.5 MW PP (MAX)	QRPP	2'40	78	61	1246560	Gas shortage.
4	Ghorashah 108MW PP (Regent)	IPP	34'3.35	108	107	1528454	
5	Haripur GTPP	SBU, PDB	2'32	40	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	329	8394680	FGMO
7	Haripur 360MW CCGP(MPL)	IPP	1'236+1'125	360	349	7472000	
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	450	8897250	
9	Meghnaghat 100 MW (EPL)	QRPP	1'27.9	100	100	1192320	
10	Meghnaghat CCRP(Summit)	IPP	2'110+1'110	305	0	0	FGMO
11	Madanganj 102 PP(Summit)	QRPP	6'17	100	92	1662842	
12	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	36	542694	Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	85	828973	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	16	125748	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	3184000	Gas shortage.
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	82	785280	Low demand
18	Siddhirgonj 335 MW CCGP	EGCB	1'217+118	335	0	0	Under S/D.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	84	518256	Low demand
20	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	51	48	322176	Engine problem
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	53	651960	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	149	770880	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	711008	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	289426	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel Shortage
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	47	1123980	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	24	462700	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	29	753700	Engine problem
29	Gazipur 52 MW PP	IPP	6'8.9	52	0	0	Reserve
30	Tongi 80 MW GTPP	IPP	1'105	105	0	0	under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	285	3776160	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	828973	Reserve
33	Bramanganj 100 MW PP (Aggreko)	IPP	100	100	0	6189	Reserve
34	Aurshahi 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	10078	Reserve
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3019680	
36	Gazipur 100 MW PP	RPCL	100 MW	105	88	957720	Engine problem
Dhaka area Total				5811	2993	53993507	
37	Chattogram TPP-1	PDB	1'210	180	90	2200000	Gas shortage.
	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage.
38	Razzan 25 MW PP	IPP	3'8.9	25	25	177732	
39	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	112725	
40	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	50	830400	
41	Kapali Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	32	797660	Low water level
42	Sikalbaha 225MW	PDB	1'150+1'175	225	217	5144447	FGMO
43	Sikalbaha Peaking GT	PDB	1'150	150	139	3323704	FGMO
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	IPP	105 MW	105	0	0	Reserve
45	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under maint.
46	Dohazari-Kalaish 100 MW Peaking	PDB	6'17	102	102	1023696	
47	Juidah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	40	242400	Low demand
48	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2447040	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	22	512352	
*	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	42	623040	
50	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	96	1203840	Engine problem
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	38160	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	199	4237855	Low demand
53	Jodiak Power	IPP	3'18.55+1'3.6	54	0	0	Reserve
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve
	Juidah unit-2	IPP	0	0	100	2428800	
Chattogram area Total				2166	1254	25343851	
55	Ashuganj TPP Unit-3	APSCL	1'150	135	135	2728536	Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1'150	129	0	0	Gas shortage.
	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage.
56	Ashuganj 225 MW CCGP	APSCL	1'142+1'175	221	215	3882000	FGMO
57	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	310	7829700	FGMO
58	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	275	6882000	FGMO
59	Ashuganj 50 MW PP	APSCL	14'3.968	45	42	787104	
60	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	49	741600	
62	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'116	195	157	802909	Gas shortage.
63	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	970388	
64	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	147	1639327	
66	Titas 50 MW Peaking PP	PDB	6'8.92	52	39	88472	
67	Chandpur 150 MW CCGP	PDB	1'106+1'57	163	0	0	Under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	98	273600	Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	458856	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	237960	
**	Impoort (Tripura)	Imported power	0	160	190	3783360	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	0	760400	
72	Jangalia 52 MW PP (Lakhdanavi)	IPP	6'8.92	52	35	231150	Low demand
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	463280	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve
	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1865040	
	Chomuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2531760	
Cumilla Area Total				2880	2019	37156442	
75	RPCL 210MW CCGP	IPP	4'35+1'70	202	171	4315520	Gas shortage.
76	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	272844	
77	Jamalpur 95 MW PP (Powerpac)	IPP	12'8.924	95	95	542400	
78	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	16000	
79	Mymensingh 200 MW PP (United)	IPP	200	200	172	2284800	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1020000	#REF!
Mymensingh Area Total				637	575	8451564	
81	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	85	2028000	
82	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	30	726000	
83	Kushiyara 163 MW CCGP (KP)	IPP	1'109+1'54	163	130	3421145	Frequency Control.
84	Shajibazar 330 MW CCGP	PDB	3'110	330	187	4386000	FGMO & ST under S/D
85	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	840600	
86	Fenchugonj 44MW (Energyprima)	RPP	12'3.4+5'2	44	50	985608	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	220000	
88	Shajibazar GTTP Unit- 8 & 9	PDB	2'35	66	61	1407456	FGMO
89	Shajibazar 86MW PP (Shajibazar)	RPP	32'2.90	86	76	1247040	
90	Shajibazar 50MW PP (EPL)	RPP	27'2.0	50	0	0	Contact expired
91	Syhet 150 MW CCGP	PDB	1'142	142	149	3505220	
92	Syhet 20 MW GTTP	PDB	1'20	20	18	429000	
93	Syhet 50MW PP (EPL)	RPP	27'2	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	374352	
95	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	270	7249000	FGMO
96	Bibiyana-II 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.
97	Syhet 10MW PP (Desh)	RPP	6'1.95	10	10	240840	
Syhet Area Total				1949	1146	27042261	
98	Bheranara GTTP Unit-1,2 & 3	PDB	3'20	46	0	0	Reserve
**	Bheranara (IWDG)	Imported power	2'500	1000	937	2204363	
99	Khulna 115 MW (KPCL-2)	QRPP	7'17	115	99	1912320	Engine problem
100	Fariapur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve
101	Khulna 225 MW CCGP	NWPGCL	1'150+1'175	230	0	0	Reserve
102	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve
103	Bheranara 410 MW CCGP	NWPGCL	1'278+1'132	410	330	8254368	FGMO
104	Noapara 40 MW PP (Kharjahan Ali)	QRPP	5'8.5	40	40	536250	
105	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	90	939840	Engine problem
106	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	105	933600	
107	Madhumati 100 MW PP	IPP	100 MW	105	105	463824	
Khulna Area Total				2314	1706	35044565	
108	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	110	965184	
109	Barisal GT PP Unit-1& 2	PDB	2'20	30	0	0	Reserve
110	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	33	654313	
111	Bhola 225 MW CCGP	PDB	2'63+1'68	194	83	2015325	
112	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	82	2084562	Engine problem
	Payra 1320 MW	NWPGCL	0	0	250	9893400	On test
Barisal Area Total				462	558	15612784	
113	Baghabari 71 MW GTTP	PDB	1'71	71	0	325000	Gas shortage.
	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	43	237063	Low demand
115	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve
116	Amnura 50 MW PP(Sinha)	QRPP	7'7.9	50	50	598410	
117	Katakali 50 MW PP (Northern)	QRPP	6'8.9	50	34	124469	Engine problem
118	Katakali 50 MW Peaking PP	PDB	6'8.7	50	38	155285	
119	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	0	0	Gas shortage.
120	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	161	4363464	FGMO
121	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	191	4831864	FGMO
122	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1'282+1'132				