

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 28-Jun-20

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|-------------------------------|--|----------------------|---------------------|------------------|----------------------|------------------|------------------------|
| | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*55 | 85 | 35 | 730000 | Unit-2 Under maint. |
| | Ghorasal Repowered CCPP Unit-3 | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CCPP Unit-4 | PDB | 1*210 | 180 | 0 | 0 | Under maint. |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 0 | 0 | Under maint. |
| 2 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 205 | 3051545 | |
| 3 | Ghorashal 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 73 | 1230880 | |
| 4 | Ghorashal 108MW PP (Regent) | IPP | 3*3.35 | 108 | 101 | 2154681 | |
| 5 | Haripur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CCPP | EGCB | 1*273+1*139 | 412 | 0 | 0 | Under maint. |
| 7 | Haripur 360MW CCPP(HPL) | IPP | 1*235+1*125 | 360 | 352 | 7654000 | FGMO |
| 8 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 420 | 8981250 | Frequency control |
| 9 | Meghnaghat 100 MW (EL) | QRPP | 12*8.9 | 100 | 100 | 1700160 | |
| 10 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 305 | 255 | 5970298 | FGMO |
| 11 | Nadanganj 102 PP(Summit) | QRPP | 8*17 | 150 | 96 | 2031192 | |
| 12 | Nadanganj-55 MW PP(Summit) | (IPP) | 3*17.08+1*11.3 | 55 | 40 | 750881 | Engine problem |
| 13 | Keraniganj 100 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 0 | 0 | Reserve |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 372816 | |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 90 | 13720000 | Gas shortage. |
| 17 | Siddhirgonj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 100 | 99 | 1600320 | |
| 18 | Siddhirgonj 335 MW CCPP | EGCB | 1*217+1*118 | 335 | 328 | 6944330 | |
| 19 | Gagnagar 102 MW PP (Digital Power) | IPP | 12*8.924 | 102 | 84 | 1631376 | Engine problem |
| 20 | Kaipoti 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 0 | 0 | Reserve |
| 21 | Kamalaghat 54 MW PP(Banco Energy) | IPP | 3*18 | 54 | 53 | 606960 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 0 | 449760 | Reserve |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 928434 | |
| 24 | Nababganj 55 MW PP (Southern power) | IPP | 3*19.3 | 55 | 17 | 261277 | Low demand |
| 25 | Bosila 108MW PP(ELC) | IPP | 12*8.975+1*3.5 | 108 | 0 | 0 | Fuel Shortage |
| 26 | Summit Power, (Madhabdi+Ashulia) | SIPP, REB | 3*3.67+4*8.73 | 80 | 55 | 1274100 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 791300 | |
| 28 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 775700 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 0 | 22548 | Reserve |
| 30 | Tongi 80 MW GTPP | PDB | 1* 105 | 105 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 115 | 1339854 | Low demand |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 256*1.4 | 300 | 0 | 0 | Reserve |
| 33 | Bramhangaoan 100 MW PP (Aggreko) | IPP | 100 | 100 | 0 | 0 | Reserve |
| 34 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | Reserve |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 129 | 3094560 | Engine problem |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 0 | 621348 | Reserve |
| | Sonarganj 104 MW (Orion) | IPP | 18.9*5 | 100 | 108 | 2492160 | |
| Dhaka area Total | | | | 5791 | 2898 | 7118730 | |
| 37 | Chattoagram TPP-1 | PDB | 1*210 | 180 | 95 | 2200000 | Gas shortage. |
| | Chattoagram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage. |
| 38 | Racazan 25 MW PP | IPP | 3*8.9 | 25 | 0 | 0 | Reserve |
| 39 | Teknaf 20MW PP (Solartech) | Teknaf Solartech Ene | 20 | 20 | 0 | 63855 | |
| 40 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 0 | 0 | Reserve |
| 41 | Kaptai Hydro Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 103 | 2454798 | Low water level |
| 42 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 0 | 0 | Under S/d. |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 140 | 3348924 | FGMO |
| 44 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 105 MW | 105 | 0 | 0 | Reserve |
| 45 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 9 | 38878 | Low demand |
| 46 | Dohazari -Kalaish 100 MW Peaking | PDB | 6*17 | 102 | 51 | 253194 | Low demand |
| 47 | Juldah 100 MW Unit-1 (Acorn) | QRPP | 8*13.45 | 100 | 0 | 0 | Reserve |
| 48 | Juldah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 100 | 2434560 | |
| 49 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 18 | 381024 | |
| | Manancha, Ctg. EPZ (United) | IPP | 5*8.73+3*9.34 | 0 | 35 | 571680 | |
| 50 | Chattoagram 108 MW PP (ECPV) | IPP | 7.4 | 106 | 0 | 16*7 | Reserve |
| 51 | Kaptai 7 MW Solar PP | PDB | 7.4 | 7 | 0 | 23280 | |
| 52 | Anwara 300 MW PP (United) | IPP | 300 MW | 300 | 233 | 3562909 | Low demand |
| 53 | Jodiac Power | IPP | 3*18.55+1*3.6 | 54 | 0 | 35194 | Reserve |
| 54 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | Reserve |
| | Juldah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 90 | 2282880 | Engine problem |
| Chattoagram area Total | | | | 2266 | 874 | 17651176 | |
| 55 | Ashuganj TPP Unit- 3 | APSCL | 1*150 | 135 | 0 | 0 | Gas shortage. |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 80 | 2117530 | Gas shortage. |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 0 | 0 | Gas shortage. |
| 56 | Ashuganj 225 MW CCPP | APSCL | 1*142+1*75 | 221 | 181 | 4591000 | FGMO |
| 57 | Ashuganj 450 MW CCPP(North) | APSCL | 1*360 | 360 | 320 | 7271900 | FGMO |
| 58 | Ashuganj 450 MW CCPP(South) | APSCL | 1*360 | 360 | 310 | 6941000 | FGMO |
| 59 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 41 | 899712 | |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 25 | 473760 | Gas shortage. |
| 62 | Ashuganj 195MW PP (APSCL-United) | IPP | 20*9.73+1*16 | 195 | 8 | 418181 | Gas shortage. |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 43 | 1053203 | Engine problem |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 10 | 252581 | Low demand |
| 65 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 0 | 0 | Reserve |
| 67 | Chandpur 150 MW CCPP | PDB | 1*106+1*157 | 163 | 90 | 2053990 | |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 0 | 0 | Reserve |
| 69 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 21 | 448776 | |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 0 | 99720 | Engine problem |
| ** | Impoort (Tripura) | Imported power | 0 | 160 | 108 | 2415360 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 25 | 606500 | Engine problem |
| 72 | Jangalia 52 MW PP (Lakdhanav) | IPP | 6*8.92 | 52 | 16 | 76094 | Low demand |
| 73 | Cumilla 25 MW CCPP | SIPP, PDB | 3*3.25+2*5.97 | 25 | 21 | 438600 | Engine problem |
| 74 | Daukandi 200 MW PP (B. Trac) | IPP | 154*1.4 | 200 | 0 | 0 | Reserve |
| | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 0 | 0 | Reserve |
| | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 113 | 2093280 | |
| Cumilla Area Total | | | | 2980 | 1412 | 32251487 | |
| 75 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 157 | 3694000 | Gas shortage. |
| 76 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 20 | 413316 | |
| 77 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 24 | 583680 | Engine problem |
| | Sarshabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 9750 | |
| 79 | Mymensingh 200 MW PP (United) | IPP | 200 | 200 | 192 | 2484000 | |
| 80 | Jamalpur 115 MW PP (United) | IPP | 115 MW | 115 | 109 | 2547600 | #REF! |
| Mymensingh Area Total | | | | 637 | 502 | 9732346 | |
| 81 | Fenchuganj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 75 | 1775000 | |
| 82 | Fenchuganj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 30 | 254000 | Under maint. |
| 83 | Kushlari 163 MW CCPP (KP) | IPP | 1*109+1*54 | 163 | 130 | 3304473 | Frequency control |
| 84 | Shahjibazar 330 MW CCPP | PDB | 3*110 | 330 | 309 | 6863000 | FGMO & ST under S/D |
| 85 | Fenchuganj 51 MW PP (Barakatullah) | RPP | 19*2.90 | 51 | 47 | 979800 | |
| 86 | Fenchuganj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 44 | 46 | 1098684 | |
| 87 | Hobuganj 11MW PP (Cofidence-E) | SIPP, REB | 4*2.90 | 11 | 11 | 264000 | |
| 88 | Shahjibazar GTTP Unit- 8 & 9 | PDB | 2*18 | 61 | 61 | 1132320 | FGMO |
| 89 | Shahjibazar 86MW PP (Shahjibazar) | RPP | 32*2.90 | 86 | 74 | 1529280 | Engine problem |
| 91 | Sylhet 225 MW CCPP | PDB | 1*142+1*89 | 231 | 150 | 3070000 | |
| 92 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 18 | 435000 | |
| 93 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | Contract Expired |
| 94 | Shahjahanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 24 | 570096 | |
| 95 | Bibiana-II 341 MW CCPP (Summit) | IPP | 1*222+1*119 | 341 | 315 | 7412800 | FGMO |
| 96 | Bibiyana-III 400 MW CCPP | PDB | 400 MW | 400 | 0 | 0 | Under maint. |
| 97 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 247660 | |
| | Bibiyana South 400 MW | PDB | 400 MW | 0 | 0 | 0 | On test |
| Sylhet Area Total | | | | 1988 | 1300 | 28936583 | |
| 98 | Bheramara GTTP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | Reserve |
| ** | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 936 | 22469090 | |
| 99 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 115 | 99 | 850560 | Engine problem |
| 100 | Faridpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 0 | 0 | Reserve |
| 101 | Khulna 225 MW CCPP | NWPGCL | 1*150+1*75 | 229 | 0 | 0 | Reserve |
| 102 | Gopalganj 100 MW Peaking PP | PDB | 6*6.98 | 100 | 0 | 0 | Reserve |
| 103 | Bheramara 410 MW CCPP | NWPGCL | 1*278+1*132 | 410 | 375 | 8519040 | FGMO |
| 104 | Noopara 40 MW PP (Khanjahan Ali) | QRPP | 5*8.5 | 40 | 40 | 461250 | |
| 105 | Noopara 100 MW PP (Bangla Trac) | IPP | 70*1.4 | 100 | 0 | 55680 | |
| 106 | Rupsha 105 MW PP (Orion rupsha) | IPP | 6*18.445 | 105 | 0 | 0 | Reserve |
| 107 | Madhumati 100 MW PP | IPP | 100 MW | 105 | 0 | 0 | Reserve |
| Khulna Area Total | | | | 2284 | 1450 | 32355620 | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 80 | 832416 | |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 36 | 668284 | |
| 111 | Bhola 225 MW CCPP | PDB | 2*63+1*68 | 194 | 87 | 2095689 | GT-2 & ST Under maint. |
| 112 | Bhola 95 MW PP (Aggreko) | QRPP | 96*1.10 | 95 | 77 | 1464398 | Engine problem |
| | Payra 1320 MW | BCPCL | 1*622 | 622 | 622 | 1363320 | |
| Barisal Area Total | | | | 1054 | 912 | 16893987 | |
| 113 | Baghabari 71 MW GTTP | PDB | 1*71 | 71 | 0 | 120000 | Gas shortage. |
| | Baghabari 100 MW GTTP | PDB | 1*100 | 100 | 60 | 1481000 | Gas shortage. |
| 114 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 0 | 0 | |
| 115 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 0 | 0 | Reserve |
| 116 | Amnura 50 MW PP(Sinha) | QRPP | 7*7.79 | 50 | 0 | 0 | Fuel shortage |
| 117 | Katakhat 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 0 | 0 | Reserve |
| 118 | Katakhat 50 MW Peaking PP | PDB | 6*8.9 | 50 | 0 | 0 | Reserve |
| 119 | Sirajgonj Unit-1 225MW | NWPGCL | 1*150+1*75 | 210 | 0 | 0 | Gas shortage. |
| 120 | Sirajgonj Unit-2 225MW | NWPGCL | 1*150+1*75 | 220 | 200 | 4369027 | FGMO |
| 121 | Sirajgonj Unit-3 225MW | NWPGCL | 1*141 | 220 | 196 | 4386391 | FGMO |
| 122 | Sirajgonj 400 MW CCPP Unit-4 | SNWPGCL | 1*282+1*132 | 414 | 415 | 9226763 | FGMO |
| 123 | Santalar 50 MW Peaking PP | PDB | 6*8.7 | 50 | 0 | | |